

CONSULTANCY CELL

Dr. A.P.J. Abdul Kalam Technical University
Faculty of Architecture & Planning
(Incorporating Former Lucknow College of Architecture)
Tagore Marg, Lucknow - 226 007 (U.P.) India
Phone: +91 522 2741598 (Telefax): +91 522 2741598 (EPBAX)



डॉ० ए० पी० जे० अब्दुल कलाम प्रौद्योगिक विश्वविद्यालय
वास्तुकला एवं योजना संकाय
(पूर्ववर्ती लखनऊ वास्तुकला महाविद्यालय संयुक्तित)
टैगोर मार्ग, लखनऊ-226007 (उ.प्र.) भारत
दूरभाष: +91522 2741598 (टेलीफैक्स) +915222741598 (ई.पी.ए.ए.)
वेबसाइट: www.iaaahlu.ac.in ई-मेल: drapj@iaaahlu.ac.in

Date: 08/10/2025

Ref: Consultancy/Material-Testing Report/2025-26/01-1547

To,
Executive Engineer
UPRNS, Construction Division-III
5/148 Vikas Nagar Lucknow-226028

Subject: - Material Testing Report

Sir,

As per your Letter No. 390/UPRNS/नि०प्र०मु०-III/2025-26 Dated 22.07.2025 regarding material testing for construction work of Registrar office Safipur, Unnao (U.P.)
The test results are as follows -

1. C.C. Cube

Average Compressive Strength :

27.85 N/mm²

2. Steel Reinforcement Bar

Ultimate Tensile Strength of Bar diameter

08 mm

555 N/mm²

10mm

560 N/mm²

12mm

560 N/mm²

16mm

570 N/mm²

3. Coarse Aggregate

S.No.	Sieve size (mm)	% passing in Result
1	80 mm	100
2	63mm	100
3	40 mm	100
4	20 mm	89
5	16 mm	87
6	12.5 mm	86.4
7	10 mm	9.96
8	4.75 mm	1
9	2.36 mm	0
10	1.18	0

Er. Kumar Vanshaj
(Assistant Professor
M.Tech.-Structures)

Er. Ekta
(Assistant Professor,
M.Tech.-Structures)