

CONSULTANCY CELL

J. Abdul Kalam Technical University

Faculty of Architecture & Planning

Incorporating Lucknow College of Architecture

Lucknow - 226 007 (U.P.) India

Phone: +91 522 2741588 (TANPA), +91 522 2741588 (BPBX)



डी.ए.के.टी.यू. जवाहर लाल नेहरू प्रतिष्ठान
वास्तुकला एवं योजना संकाय
पूर्ववर्ती लखनऊ वास्तुकला महाविद्यालय एवं
होस्टल मार्ग, लखनऊ- 226007 (U.P.) भारत
दूरभाष - +91522 2741588 (टीएनपीए) +91522 2741588 (बीएबीएक्स)
वेबसाइट: www.facastu.ajktu.ac.in, ईमेल: dean.facastu@ajktu.ac.in

Ref. Consultancy/Material-Testing/2023-24/ 01-1340

Date 29/09/2023

To,
Executive Engineer,
UPRNSS, Construction Division -III
Lucknow


Subject: - Material Testing Report


Sir,

As per your Letter No. 834/यू.पी.आर.एन.एस.एस.नि.ल.-III/2023-24 Dated 23.08.2023 regarding material testing for construction of P.G. hostel at Rajkiya National Homeopathic Medical College and Hospital Lucknow.

The test results are as follows: -

S. No.	Materials	Tests	Result
1	Brick	Average Compressive Strength	15.10 N/mm ²
2	C.C Cube	Average Compressive Strength	32.80 N/mm ²
3	Mortar	Mortar Ratio	1 : 6


Er. Kumar Vanshaj
(Assistant Professor
M.Tech. Structures)
ER. KUMAR VANSHAJ
Assistant Professor (M. Tech Structure)
Faculty of Architecture & Planning
Dr. A.P.J. Abdul Kalam Technical University, Lucknow


Er. Ekta
(Assistant Professor,
M.Tech. Structures)
ER. ERTA
Assistant Professor (M. Tech Structure)
Faculty of Architecture & Planning
Dr. A.P.J. Abdul Kalam Technical University, Lucknow

CONSULTANCY CELL

Dr. A.P.J. Abdul Kalam Technical University
Faculty of Architecture & Planning
(Incorporating Former Lucknow College of Architecture)
Tagore Marg, Lucknow - 226 007 (U.P.) India
Phone: +91 522 2741568 (Telex); +91 522 2741568 (EPBAX)



डॉ० ए० पी० जे० अब्दुल कलाम तकनीक विश्वविद्यालय
वास्तुकला एवं योजना संकाय
(पूर्ववर्ती लखनऊ वास्तुकला महाविद्यालय संयुक्तित)
टैगोर मार्ग, लखनऊ-226007 (उ.प्र.) भारत
दूरभा. : +91522 2741568 (टेलीफोन) +915222741568 (ईपीएक्स)
फैक्स: +91522 2741568 (ईपीएक्स)

Ref. Consultancy/Material-Testing/2023-24/01-89

Date: 30-1-24

To,
Executive Engineer,
UPRNS, Construction Division-III
Lucknow.

Subject :- Material Testing Report.

Sir,

As per your Letter No. 1529/यू०पी०आर०एन०एस०एस०नि०प्र०ल०-III/2023-24 Dated- 22.01.2024 regarding material testing for P.G. Hostel. The Results are as follows :-

S. No.	Materials	Tests	Results
1.	Brick	Average Compressive Strength	15.20 N/mm ²
2.	C.C. Cube	Average Compressive Strength	25.80 N/mm ²
3.	Mortar	Mortar Ratio	1:5:9


Er. Kumar Vanshaj
(Assistant Professor
M.Tech-Structures)
Assistant Professor (M.Tech Structures)
Faculty of Architecture & Planning
Dr. A.P.J. Abdul Kalam Technical University, Lucknow


Er. Ekta
(Assistant Professor,
M.Tech - PGTAures)
Assistant Professor (M.Tech Structures)
Faculty of Architecture & Planning
Dr. A.P.J. Abdul Kalam Technical University, Lucknow