

CONSULTANCY CELL

A.P.J. Abdul Kalam Technical University
Faculty of Architecture & Planning
 (Incorporating Former Lucknow College of Architecture)
 Sector Marg, Lucknow - 226 007, (U.P.) India
 Phone: +91 522 2741568 (Telefax); +91 522 2741568 (FAX)



डॉ० ए० पी० जे० अब्दुल कलाम प्राविधिक विश्वविद्यालय
वास्तुकला एवं योजना संकाय
 (पूर्ववर्ती लखनऊ वास्तुकला महाविद्यालय संयुक्तित)
 देगोड मार्ग, लखनऊ-226007 (उ.प्र.) भारत
 टेलफोन: +91522 2741568 (टेलीफोन) +91522 2741568 (फैक्स)
 ईमेल: dean.foa@aktu.ac.in, वेबसाइट: www.foa.aktu.ac.in

Ref: Consultancy/Material-Testing/2023-24/ 01-1339

Date 29/09/2023

To,
 Executive Engineer,
 UPRNSS, Construction Division -III
 Lucknow

Subject: - Material Testing Report

Sir,

As per your Letter No. 691/यू.पी.आर.एन.एस.एस.नि.ल.-III/2023-24 Dated 31.07.2023 regarding material testing for construction of Kasturba Gandhi Balika Vidyalaya, Shahanabad moon road (Bilhari), District Hardoi (U.P.)

The test results are as follows: -

S. No.	Materials	Tests	Result
1.	Brick	Average Compressive Strength	15.25 N/mm ²
2.	C.C Cube	Average Compressive Strength	27.80 N/mm ²
3.	Mortar	Mortar Ratio	1 : 4

Er. Kumar Vanshaj
 (Assistant Professor
 M.Tech.-Structures)

Er. KUMAR VANSHAJ
 Assistant Professor (M. Tech Structure)
 Faculty of Architecture & Planning
 Dr. A.P.J. Abdul Kalam Technical University, Lucknow

Er. Ekta
 (Assistant Professor,
 M.Tech.-Structures)

Er. EKTA
 Assistant Professor (M. Tech Structure)
 Faculty of Architecture & Planning
 Dr. A.P.J. Abdul Kalam Technical University, Lucknow