

NCY CELL

Kalam Technical University
Architecture & Planning
Lucknow College of Architecture
Lucknow - 226 007, (U.P.) India
E-MAIL: (Tel: 0522 2741588) (EPBAX)

सं. ए. पी. ओ. अब्दुल कलाम प्राविधिक विश्वविद्यालय
वास्तुकला एवं योजना संकाय
पूर्ववर्ती संस्करण वास्तुकला महाविद्यालय संयुक्तित
देगौर मार्ग, लखनऊ-226007 (उ.प्र.) भारत
दूरभा. +91522 2741588 (टेलीफोन) +915222 741588 (टेलीफैक्स)
वेबसाइट: www.ikarakiu.ac.in, ई.मेल. ikarakiu.ac.in

Date: 20/05/2023

Consultancy/Material-Testing/2022-23/ 01-530

Executive Engineer,
JPRNSS, Construction Div-III
Lucknow(U.P.)

Subject: - Material Testing Report

Sir,

As per your Letter No. यू.पी.आर.एन.एस.एस.नि.प्र.ल.-3/1769 Dated 22.02.2023 regarding material testing for construction of Hostel at Kasturba Gandhi Balika Vidhyalaya Safipur, District-Unnao (U.P)

The test results are as follows: -

S. No.	Materials	Tests	Result
1.	Brick	Average Compressive Strength	15.26 N/mm ²
2.	C.C Cube	Average Compressive Strength	27.10 N/mm ²
3.	Mortar	Mortar Ratio	1 : 4

Er. Kumar Vanshaj
(Assistant Professor
M.Tech.-Structures)

Er. Ekta
(Assistant Professor,
M.Tech.-Structures)

P.W.D. DISTRICT LABORATORY, UNNAO



Date 30/08/2023

सहायक अभियन्ता
प्रांतीय खण्ड लोकोपयोगिक
उन्नाव
Lab. No. 2023-24

Laboratory Sample No. 194/B/DL/AE/08/2023-24

of Material

Sample Submitted By A.E.

Letter No.

Material to be used

Examined for

Serial No.

Sl. No.

1

2

3

4

5

Frog. Mark

Load in Kg.

Compressive Strength Kg. / CM²

35800

149

36800

152

35800

150

(G.B.F.)

Average

150

Note : 1- The result only pertains to the particular sample submitted for the test.
2- The samples submitted are Destroyed during the test.
3- The laboratory will not be responsible regarding the interpretation of the results.

Lab Asst.
District Lab

Office in Charge
जनपदीय प्रयोगशाला
प्रांतीय खण्ड लोकोपयोगिक
P.W.D. Unnao

Tested By

Copy to -

OFFICE IN CHARGE
DISTT. LAB P.W.D. UNNAO