

Table 1: BGST Dataset Comparison

S.No	PD Types (BGST)	% Rule-Based (20dB)	% Rule-Based (50dB)	%SVM (20dB)	%SVM (50dB)	%CNN (20dB)	%CNN (50dB)
1	Simulated (116)	100.00	100.00	100	100	100	100
2	Sharp (116)	98.28	99.14	98.30	99.17	99.13	99.13
3	Void (253)	36.76	47.83	64.63	62.05	64.44	62.89
4	Surface (253)	98.02	97.63	86.37	82.41	82.31	83.10

Table 2: CST Dataset Comparison

S.No	PD Types (CST)	% Rule-Based (20dB)	% Rule-Based (50dB)	%SVM (20dB)	%SVM (50dB)	%CNN (20dB)	%CNN (50dB)
1	Simulated (116)	100.00	100.00	100	100	100	100
2	Sharp (116)	96.55	96.55	99.17	99.17	99.13	99.13
3	Void (253)	62.45	81.03	68.78	72.53	61.32	60.49
4	Surface (253)	66.01	45.06	71.15	59.49	76.39	78.31

Table 3: HST Dataset Comparison

S.No	PD Types (HST)	% Rule-Based (20dB)	% Rule-Based (50dB)	%SVM (20dB)	%SVM (50dB)	%CNN (20dB)	%CNN (50dB)
1	Simulated (116)	100.00	100.00	100	100	100	100
2	Sharp (116)	0.00	99.14	98.30	99.13	93.13	93.13
3	Void (253)	36.76	47.04	65.62	67.57	67.02	65.23
4	Surface (253)	98.81	98.81	87.75	80.73	85.80	81.14