# Fire Dynamics Compartment fire phenomena III

Haejun Park




#### Objectives

Understanding post-flashover phenomena and structural fire safety



# Compartment fire HRR curve





# Concerns in post-flashover

- Occupants life safety is already determined!
- Fire spread beyond the fire compartment (property protection)
  - Performance of passive systems
  - Performance of active systems
- Structural stability (property protection, firefighters' life safety)




# Passive system/structural element performance

- Fire-resistance rating (ASTM E119)
  - At least 2 hr or at most 2 hr?
  - https://www.youtube.com/watch?v=hUrDtttCwRE
  - https://www.youtube.com/watch?v=J0j54i7zArY(1:42 sec)




### Passive system performance

- 2 hr fire-resistance rating
  - Per ASTM E119 (standard time temp. curve)
  - Parametric fire (Eurocode BS EN 1991-1-2-2002)
  - Real fire ?





#### Equivalent time concept





### Equivalent time formula

```
t_e = e_f k_b w_f where,
```

 $t_e$ : Equivalent time to the standard test [min]

 $e_f$ : Fire load density [MJ/m<sup>2</sup>]

 $k_h$ : Heat loss factor

 $w_f$ : Ventilation factor



## Fire load density

• Eurocode fire load density [MJ/m<sup>2</sup>]

Occupancy	Average	80% Fractile
Dwelling	780	948
Hospital (room)	230	280
Hotel (room)	310	377
Library	1 500	1 824
Office	420	511
Classroom of a school	285	347
Shopping centre	600	730
Theatre (cinema)	300	.365
Transport (public space)	100	122



## Equivalent time formula

Depending on the wall surface materials,

- Thermal conductivity [J/m-K]
- Density [kg/m<sup>3</sup>]
- Specific heat [J/kg-K]

k <sub>b</sub> [min/MJ-m <sup>2</sup> ]	$\sqrt{k ho c}$ [J/s $^{0.5}$ -m $^2$ -K]
0.08	<720
0.055	720< <2500
0.045	>2500



#### Equivalent time formula

$$w_f = \left(\frac{6.0}{H}\right)^{0.3} \left[0.62 + \frac{90(0.4 - \alpha_v)^4}{1 + (b_v \alpha_h)}\right]$$

where,

$$\alpha_v = \frac{A_v}{A_f} = \frac{\text{Opening area on walls}}{\text{Enclosure floor area}}$$

$$0.05 \le \alpha_v \le 0.25$$

$$\alpha_h = \frac{A_h}{A_f} = \frac{\text{Opening area on the roof}}{\text{Enclosure floor area}}$$

$$\alpha_h \leq 0.25$$

$$b_{v} = 12.5(1+10\alpha_{v} - \alpha_{v}^{2})$$



#### Practical meaning of equivalent time

- Comparison of the estimated failure time (=equivalent time) to the time unit in the fire resistance rating of actual construction
- Equivalent time << fire rating in hr : safe</li>




# Fire ratings


• UL Fire Resistance Directory website



#### Example

– Calculate equivalent times for the following compartments. If the structural loadbearing walls are 1 hr fire rated, is it deemed to be structurally safe?





- Retail shop
- Thermal conductivity = 0.2 W/m-K
- Density = 800 kg/m3
- Specific heat = 1200 J/kg-K

