



Fire Protection Hydraulics and Water Supply Analysis

FPST 2483 Chapter 11
Elevated tanks

1



Module objective

- Upon completing this module, the student should be able to understand:
 - Elevated tanks
- Reading materials
- Brock's book, chapter 11


2




Elevated tanks


- Graphically representing the water supply available from an elevated storage tank.
 - Determine the height from the test location to the bottom of the tank; (Note: bottom of tank is used to be on the safe side since tank will only be full when flow first begins.)
 - Height to bottom of tank times 0.433 gives static pressure head.
 - Assume any reasonable flow and calculate friction loss from tank to test point.
 - Subtract friction loss from static pressure and plot result above flow used to get the friction loss.

3




Elevated water tank






- Static pressure
= $70 \times 0.433 = 30$ psi
- Friction loss:
@500', 6", C=100 assume
500 gpm $\rightarrow P_f = 7.0$ psi
- Residual pressure @500
gpm is
 $30 - 7 = 23$ psi


4



5




Gravity tank




- In reality, a gravity tank seldom feeds a dead end main and most often supports an existing water system.
- Therefore, to graphically represent the contribution of the tank requires testing the existing system and the tank independently, then combining the results.

6

6




Parallel supply




- Combining hydrant test data with supply available from elevated tanks
 - Plot water supply curve from test data with elevated tank turned off.
 - Plot water supply curve from test data with elevated tank turned on and city supply turned off.
 - At various pressures add the flows contributed by each supply.


7

7



65x0.433=28 psi







- Note the flow test results must be adjusted to the elevation of the bottom of the tank so the results will be valid until the tank is empty.
- Also, the tank will not be considered contributing until city pressure drops below 28 psi.

8


8





9




Combined water supply




- City water supply: Static 68psi, Residual = 12 psi with 800 gpm
- Water tank: 65 ft high, 8" pipe (C=100, D=8.23"), L=1300 feet


10

10



11