GOVERNMENT OF TELANGANA
ELECTRICAL INSPECTORATE
(An IS/ISO 9001: 2015 Certified Department)

From

The Electrical Inspector/Nizamabad
D.No.10-2-177/1
Munnur Kapu Sangam Building,Nizamabad-503001.
Phone No: **07382618537**

To

M/s: **LAXMI GANAPATHI AGRO INDUSTRIES**
Street: Indaram
H.No/D.No.: Sy.No.593,594/E,595/A,596
Sy. No.: Sy.No.593,594/E,595/A,596
(V): Indaram
(M): Jaipur
(D): Mancherial
Pincode: 504216 , Phone No: 7396838387

Lr.No.EI-NZB/TG/EI Ex. 650V/**HT-MCL-2025-20027**/D.No. 409/**2026** Dated: 25/03/2026

Sub : The Electricity Act-2003 and Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2023 - Electrical Installation of Voltage Exceeding 650 V of M/s **LAXMI GANAPATHI AGRO INDUSTRIES**, **Indaram Jaipur** Mandal **Mancherial** District - Statutory Approval under Section 54 of the Electricity Act-2003 and Regulation - **45(3)** of CEA (Measures Relating to Safety and Electric Supply), Regulations 2023 Accorded.

Ref:- 1) Inspection Dated **17/03/2026**

2) Your Lr. received on dated., 25/03/2026

***

Under Section 54 of The Electricity Act-2003 and Regulations **45(3)** of Central Electricity Authority (Measures relating to Safety and Electric Supply)Regulations,2023, the following equipment of your Electrical Installation of voltage Exceeding 650V are approved for energisation.

AS PER ANNEXURE ENCLOSED.

Under Regulation 45(6) of Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2023, any additions or alteration in your installation shall not be connected to supply until the same are approved in writing by this office and offer for annual inspection under Regulation 32 of Central Electricity Authority(Measures relating to Safety and Electric Supply)Regulations, 2023 every year to the concerned Deputy Electrical Inspector.

Under Regulation 15(4), 48(7) of Central Electricity Authority(Measures relating to Safety and Electric Supply)Regulations, 2023, you are at all times solely responsible for the maintenance of the above installation on such condition as to be free from danger.

The above approval accorded is without prejudice to the statutory/ mandatory obligations to be fulfilled by you under various other acts and rules as the case may be. The approval accorded for energizing the electrical equipment is the safety for men and machine from electrical hazards in your installation and ipso facto does not confer any right to be used for any other purpose other than for which the approval is accorded.

Yours faithfully

Digitally signed by MADHU PORIKA
Date: 2026.03.25 13:55:15 +05'30'

ELECTRICAL INSPECTOR, NIZAMABAD

Encl:- List of Load Particulars

Copy to The Superintendent Engineer / Operation/ TGSPDCL or TGNPDCL to verify our Department approval before release of supply from the link in third party verification https://tgceig.cgg.gov.in/SearchIndustry.do

Lr.No:E.I/NZB/TG/EI. Ex. 650V/HT-MCL-2025-20027/D.No:409/2026, Dated: 25-03-2026.

M/S. LAXMI GANAPATHI AGRO INDUSTRIES, SY.NO.593, 594/E, 596, INDARAM (V), JAIPUR (M), MANCHERIAL DISTRICT.

Sl.No.	Particulars of Equipment	MAKE	SERIAL NO.	CAPACITY / VOLTAGE RATIO
I	**HT INSTALLATION**			
a.	TRANSFORMER	V.V.E	V-1229	200KVA, 11KV/433V
b.	HT LBS	G5 SWITCHGEAR	2508102	630A,11KV
II	**MV INSTALLATION**			
a.	M.V LOAD	----	----	224HP,415V
b.	CAPACITOR	----	----	100KVAR
III	**L.V.INSTALLATION**			
a.	L.V LOAD	----	----	10KW,230V

Digitally signed by MADHU PORIKA
Date: 2026.03.25 13:55:46 +05'30'

ELECTRICAL INSPECTOR
NIZAMABAD