GOVERNMENT OF TELANGANA

BOILERS DEPARTMENT

FORM VI

TELANGANA STATE BOILER INSPECTION DEPARTMENT
CERTIFIFCATE FOR USE OF A BOILER

[REGULATIONS 389]

No.57/ 2024-25

Registry Number of Boiler : **TS/0748**

Type of Boiler : **Package Boiler - High Risk**

Boiler Rating : **112.00 Square Meter**

Place & Year of manufacture:
RANIPET - 2019

Maximum Continuous Evaporation : **3360.00 kg/hr**

Name of Owner: M/s **M/s VYANKTESH PACKAGING (HYDERABAD) PVT LTD**

Situation of Boiler : **Kompalle(V),Qutubullapur(M),Medchal(D)**

Repairs :

Remarks : **Ensure safety valve working periodically.**

Hydraulically tested on 25/07/2024 to 21.75 Kilogram per Square Centimeters.

I hereby certify that the above described boiler is permitted by me / the Director under the provisions of Section 8 of the Boilers Act, No V of 1923,to be worked at maximum pressure of **14.50** Kilogram per Square Centimeters. for the period from **26/07/2024** to **16/07/2025**

The loading of the **DSL** safety valve is not to exceed **14.50** Kilogram per Square Centimeters.

Fee : 4450, paid on :16/07/2024, Challan No :113378500960

Dated at :Hyderabad

This : 31/07/2024

T.E OF SPL L-217.69 Mtrs satisfactory

BOGADA HIMA BINDU

Digitally signed by BOGADA HIMA BINDU
DN: c=IN, o=DIRECTOR OF BOILER, ou=DIPUTY CHIEF INSPECTOR OF BOILERS SPECIAL OFFICER, 2.5.4.20=f51bb89db051c01a373263721e37567bcaf25b047316a0797ec342703132fb35, postalCode=500013, st=TELANGANA, serialNumber=4a71f9ebda5340fba81e25be2ee61ca311bdb960800c6afd2a4800131b63d232, cn=BOGADA HIMA BINDU
Date: 2024.07.31 15:03:31 +05'30'

Deputy Chief Inspector of Boilers (Speci Officer), Hyderabad

Director Of Boilers

Telangana State, Hyderabad