SOUTHERN POWER DISTRIBUTION COMPANY OF T.G LIMITED

From,
THE CHIEF ENGINEER
OPERATION
RANGA REDDY ZONE
TGSPDCL
HYDERABAD

To,
M/S. PRAVARTH BEVERAGES I
SY NO: 25/E/2/1
Mirjaguda
Mirjaguda
Rangareddy

LR.NO. CE/OP/RRZ/DET/ADE-T/F.TURNKEY/D.NO. 3670 /2024-25, DT: 24 .09.2024

Sub:- Revised of Auto-estimate for extension of HT supply at 11KV level for a CMD of 78KVA with a connected load of 99HP to M/s. Pravarth Beverages India Private Limited represented by Sri A Sridhar Rao, Sy. No: 25/E/2/1 situated at Mirzaguda Village in Ope ration Section Chevella of Operation Sub-Division Chevella in Ibrahimbagh Division of Cybercity circle under Capital works - Turnkey - Regarding.

Ref No: MEMO.NO. CE/OP/RRZ/DET/ADE-T/F.CAPITAL/D.NO. 3669 /2024-25, DT: 24 .09.2024
Estimate Number: E-2024-65-01-12-01-051 Reg no. HT99943773

The permission accorded is subjected to the following conditions:

1. The work should be executed by a Licensed Contractor as per the standards of TGSPDCL under supervision of THE CHIEF ENGINEER COMMERCIAL CORPORATE OFFICE.

2. The material used in the work should confirm to TGSPDCL specifications.

3. Major materials like AB Switches, HG Fuse sets, Conductor,Structure steel and other materials should be purchased as per TGSPDCL specifications along with test certificate from TGSPDCL vendor. The bills/voucher of materials purchased along with test certificate should be produced to concerned CSC/ICSC before execution of work or uploaded in the TGSPDCL Website.

4. The work executed by consumer shall be taken over by the TGSPDCL after statuary inspection by TGSPDCL Officials. The installation shall be deemed to the property of TGSPDCL after such takeover.

5. The consumer shall clear off the dues of UDC/Bill stopped services if any existing in the premises or found at a later date and no court cases pending. If any legal disputes arise electricity supply will be disconnected to the premises.

6. There should not be any 11 KV /LT lines passing through from other source of supply in the proposed premises.

7. Distribution Transformer will be provided by TGSPDCL by collecting the cost of DTR/Development charges whichever is higher, however, in case of auto-generated (TGipass and HT) estimates, transformer is to be procured by consumer.

8. Obtaining CEIG/CEA approval for electrical installing. Obtaining NOC as per requirement of A.P Fire Services act 1999, Multi-storied building regulations.

9. No service connection shall be released for Multi-storied buildings / Complexes greater than 10Mtrs in height unless occupancy certificate from concerned authorities.

10. If unforeseen calamities/ accidents occur during the execution of work, the TGSPDCL authorities are not held responsible for such incidents and consequential losses or damages. It is the responsibility of the consumer for any loss of material utilised in completing the work till all the services contemplated in the proposal are released.

SOUTHERN POWER DISTRIBUTION COMPANY OF T.G LIMITED

Description of Demand	Original Demand Notice Amount (In Rs)	Revised Demand Notice Amount (In Rs)	Paid Amount (In Rs)	To be paid Amount (In Rs)
Application Fees	100	0	0	0
CGST on Application Fee	9	0	0	0
SGST on Application Fee	9	0	0	0
Supervision Charges	383,976.47	207,896.15	383,976.47	0
CGST on Supervision charges	34,557.88	18,710.65	34,557.88	0
SGST on Supervision charges	34,557.88	18,710.65	34,557.88	0
Security Deposit	117,000	117,000	117,000	0
Development Charges	93,600	93,600	93,600	0
CGST on Development Charges	8,424	8,424	8,424	0
SGST on Development Charges	8,424	8,424	8,424	0
Rounded-off cost	0.77	0.55	0.77	0
Total Cost	680,659	472,766	680,541	0

11. You are requested to pay an Amount of Rs.0.00 through adjusted bill.

12. Payments must be received on or before 18-12-2024 ,If not received existing registration will be cancelled.

Note :

**** This is a Revised sanction. Previous sanction was done inCGM_COMMLlogin on20240703**

SD/-

CHIEF GENERAL MANAGER