GOVERNMENT OF TELANGANA

BOILERS DEPARTMENT

FORM VI

TELANGANA STATE BOILER INSPECTION DEPARTMENT
CERTIFIFCATE FOR USE OF A BOILER

[REGULATIONS 389]

No.JD 403/2023-24

Registry Number of Boiler : **TS/1191**

Type of Boiler : **Assembled Boiler - High Risk**

Boiler Rating : **224 Square Meter**

Place & Year of manufacture: **SURAT,2022**

Maximum Continuous Evaporation : **4500.00 kg/hr**

Name of Owner: M/s **MEENAKSHI PAPER MILLS PVT.LTD**

Situation of Boiler : **Satamrai(V),Shamshabad(M),Rangareddy(D)**

Repairs : **NIL**

Remarks : **Management instructed to check the operation of safety valves and quality of feed water periodically**

Hydraulically tested on 19/02/2024 to 15.80 Kilogram per Square Centimeters.

I hereby certify that the above described boiler is permitted by me / the Director under the provisions of Section 8 of the Boilers Act, No V of 1923,to be worked at maximum pressure of **10.54** Kilogram per Square Centimeters. for the period from **19/02/2024** to **15/02/2025**

The loading of the **DSL** safety valve is not to exceed **10.54** Kilogram per Square Centimeters.

Fee : 4300, paid on :09/02/2024, Challan No :113173019487

Dated at :Hyderabad

This : 20/02/2024

T.E OF TS/SPL-749, L-150.30 Mtrs Satisfactory

NULU SRINIVASARAO

Digitally signed by NULU SRINIVASARAO
DN: cn=NULU SRINIVASARAO, o=JOINT DIRECTOR OF BOILERS, ou=DIRECTOR OF BOILERS, email=jointdobts@gmail.com, c=US
Date: 2024.02.20 22:08:17 +05'30'

Joint Director Of Boilers TS HYD

Director Of Boilers

Telangana State, Hyderabad