GOVERNMENT OF TELANGANA

BOILERS DEPARTMENT

FORM VI

TELANGANA STATE BOILER INSPECTION DEPARTMENT
CERTIFIFCATE FOR USE OF A BOILER

[REGULATIONS 389]

No.HR-140/2023-24

Registry Number of Boiler : **TS/1032**

Type of Boiler : **Package Boiler - High Risk**

Boiler Rating : **173 Square Meter**

Place & Year of manufacture: **PUNJAB, 2021**

Maximum Continuous Evaporation : **5000 kg/hr**

Name of Owner: M/s **NCL INDUSTRIES LIMITED(DOORS DIVISION)**

Situation of Boiler : **Malkapur(V),Choutuppal(M),Yadadri(D)**

Repairs : **nil**

Remarks : **Ensure proper working of safety valves, twice a day.**

Hydraulically tested on 12/12/2023 to 26.4 Kilogram per Square Centimeters.

I hereby certify that the above described boiler is permitted by me / the Director under the provisions of Section 8 of the Boilers Act, No V of 1923,to be worked at maximum pressure of **17.6** Kilogram per Square Centimeters. for the period from **12/12/2023** to **01/12/2024**

The loading of the **DSL** safety valve is not to exceed **17.6** Kilogram per Square Centimeters.

Fee : 5450, paid on :09/10/2023, Challan No :113038891979

Dated at :Warangal

This : 13/12/2023

T.E OF SPL F/R

NARESH KUMAR AAVULA

Digitally signed by NARESH KUMAR AAVULA
DN: c=IN, o=OFFICE OF THE DEPUTY CHIEF INSPECTOR OF BOILERS WARANGAL REGION, ou=OFFICE OF THE DEPUTY CHIEF INSPECTOR OF BOILERS, WARANGAL REGION, 2.5.4.20=24dce371d073b505e788b7c4c914e8c4f28044d98e690084aeb362330496bb61, postalCode=506001, st=TELANGANA, serialNumber=531d7cefb68c111efbc8bb67dbfb117340436c9e997ad25465291d25055f6b38, cn=NARESH KUMAR AAVULA
Date: 2023.12.13 17:57:52 +05'30'

Deputy Chief Inspector of Boilers (Warangal Region), Warangal

Director Of Boilers

Telangana State, Hyderabad

CONDITIONS

(1) No structural alteration, addition or renewal shall be made to the boiler otherwise than in accordance with section 12 of the Act.

(2) Under the provisions of Section 8 of the Act this certificate shall cease to be in force:

(a) On the expiry of the period for which it was granted; or

(b) When any accident occurs to the boiler; or

(c) When the boiler is moved the boiler not being vertical boiler the heating surface of which is less than two hundred square feet, or a portable or vehicular boiler; or

(d) save as provided in section 12 of the Act, when any structural alteration, addition or renewal is made in or to the boiler; or

(e) If the Director in any particular case so directs when any structural alteration, addition or renewal is made in or to any steam-pipe attached to the boiler; or

(f) On the communication to the owner of the boiler of an order of the Director or Inspector prohibiting its use on the ground that it or any boiler component attached thereto is in a dangerous condition.

Under Section 10 of the Act, when the period of a certificate relating to a boiler has expired, the owner shall, provided that he has applied before the expiry of that period for a renewal of the certificate be entitled to use the boiler at the maximum pressure entered in the former certificate, pending the issue of orders on the application but this shall not be deemed to authorise the use of a boiler in any of the cases referred to in clauses (b), (c), (d), (e) and (f) of sub-section (1) of section 8 occurring after the expiry of the period of the certificate.

(3) The boiler shall not be used at a pressure greater than the pressure entered in the certificate as the maximum pressure nor with the safety valve set to a pressure exceeding such maximum pressure.

(4) The boiler shall not be used otherwise than in a condition which the owner reasonably believes to be compatible with safe working.

(5) Form-VI shall be countersigned by the Director at the time of Registration only as per the provisions of sub section (5) of section 7 of the Act.

Note: The particulars and dimensions regarding this boiler may be obtained by the owner on payment in the prescribed manner on application to the Director