CITY OF CLEVELAND HEIGHTS

HOUSING INSPECTION DEPARTMENT

Garage - Exterior

14. **Properly remove. REMOVE DETERIORATING WINDOW UNIT AND SIDE OVER**
    Section: 1351.23, 1369.02
15. **Clean out gutter(s).**
    Section: 1351.25, 1369.04

Exterior - Yard

16. **Make drain fully operable. DRIVEWAY DRAIN**
    Section: 1351.13, 1369.08
17. **Cut tall grass/weeds & properly maintain landscaped areas..**
    Section: 1351.29, 1775.10

Basement - Main Room

1. **Replace missing pilot cover on hot water tank..**
   Section: 1351.13, 1369.08
2. **Properly install hot water tank flue pipe, maintaining a 1/4 inch per foot rise. CORRECT NEGATIVE PITCH**
   Section: 1351.18, 1369.10
3. **Make light fixture fully operable.**
   Section: 1351.20, 1369.09
4. **Properly install a smoke detector. This violation requires immediate compliance.**
   Section: 1351.211
5. **Properly install a CO detector outside of the sleeping area in the immediate vicinity of the bedrooms or within the bedroom where a fuel-burning appliance is located. Including one on every level where a fuel-burning appliance is located.**
   Section: 1103.09

Stairway to 1st Floor

6. **Make light fixture fully operable.**
   Section: 1351.20, 1369.09
7. **Properly replace. REPLACE CLOSER FOR SECURITY DOOR**
   Section: 1351.23, 1369.02

1st Floor - Kitchen

CITY OF CLEVELAND HEIGHTS

HOUSING INSPECTION DEPARTMENT

Basement - Main Room

1. **Replace missing pilot cover on hot water tank..**
   Section: 1351.13, 1369.08
2. **Properly install hot water tank flue pipe, maintaining a 1/4 inch per foot rise. CORRECT NEGATIVE PITCH**
   Section: 1351.18, 1369.10

Dear

I am pleased to report that a reinspection of your property indicates that all violations noted in our inspection report have been corrected.

The City's inspection programs are designed to ensure that properties are preserved and maintained in good repair. While this process may be inconvenient at times, such a policy is necessary if our community is to remain an attractive and desirable place in which to live.

On behalf of the City of Cleveland Heights, please let me take this opportunity to thank you for your efforts to complete the repairs called for in your inspection notice.