

PID Algorithm Basics

1. Introduction


PID performs proportional, integral, and derivative operations on the input deviation, and the superposition result of the operations controls the actuator. The formula is as follows:

$$u(t) = K_p [e(t) + \frac{1}{T_i} \int_0^t e(t) dt + T_d \frac{de(t)}{dt}]$$

It consists of three parts:

- P is proportional, which is the input deviation multiplied by a coefficient;
- I is integral, which performs integral operation on the input deviation;
- D is derivative, which performs derivative operation on the input deviation.

As shown in the figure below is a basic PID controller:



(1) Proportional Part

The mathematical expression of the proportional part is: $K_p \cdot e(t)$

In analog PID controllers, the role of the proportional link is to react instantly to deviations. Once a deviation occurs, the controller immediately produces a control action that changes the control quantity in the direction of reducing the deviation. The strength of the control action depends on the proportional coefficient. The larger the proportional coefficient, the stronger the control action, the faster the transition process, and the smaller the static deviation of the control process; however, the larger it is, the more likely it is to produce oscillations, destroying system stability. Therefore, the selection of the proportional coefficient must be appropriate to achieve the effects of short transition time, small static deviation, and stability.

Advantages: Adjust the system's open-loop proportional coefficient to improve the system's steady-state accuracy, reduce system inertia, and speed up response time.

Disadvantages: Using only a P controller, an excessively large open-loop proportional coefficient not only increases the system's overshoot but also reduces the system's stability margin, possibly causing instability.

(2) Integral Part

The mathematical expression of the integral part is:

$$\frac{K_p}{T_i} \int_0^t e(t)dt$$

The larger the integral constant, the weaker the cumulative effect of integration. At this time, the system will not oscillate during transition; however, increasing the integral constant will slow down the process of eliminating static errors, and the time required to eliminate deviations is longer, but it can reduce overshoot and improve system stability. When T_i is smaller, the integral effect is stronger. At this time, the system may oscillate during the transition time, but the time required to eliminate deviations is shorter. Therefore, T_i must be determined according to the specific requirements of actual control.

Advantages: Eliminate steady-state errors.

Disadvantages: The addition of an integral controller affects system stability and reduces the system's stability margin.

(3) Derivative Part

The mathematical expression of the derivative part is:

$$K_p * Td \frac{de(t)}{dt}$$

The role of the derivative link is to prevent changes in deviation. It controls based on the trend of deviation changes (rate of change). The faster the deviation changes, the larger the output of the derivative controller, and it can make corrections before the deviation value becomes larger. The introduction of the derivative effect will help reduce overshoot, overcome oscillations, and make the system tend toward stability, which is particularly beneficial for high-order systems as it speeds up the system's tracking speed. However, the derivative effect is very sensitive to input signal noise. Generally, derivative control is not used for systems with high noise, or the input signal is filtered before the derivative effect takes effect. The effect of the derivative part is determined by the derivative time constant Td . The larger Td is, the stronger its effect of suppressing deviation changes; the smaller Td is, the weaker its effect of resisting deviation changes. The derivative part obviously has a great effect on system stability. Properly selecting the derivative constant Td can make the derivative effect optimal.

Advantages: Makes the system's response speed faster, reduces overshoot, alleviates oscillations, and has a "prediction" effect on dynamic processes.

2. Selection of PID Algorithms

Digital PID control algorithms can be divided into positional PID and incremental PID control algorithms. Before deciding which PID algorithm to use, we should first understand its principle:

- Positional PID Algorithm:

$$u(k) = K_p e(k) + K_I \sum_{i=0}^k e(i) + K_D [e(k) - e(k-1)]$$

$e(k)$: user-set value (target value) - current state value of the controlled object

Proportional P: $e(k)$

Integral I: $\Sigma e(i)$ cumulative error

Derivative D: $e(k) - e(k-1)$ current error - previous error

That is, positional PID performs PID control based on the deviation between the current actual position of the system and the expected position you want to achieve

Because of the error integral $\Sigma e(i)$, which keeps accumulating, the current output $u(k)$ is related to all past states, using the cumulative value of errors; (error e will have error accumulation), the output $u(k)$ corresponds to the actual position of the actuator. Once the control output is wrong (the current state value of the controlled object has problems), large changes in $u(k)$ will cause large changes in the system. When the integral term of positional PID reaches saturation, the error will still continue to accumulate under the integral effect. Once the error starts to change in the opposite direction, the system needs a certain time to exit the saturation zone. Therefore, when $u(k)$ reaches maximum and minimum, the integral effect should be stopped, and there should be integral limiting and output limiting. Therefore, when using positional PID, we generally directly use PD control, while positional PID is suitable for objects whose actuators do not have integral components, such as servos and balance car upright and temperature control system control

Advantages: Positional PID is a non-recursive algorithm that can directly control actuators (such as balance cars). The value of $u(k)$ corresponds one-to-one with the actual position of the actuator (such as the current angle of the car), so it can be well applied in objects whose actuators do not have integral components

Disadvantages: Each output is related to past states, and $e(k)$ needs to be accumulated during calculation, resulting in a large computational workload.

- Incremental PID:

$$\Delta u(k) = u(k) - u(k-1) = K_P[e(k) - e(k-1)] + K_i e(k) + K_D[e(k) - 2e(k-1) + e(k-2)]$$

Proportional P: $e(k) - e(k-1)$ current error - previous error

Integral I: $e(k)$ error

Derivative D: $e(k) - 2e(k-1) + e(k-2)$ current error - 2*previous error + error before previous

Incremental PID can be clearly seen from the formula. Once KP, TI, and TD are determined, as long as the deviation of the last three measurement values is used, the control increment can be calculated from the formula. The resulting control amount $\Delta u(k)$ corresponds to the increment of recent position errors, not the deviation corresponding to the actual position. There is no error accumulation, meaning that incremental PID does not need accumulation. The determination of the control increment $\Delta u(k)$ is only related to the most recent 3 sampling values, making it easy to obtain better control effects through weighting, and when system problems occur, incremental will not seriously affect system work

Summary: Incremental PID takes the increment of positional PID. At this time, the controller outputs the difference between the position values calculated at two adjacent sampling moments. The result is the increment, that is, on the basis of the previous control amount, the control amount needs to be increased (negative value means reduced).

Advantages: ① Small impact when malfunctioning, and if necessary, logical judgment methods can be used to remove erroneous data.

② Small impact during manual/automatic switching, facilitating bumpless switching. When computer fails, it can still maintain the original value.

③ No accumulation required in the formula. The determination of control increment $\Delta u(k)$ is only related to the most recent 3 sampling values.

Disadvantages: ① Large integral truncation effect, with steady-state errors;

② Large impact of overflow. Some controlled objects are not suitable for incremental;

- Differences Between Incremental and Positional

(1) Incremental algorithms do not need accumulation. The determination of control increment is only related to the most recent few deviation sampling values, and the impact of calculation errors on control quantity calculation is small. Positional algorithms need to use the accumulated value of past deviations, which easily produces larger accumulation errors.

(2) Incremental algorithms produce the increment of control quantity. For example, in valve control, only the change part of valve opening is output. The impact of malfunctioning is small, and if necessary, the current output can be limited or prohibited through logical judgment without seriously affecting system work. Positional output directly corresponds to the object's output, thus having a larger impact on the system.

(3) Incremental PID controls the increment of control quantity and has no integral effect, so this method is suitable for objects whose actuators have integral components, such as stepper motors, while positional PID is suitable for objects whose actuators do not have integral components, such as electro-hydraulic servo valves.

(4) When performing PID control, positional PID needs integral limiting and output limiting, while incremental PID only needs output limiting. Positional PID and incremental PID are just two implementation forms of digital PID control algorithms, essentially identical. The main difference is the storage method of integral terms. Positional PID stores integral terms separately, while incremental PID stores integral terms as part of the output. Various players online also have their unique insights and views on the use of positional and incremental forms. Specifically, we still need to see which algorithm is suitable for our specific application scenario.

3. Tuning of PID Parameters

There are many methods for selecting PID controller parameters, such as trial and error method, critical proportion method, expanded critical proportion method, etc. However, for PID control, parameter selection is always a very cumbersome task, requiring constant adjustment to obtain satisfactory control effects. Based on experience, the general steps for determining PID parameters are as follows:

- Determine Proportional Coefficient K_p

When determining the proportional coefficient K_p, first remove the integral and derivative terms of PID, can set T_i=0, T_d=0, making it

pure proportional control. Input is set to 60% to 70% of the system's allowed maximum output. The proportional coefficient K_p gradually increases from 0 until the system oscillates; then conversely, gradually decrease the proportional coefficient K_p from this point until the system oscillation disappears. Record the proportional coefficient K_p at this time, and set the PID's proportional coefficient K_p to 60% to 70% of the current value.

- Determine Integral Time Constant T_i

After the proportional coefficient K_p is determined, set a larger integral time constant T_i, then gradually decrease T_i until the system oscillates, then conversely, gradually increase T_i until the system oscillation disappears. Record the T_i at this time, and set the PID's integral time constant T_i to 150% to 180% of the current value.

- Determine Derivative Time Constant T_d

The derivative time constant T_d generally does not need to be set, can be 0, at which time PID control converts to PI control. If setting is needed, it is the same as the method for determining K_p, taking 30% of its value when not oscillating.

- System No-load, Load Joint Debugging

Fine-tune PID parameters until performance requirements are met.

of course, this is just my personal debugging method and may not necessarily be suitable for everyone and every environment. It is only provided for everyone's reference; however, there are also classic trial-and-error formulas for debugging PID circulating online. I have also posted them for everyone's reference:

Parameter tuning to find the best, check in order from small to large.

First proportional then integral, finally add derivative.

Curve oscillates frequently, proportional dial should be enlarged.

Curve floats around large bends, proportional dial should be turned smaller.

Curve deviates and recovers slowly, integral time should be decreased.

Curve fluctuation period is long, integral time should be increased.

Curve oscillation frequency is fast, first reduce derivative.

Large dynamic error and slow fluctuation, derivative time should be increased.

Ideal curve has two waves, front high back low four to one.

Look, adjust, and analyze more, regulation quality won't be low.

PID is proportional (P), integral (I), derivative (D) control algorithm, and it's not necessary to have all three algorithms simultaneously. It can also be PD, PI, or even only P algorithm control. My previous most basic idea for closed-loop control was only P control - feedback the current result, subtract from the target, if positive, decelerate, if negative, accelerate. Of course, this is just the simplest closed-loop control algorithm. Going back to the summary of positional and incremental from the previous section, we need to refer to our current control environment specifically, because each control system is different, and the parameters that can make our system achieve the most stable effect are naturally OK.