DOC name: Issued Date:

Version:

自主 SAT 測試表格



Project name:

Typical Type:RTU

Station: SCADA #6 (2F 電驛室)

			RT	U#1							
	Device		SCADA	4/畫面	SCADA	A / 畫面	SCADA	4/畫面	SCADA	4/畫面	
no.	Manual 敘述	中文敘述	正確	不正確	正確	不正確	正確	不正確	正確	不正確	備註
001	Q01_CB Close Block	1650_CB 投入閉鎖									
002	Q01_CB Trip Block	1650_CB Trip Block									
003	Q01_CB SF6 Stage 1	1650_CB SF6 Stage 1									
004	Q01_CB SF6 Stage 2	1650_CB SF6 Stage 2									
005	Q01_HYDR.Pump fault	1650_HYDR.Pump fault									
006	Q01_AC MCBS Tripped	1650_AC MCBS Tripped									
007	Q01_DC MCBS Tripped	1650_DC MCBS Tripped									
008	Q01_BP11 SF6 stage 1	1650_BP11 SF6 stage 1									
009	Q01_BP04 SF6 stage 1	1650_BP04 SF6 stage 1									
	Q01_ SF6 stage 2 (Collected Alarm)	1650_ SF6 stage 2 (Collected Alarm)									
	MTR#1_86T1 Trip	MTR#1_86T1 Trip									
012	87T/51G_ 43-11 Enable	87T/51G_ 43-11 Enable									
013	87T/51G_ 43-11 Disable	87T/51G_ 43-11 Disable									
014	50/51_43-12 Enable	50/51_43-12 Enable									
015	50/51_43-12 Disable	50/51_43-12 Disable									
	Q01_Control OFF	1650_Control OFF									
	Q01_LCC Control	1650_LCC Control									
018	Q01_RCP Control	1650_RCP Control									
	Q01_SCADA Control	1650_SCADA Control									
	MTR#1_86P Trip	MTR#1_86P Trip									
	MTR#1 _86P_43 Enable	MTR#1 _86P_43 Enable									
022	MTR#1_86P_43 Disable	MTR#1_86P_43 Disable									
023	Q02_CB Close Block	1660_CB投入閉鎖									
024	Q02_CB Trip Block	1660_CB Trip Block									
	Q02_CB SF6 Stage 1	1660_CB SF6 Stage 1									
026	Q02_CB SF6 Stage 2	1660_CB SF6 Stage 2									
027	Q02_HYDR.Pump fault	1660_HYDR.Pump fault									
028	Q02_AC MCBS Tripped	1660_AC MCBS Tripped									
029	Q02_DC MCBS Tripped	1660_DC MCBS Tripped									
030	Q02_BP11 SF6 stage 1	1660_BP11 SF6 stage 1									1

DOC name: Issued Date:

Version:



Project name:

Typical Type:RTU

Station: SCADA #6 (2F 電驛室)

SAT Date:

bianon. by	CADA #U (ZI 电对主)	SAT Date.					Г		T .		
			_	`U#1							
	Device		SCADA	A/畫面	SCADA	A/畫面	SCADA	1/畫面	SCADA	1/畫面	
no.	Manual 敘述	中文敘述	正確	不正確	正確	不正確	正確	不正確	正確	不正確	備註
031	Q02_BP04 SF6 stage 1	1660_BP04 SF6 stage 1									
032	Q02_ SF6 stage 2 (Collected Alarm)	1660_ SF6 stage 2 (Collected Alarm)									
033	MTR#2_86T2 Trip	MTR#2_86T2 Trip									
034	87T/51G_ 43-21 Enable	87T/51G_ 43-21 Enable									
035	87T/51G_ 43-21 Disable	87T/51G 43-21 Disable									
036	50/51_43-22 Enable	50/51_43-22 Enable									
037	50/51_43-22 Disable	50/51_43-22 Disable									
038	Q02_Control OFF	1660_Control OFF									
039	Q02_LCC Control	1660_LCC Control									
040	Q02_RCP Control	1660_RCP Control									
041	Q02_SCADA Control	1660_SCADA Control									
042	MTR#2_86P Trip	MTR#2_86P Trip									
043	MTR#2 _86P_43 Enable	MTR#2 _86P_43 Enable									
044	MTR#2_86P_43 Disable	MTR#2_86P_43 Disable									
045	Q03_CB Close Block	1510_CB投入閉鎖									
046	Q03_CB Trip Block	1510_CB Trip Block									
047	Q03_CB SF6 Stage 1	1510_CB SF6 Stage 1									
048	Q03_CB SF6 Stage 2	1510_CB SF6 Stage 2									
049	Q03_HYDR.Pump fault	1510_HYDR.Pump fault									
050	Q03_AC MCBS Tripped	1510_AC MCBS Tripped									
051	Q03_DC MCBS Tripped	1510_DC MCBS Tripped									
052	Q03_VT MCBS Tripped	1510_VT MCBS Tripped									
053	Q03_HVDS OFF	1510_HVDS OFF									
054	Q03_BP11 SF6 stage 1	1510_BP11 SF6 stage 1									
055	Q03_BP04 SF6 stage 1	1510_BP04 SF6 stage 1									
056	Q03_BP05 SF6 stage 1	1510_BP05 SF6 stage 1									
057	Q03_BP06 SF6 stage 1	1510_BP06 SF6 stage 1									
058	Q03_BP07 SF6 stage 1	1510_BP07 SF6 stage 1									
059	Q03_BP50 SF6 stage 1	1510_BP50 SF6 stage 1									
060	Q03_BP101 SF6 stage 1	1510_BP101 SF6 stage 1									

Version:

DOC name: Issued Date:



Project name:

Typical Type:RTU

Station: SCADA #6 (2F 電驛室)

SAT Date:

		SAT Daic.									
			RT	U#1							
	Device		SCADA	A/畫面	SCADA	A/畫面	SCADA	A / 畫面	SCADA	1/畫面	
no.	Manual 敘述	中文敘述	正確	不正確	正確	不正確	正確	不正確	正確	不正確	備註
061	Q03_BP102 SF6 stage 1	1510_BP102 SF6 stage 1									
062	Q03_BP103 SF6 stage 1	1510_BP103 SF6 stage 1									
063	Q03_BP1105 SF6 stage 1	1510_BP1105 SF6 stage 1									
064	Q03_BP111 SF6 stage 1	1510_BP111 SF6 stage 1									
065	Q03_BP112 SF6 stage 1	1510_BP112 SF6 stage 1									
066	Q03_BP120 SF6 stage 1	1510_BP120 SF6 stage 1									
067	Q03_ BE1 NO ERROR	1510_ BE1 NO ERROR									
068	Q03_ SF6 stage 2 (Collected Alarm)	1510 SF6 stage 2 (Collected Alarm)									
069	IN01_86L Trip	IN01_86L Trip									
070	87L1_ 43-31 Enable	87L1_ 43-31 Enable									
071	87L1_ 43-31 Disable	87L1_ 43-31 Disable									
072	DTT1_ 43-32 Enable	DTT1_ 43-32 Enable									
073	DTT1_ 43-32 Disable	DTT1_ 43-32 Disable									
074	21/21N-1_ 43-33 Enable	21/21N-1_ 43-33 Enable									
075	21/21N-1_ 43-33 Disable	21/21N-1_ 43-33 Disable									
076	67/67N-1_ 43-34 Enable	67/67N-1_ 43-34 Enable									
077	67/67N-1_ 43-34 Disable	67/67N-1_ 43-34 Disable									
078	50+2-1_ 43-35 Enable	50+2-1_ 43-35 Enable									
079	50+2-1_ 43-35 Disable	50+2-1_ 43-35 Disable									
080	87L2_ 43-36 Enable	87L2_ 43-36 Enable									
081	87L2_ 43-36 Disable	87L2_ 43-36 Disable									
082	DTT2_ 43-37 Enable	DTT2_ 43-37 Enable									
083	DTT2_ 43-37 Disable	DTT2_ 43-37 Disable									
084	21/21N-2_ 43-38 Enable	21/21N-2_ 43-38 Enable									
085	21/21N-2_ 43-38 Disable	21/21N-2_ 43-38 Disable									
086	67/67N-2_ 43-39 Enable	67/67N-2_ 43-39 Enable									
087	67/67N-2_ 43-39 Disable	67/67N-2_ 43-39 Disable									
088	50+2-2_ 43-40 Enable	50+2-2_ 43-40 Enable									
089	50+2-2_ 43-40 Disable	50+2-2_ 43-40 Disable									
090	Q04_CB Close Block	1670_CB投入閉鎖									

Version:

DOC name: Issued Date:



Project name:

Typical Type:RTU

Station: SCADA #6 (2F 電驛室)

SAT Date:

Device SCADA / 書面 SCADA /	oution. by		SAT Date.	RT	`U#1							
P文教速 中文教速 中流 下離 下離 下離 下離 下離 下離 下離 下		Device				SCADA	A / 畫面	SCADA	A / 畫面	SCADA	A / 畫面	
Q04_CB Trip Block	no.	Manual										
092 Q04_CB SF6 Stage 2 1670 CB SF6 Stage 2 9 094 Q04_CB SF6 Stage 2 9 9 094 Q04_HYDR.Pump fault 1670 LB SF6 Stage 2 9 095 Q04_AC MCBS Tripped 1670 AC MCBS Tripped 9 096 Q04_DC MCBS Tripped 9 9 097 Q04_BP11 SF6 stage 1 1670 BP11 SF6 stage 1 9 098 Q04_BP04 SF6 stage 1 1670 BP1 SF6 stage 1 9 099 Q04_SF6 stage 2 (Collected Alarm) 1670 SF6 stage 2 (Collected Alarm) 9 090 Q04_SF6 stage 2 (Collected Alarm) 1670 SF6 stage 2 (Collected Alarm) 9 100 MTR#3_86T3 Trip 1670 SF6 stage 2 (Collected Alarm) 9 101 877/S1G_43-41 Enable 877/S1G_43-41 Enable 9 102 877/S1G_43-41 Disable 9 10 103 50/51_43-42 Enable 9 10 10 104 50/51_43-42 Disable 9 10 10 10 105 Q04_Control OFF 1670 Control OFF 1670 Control OFF	091		1670 CB Trip Block									
Q04_CB SF6 Stage 2 1670 CB SF6 Stage 2 1670 AC MCBS Tripped 1670 AC MCBS Tripped 1670 DC MCBS Tripped 1670 DC MCBS Tripped 1670 DC MCBS Tripped 1670 DC MCBS Tripped 1670 BP11 SF6 stage 1 1670 BP11 SF6 stage 2 (Collected Alarm) 1670 SF0 stage 2 (Collecte												
094 Q04_HYDR.Pump fault 1670 HYDR.Pump fault												
095 Q04_AC MCBS Tripped 1670_AC MCBS Tripped 096 Q04_DC MCBS Tripped 097 Q04_BP11 SF6 stage 1 098 Q04_BP04 SF6 stage 1 099 Q04_SF6 stage 2 (Collected Alarm) 100 MTR#3_86T3 Trip 101 877/51G_43-41 Enable 102 877/51G_43-41 Disable 103 50/51_43-42 Enable 104 50/51_43-42 Disable 105 Q04_Control OFF 105 Q04_Control OFF 106 Q04_Control 107 Q04_SCADA Control 108 Q04_SCADA Control 109 MTR#3_86P_43 Enable	094	Q04_HYDR.Pump fault										
1670 DC MCBS Tripped 1670 DC MCBS Tripped 1670 DC MCBS Tripped 1670 DC MCBS Tripped 1670 BP11 SF6 stage 1 1670 BP11 SF6 stage 1 1670 BP11 SF6 stage 1 1670 BP04 SF6 stage 2 (Collected Alarm) 1670 SF6 stage 2 (Collect	095	Q04_AC MCBS Tripped										
097 Q04_BP11 SF6 stage 1 1670 BP11 SF6 stage 1 1670 BP04 SF6 stage 1 098 Q04_BP04 SF6 stage 1 1670 BP04 SF6 stage 1 1670 BP04 SF6 stage 1 099 Q04_SF6 stage 2 (Collected Alarm) 1670 SF6 stage 2 (Collected Alarm) 1670 SF6 stage 2 (Collected Alarm) 100 MTR#3_86T3 Trip MTR#3 86T3 Trip 1670 SF6 stage 2 (Collected Alarm) 101 87T/51G_ 43-41 Enable 87T/51G_ 43-41 Enable 102 87T/51G_ 43-41 Disable 1670 SF6 stage 2 (Collected Alarm) 103 50/51_43-42 Enable 1670 SF6 stage 2 (Collected Alarm) 104 50/51_43-42 Inable 1670 SF6 stage 2 (Collected Alarm) 105 50/51_43-41 Disable 1670 SF6 stage 2 (Collected Alarm) 106 50/51_43-42 Enable 1670 SF6 stage 2 (Collected Alarm) 107 50/51_43-42 Enable 1670 Control OFF 106 50/51_43-42 Enable 1670 Control OFF 107 204_RCP Control 1670 LCC Control 108 204_SCADA Control 1670 SCADA Control 109 MTR#3_86P_43 Enable 1670 SCADA Control 110 MTR#3_86P_43 Enable 1710 MTR#3_86P_43 Enable 111 MT	096											
098 Q04_BP04 SF6 stage 1 1670 BP04 SF6 stage 1 99 Q04_SF6 stage 2 (Collected Alarm) 1670_SF6 stage 2 (Collected Alarm) 1670_S	097	Q04_BP11 SF6 stage 1										
100 MTR#3_86T3 Trip MTR#3_86T3 Trip 101 87T/51G_ 43-41 Enable 87T/51G_ 43-41 Enable 102 87T/51G_ 43-41 Disable 87T/51G_ 43-41 Disable 103 50/51_43-42 Enable 50/51_43-42 Enable 104 50/51_43-42 Disable 50/51_43-42 Disable 105 Q04_Control OFF 1670_Control OFF 106 Q04_LCC Control 1670_LCC Control 107 Q04_RCP Control 1670_RCP Control 108 Q04_SCADA Control 1670_SCADA Control 109 MTR#3_86P Trip MTR#3_86P Trip 110 MTR#3_86P_43 Enable MTR#3_86P_43 Enable 111 MTR#3_86P_43 Disable MTR#3_86P_43 Disable	098	Q04_BP04 SF6 stage 1										
101 87T/51G_ 43-41 Enable 87T/51G_ 43-41 Enable 102 87T/51G_ 43-41 Disable 87T/51G_ 43-41 Disable 103 50/51_43-42 Enable 50/51_43-42 Enable 104 50/51_43-42 Disable 50/51_43-42 Disable 105 Q04_Control OFF 1670_Control OFF 106 Q04_LCC Control 1670_LCC Control 107 Q04_RCP Control 1670_RCP Control 108 Q04_SCADA Control 1670_SCADA Control 109 MTR#3_86P Trip MTR#3_86P Trip 110 MTR#3_86P_43 Enable MTR#3_86P 43 Enable 111 MTR#3_86P_43 Disable MTR#3_86P 43 Disable	099	Q04_ SF6 stage 2 (Collected Alarm)	1670_ SF6 stage 2 (Collected Alarm)									
102 87T/51G_ 43-41 Disable 87T/51G_ 43-41 Disable 97/51G_ 43-41 Disable 103 50/51_43-42 Enable 50/51_43-42 Enable 97/51G_ 43-42 Disable 104 50/51_43-42 Disable 97/51G_ 43-42 Disable 97/51G_ 43-42 Enable 105 Q04_Control OFF 1670_Control OFF 97/51G_ 43-42 Disable 97/51G_ 43-42 Enable 106 Q04_Control OFF 97/51G_ 43-42 Disable 97/51G_ 43-42 Enable 97/51G_ 43-42 Enable 107 Q04_Control OFF 97/51G_ 43-42 Disable 97/51G_ 43-42 Enable 97/51G_ 43-42 Enable 108 Q04_Control OFF 97/51G_ 43-42 Enable 97/51G_ 43-42 Enable 97/51G_ 43-42 Enable 97/51G_ 43-42 Enable 109 MTR#3_86P Trip 97/51G_ 43-42 Enable	100	MTR#3_86T3 Trip	MTR#3_86T3 Trip									
103 50/51_43-42 Enable 50/51_43-42 Enable 90.50/51_43-42 Enable 90.5	101	87T/51G_ 43-41 Enable	87T/51G_ 43-41 Enable									
104 50/51_43-42 Disable 50/51_43-42 Disable 105 Q04_Control OFF 1670_Control OFF 106 Q04_LCC Control 1670_LCC Control 107 Q04_RCP Control 1670_RCP Control 108 Q04_SCADA Control 1670_SCADA Control 109 MTR#3_86P Trip MTR#3_86P Trip 110 MTR#3_86P_43 Enable MTR#3_86P_43 Disable 111 MTR#3_86P_43 Disable MTR#3_86P_43 Disable	102	87T/51G_ 43-41 Disable	87T/51G_ 43-41 Disable									
105 Q04_Control OFF 1670_Control OFF 1670_LCC Control 106 Q04_LCC Control 1670_LCC Control 1670_LCC Control 107 Q04_RCP Control 1670_RCP Control 1670_RCP Control 108 Q04_SCADA Control 1670_SCADA Control 1670_SCADA Control 109 MTR#3_86P Trip MTR#3_86P Trip 1070_RTP 110 MTR#3_86P_43 Enable MTR#3_86P 43 Enable 1080_RTP 111 MTR#3_86P_43 Disable MTR#3_86P_43 Disable 1080_RTP	103	50/51_43-42 Enable	50/51_43-42 Enable									
106 Q04_LCC Control 1670_LCC Control 107 Q04_RCP Control 108 Q04_SCADA Control 109 MTR#3_86P Trip 110 MTR#3_86P_43 Enable 111 MTR#3_86P_43 Disable	104	50/51_43-42 Disable	50/51_43-42 Disable									
107 Q04_RCP Control 1670_RCP Control	105	Q04_Control OFF	1670_Control OFF									
108 Q04_SCADA Control 1670_SCADA Control 109 MTR#3_86P Trip MTR#3_86P Trip 110 MTR#3_86P_43 Enable MTR#3_86P_43 Enable MTR#3_86P_43 Disable 111 MTR#3_86P_43 Disable MTR#3_86P_43 Disable 111 MT	106	Q04_LCC Control	1670_LCC Control									
109 MTR#3_86P Trip MTR#3_86P Trip Incomparison of the property of	107	Q04_RCP Control	1670_RCP Control									
110 MTR#3 _86P_43 Enable MTR#3 _86P_43 Enable 111 MTR#3 _86P_43 Disable MTR#3 _86P_43 Disable	108	Q04_SCADA Control	1670_SCADA Control									
111 MTR#3_86P_43 Disable MTR#3_86P_43 Disable	109		MTR#3_86P Trip									
	110	MTR#3 _86P_43 Enable	MTR#3 _86P_43 Enable									
112ComFault	111	MTR#3_86P_43 Disable	MTR#3_86P_43 Disable									
	112	_ComFault	通訊異常									

DOC name: Issued Date:

SIEMENS

Project name:

Version:

Typical Type:RTU

Station: SCADA #6 (2F 電驛室)

SAT Date:

Station, BY	CADA #U (ZI · 电源主)	SAT Date.	RT	U#2							
	Device		SCADA	A / 畫面	SCADA	A/畫面	SCADA	1/畫面	SCADA	1/畫面	
no.	Manual 敘述	中文敘述				不正確					備註
001	Q05_CB Close Block	1680_CB Close Block									
002	Q05_CB Trip Block	1680_CB Trip Block									
003	Q05_CB SF6 Stage 1	1680_CB SF6 Stage 1									
004	Q05_CB SF6 Stage 2	1680_CB SF6 Stage 2									
005	Q05_HYDR.Pump fault	1680_HYDR.Pump fault									
006	Q05_AC MCBS Tripped	1680_AC MCBS Tripped									
007	Q05_DC MCBS Tripped	1680_DC MCBS Tripped									
008	Q05_BP11 SF6 stage 1	1680_BP11 SF6 stage 1									
009	Q05_BP04 SF6 stage 1	1680_BP04 SF6 stage 1									
010	Q05_ SF6 stage 2 (Collected Alarm)	1680_ SF6 stage 2 (Collected Alarm)									
011	MTR#4_86T4 Trip	MTR#4_86T4 Trip									
012	87B_86B Trip	87B_86B Trip									
013	87B_ 43-87B Enable	87B_ 43-87B Enable									
014	87B_ 43-87B Disable	87B_ 43-87B Disable									
015	87T/51G_ 43-51 Enable	87T/51G_ 43-51 Enable									
016	87T/51G_ 43-51 Disable	87T/51G_ 43-51 Disable									
017	50/51_43-52 Enable	50/51_43-52 Enable									
018	50/51_43-52 Disable	50/51_43-52 Disable									
019	Q05_Control OFF	1680_Control OFF									
020	Q05_RCP Control	1680_RCP Control									
021	Q05_SCADA Control	1680_SCADA Control									
022	MTR#4_86P Trip	MTR#4_86P Trip									
023	MTR#4 _86P_43 Enable	MTR#4 _86P_43 Enable									
024	MTR#4_86P_43 Disable	MTR#4_86P_43 Disable									
025	MTR1-OLTC Oil Level Low Alarm	MTR1-OLTC Oil Level Low Alarm									
026	MTR1-Buchholz Relay (1st) action	MTR1-Buchholz Relay (1st) action									
027	MTR1-Buchholz Relay (2st) action	MTR1-Buchholz Relay (2st) action									
028	MTR1Transformer Pressure equipment action	MTR1Transformer Pressure equipment action									
029	MTR1-OLTC Oil Temp Low Alarm	MTR1-OLTC Oil Temp Low Alarm									
030	MTR1-HV Winding oil Temp HI Alarm	MTR1-HV Winding oil Temp HI Alarm									

自主 SAT 測試表格

工程師簽章:

DOC name:

Issued Date:

Version:

自主 SAT 測試表格

SIEMENS

Project name:

Typical Type:RTU

Station: SCADA #6 (2F 電驛室)

SAT Date:

	CADA π0 (ZI 电解主)	SAT Date.	RT	U#2							
	Device		SCADA	A/畫面	SCADA	A/畫面	SCADA	4/畫面	SCADA	A/畫面	
no.	Manual 叙述	中文敘述	正確	不正確	正確	不正確	正確	不正確	正確	不正確	備註
031	MTR1-LV Winding oil Temp HI Alarm	MTR1-LV Winding oil Temp HI Alarm									
032	MTR1-Oil Sudden Pressure Relay Action	MTR1-Oil Sudden Pressure Relay Action									
033	MTR1-Fans Motor Control Failure	MTR1-Fans Motor Control Failure									
034	MTR1-AC Supply Failure	MTR1-AC Supply Failure									
035	MTR1-DC Supply Failure	MTR1-DC Supply Failure									
036	MTR2-OLTC Oil Level Low Alarm	MTR2-OLTC Oil Level Low Alarm									
037	MTR2-Buchholz Relay (1st) action	MTR2-Buchholz Relay (1st) action									
038	MTR2-Buchholz Relay (2st) action	MTR2-Buchholz Relay (2st) action									
039	MTR2Transformer Pressure equipment action	MTR2Transformer Pressure equipment action									
040	MTR2-OLTC Oil Temp Low Alarm	MTR2-OLTC Oil Temp Low Alarm									
041	MTR2-HV Winding oil Temp HI Alarm	MTR2-HV Winding oil Temp HI Alarm									
042	MTR2-LV Winding oil Temp HI Alarm	MTR2-LV Winding oil Temp HI Alarm									
043	MTR2-Oil Sudden Pressure Relay Action	MTR2-Oil Sudden Pressure Relay Action									
044	MTR2-Fans Motor Control Failure	MTR2-Fans Motor Control Failure									
045	MTR2-AC Supply Failure	MTR2-AC Supply Failure									
046	MTR2-DC Supply Failure	MTR2-DC Supply Failure									
047	MTR3-OLTC Oil Level Low Alarm	MTR3-OLTC Oil Level Low Alarm									
048	MTR3-Buchholz Relay (1st) action	MTR3-Buchholz Relay (1st) action									
049	MTR3-Buchholz Relay (2st) action	MTR3-Buchholz Relay (2st) action									
050	MTR3Transformer Pressure equipment action	MTR3Transformer Pressure equipment action									
051	MTR3-OLTC Oil Temp Low Alarm	MTR3-OLTC Oil Temp Low Alarm									
052	MTR3-HV Winding oil Temp HI Alarm	MTR3-HV Winding oil Temp HI Alarm									
053	MTR3-LV Winding oil Temp HI Alarm	MTR3-LV Winding oil Temp HI Alarm									
054	MTR3-Oil Sudden Pressure Relay Action	MTR3-Oil Sudden Pressure Relay Action									
055	MTR3-Fans Motor Control Failure	MTR3-Fans Motor Control Failure									
056	MTR3-AC Supply Failure	MTR3-AC Supply Failure									
057	MTR3-DC Supply Failure	MTR3-DC Supply Failure									
058	MTR4-OLTC Oil Level Low Alarm	MTR4-OLTC Oil Level Low Alarm									
059	MTR4-Buchholz Relay (1st) action	MTR4-Buchholz Relay (1st) action									
060	MTR4-Buchholz Relay (2st) action	MTR4-Buchholz Relay (2st) action									

工程師簽章:

DOC name: Issued Date:

SIEMENS

Project name:

Version:

Typical Type:RTU

Station: SCADA #6 (2F 電驛室)

SAT Date:

		SAT Date.		U#2							
	Device		SCADA	A/畫面	SCADA	A/畫面	SCADA	4/畫面	SCADA	A/畫面	
no.	Manual 敘述	中文敘述	正確	不正確	正確	不正確	正確	不正確	正確	不正確	備註
061	MTR4Transformer Pressure equipment action	MTR4Transformer Pressure equipment action									
062	MTR4-OLTC Oil Temp Low Alarm	MTR4-OLTC Oil Temp Low Alarm									
063	MTR4-HV Winding oil Temp HI Alarm	MTR4-HV Winding oil Temp HI Alarm									
064	MTR4-LV Winding oil Temp HI Alarm	MTR4-LV Winding oil Temp HI Alarm									
065	MTR4-Oil Sudden Pressure Relay Action	MTR4-Oil Sudden Pressure Relay Action									
066	MTR4-Fans Motor Control Failure	MTR4-Fans Motor Control Failure									
067	MTR4-AC Supply Failure	MTR4-AC Supply Failure									
068	MTR4-DC Supply Failure	MTR4-DC Supply Failure									
	_ComFault	通訊異常									

DOC name: Issued Date:

Version:

自主 SAT 測試表格



Project name:

Typical Type:RTU

Station: SCADA #6 (2F 電驛室)

SAT Date:

		SAT Date.	RT	U#3							
	Device				SCADA	4/畫面	SCADA	1/畫面	SCADA	A / 畫面	
no.	Manual 敘述	中文敘述	正確			不正確					備註
001	MP1-VCB ON	MP1-VCB ON									
002	MP1-VCB OFF	MP1-VCB OFF									
003	MP1-Keyswitch Local/Remote	MP1-Keyswitch Local/Remote									
004	MP1-Breaker equipment failure	MP1-Breaker equipment failure									
005	LVP-Power supply TPC Side	LVP-Power supply TPC Side									
006	LVP-Power supply MTR Side	LVP-Power supply MTR Side									
007	LVP-Breaker equipment failure	LVP-Breaker equipment failure									
008	Charger1-fault	Charger1-fault									
009	Charger1-AC Votage Low	Charger1-AC Votage Low									
010	Charger1-DC Votage High	Charger1-DC Votage High									
011	Charger1-DC Votage Low	Charger1-DC Votage Low									
012	Charger2-fault	Charger2-fault									
013	Charger2-AC Votage Low	Charger2-AC Votage Low									
014	Charger2-DC Votage High	Charger2-DC Votage High									
015	Charger2-DC Votage Low	Charger2-DC Votage Low									
016	UPS#1 in By-Pass mode	UPS#1 旁路模式									
017	UPS#1 in Battery mode	UPS#1 電池供電									
018	UPS#1 Comm. Alarm	UPS#1 異常警報									
019	UPS#3 in By-Pass mode	UPS#3 旁路模式									
020	UPS#3 in Battery mode	UPS#3 電池供電									
021	UPS#3 Comm Alarm	UPS#3 異常警報									
022	MTR1 Oil Temp (4~20mA)	MTR1 油溫溫度 (4~20mA)									
023	MTR1 HV Winding Temp (4~20mA)	MTR1 HV繞組溫度 (4~20mA)									
024	MTR1 LV Winding Temp (4~20mA)	MTR1 LV繞組溫度 (4~20mA)									
025	MTR2 Oil Temp (4~20mA)	MTR2 油溫溫度 (4~20mA)									
026	MTR2 HV Winding Temp (4~20mA)	MTR2 HV繞組溫度 (4~20mA)									
027	MTR2 LV Winding Temp (4~20mA)	MTR2 LV繞組溫度 (4~20mA)									
028	MTR3 Oil Temp (4~20mA)	MTR3 油溫溫度 (4~20mA)									
029	MTR3 HV Winding Temp (4~20mA)	MTR3 HV繞組溫度 (4~20mA)									
030	MTR3 LV Winding Temp (4~20mA)	MTR3 LV繞組溫度 (4~20mA)									

工程師簽章:

DOC name: Issued Date:

Version:

自主 SAT 測試表格



Project name:

Typical Type:RTU

Station: SCADA #6 (2F 電驛室)

SAT Date:

Station, 5		SAT Date.	RT	U#3							
	Device				SCADA	A / 畫面	SCADA	() 書面	SCADA	/書面	
no.	Manual 叙述	中文敘述				不正確		不正確			備註
031	MTR4 Oil Temp (4~20mA)	MTR4 油溫溫度 (4~20mA)									
032	MTR4 HV Winding Temp (4~20mA)	MTR4 HV繞組溫度 (4~20mA)									
033	MTR4 LV Winding Temp (4~20mA)	MTR4 LV繞組溫度 (4~20mA)									
034	_ComFault	通訊異常									
035											
036											
037											
038											
039											
040											
041											
042											
043											
044											
045											
046											
047											
048											
049		<u> </u>									
050											
051											
052											
053		1									
054 055											
056											
057											
057											
059											
060											
000	<u> </u>		<u> </u>	ļ							

工程師簽章:

DOC name:
Issued Date:

SIEMENS

Project name:

Version:

Typical Type:RTU

Station: SCADA #7 (戶外)

SAT Date:

		2.11 2	RT	U#4							
	Device		SCADA	A/畫面	SCADA	1/畫面	SCADA	4/畫面	SCADA	/畫面	
no.	Manual 敘述	中文敘述	正確	不正確	正確	不正確	正確	不正確	正確	不正確	備註
001	MHP_VCB_ON	MHP_VCB_ON									
002	MHP_VCB_OFF	MHP_VCB_OFF									
003	MHP_Keyswitch_Local_Remote	MHP_Keyswitch_Local_Remote									
004	MHP_Breaker_equipment_failure	MHP_Breaker_equipment_failure									
005	MHP_50_51	MHP_50_51									
006	MHP_50N_51N	MHP_50N_51N									
007	MHP_27	MHP_27									
800	MHP_59	MHP_59									
009	VCB1_VCB_ON	VCB1_VCB_ON									
010	VCB1_VCB_OFF	VCB1_VCB_OFF									
011	VCB1_Keyswitch_Local_Remote	VCB1_Keyswitch_Local_Remote									
012	VCB1_Breaker_equipment_failure	VCB1_Breaker_equipment_failure									
013	VCB1_50_51_	VCB1_50_51_									
014	VCB1_50N_51N	VCB1_50N_51N									
015	VCB1_27	VCB1_27									
016	VCB1_59	VCB1_59									
017	VCB2_VCB_ON	VCB2_VCB_ON									
018	VCB2_VCB_OFF	VCB2_VCB_OFF									
019	VCB2_Keyswitch_Local_Remote	VCB2_Keyswitch_Local_Remote									
020	VCB2_Breaker_equipment_failure	VCB2_Breaker_equipment_failure									
021	VCB2_50_51_	VCB2_50_51_									
022	VCB2_50N_51N	VCB2_50N_51N									
023	VCB2_27	VCB2_27									
024	VCB2_59	VCB2_59									
025	VCB3_VCB_ON	VCB3_VCB_ON									
026	VCB3_VCB_OFF	VCB3_VCB_OFF									
027	VCB3_Keyswitch_Local_Remote	VCB3_Keyswitch_Local_Remote									
028	VCB3_Breaker_equipment_failure	VCB3_Breaker_equipment_failure									
029	VCB3_50_51	VCB3_50_51									
030	VCB3_50N_51N	VCB3_50N_51N									

自主 SAT 測試表格

工程師簽章:

DOC name: Issued Date: 自主 SAT 測試表格

SIEMENS

Version:

Project name:

Typical Type:RTU

Station: SCADA #7 (戶外)

SAT Date:

	$ADA \pi I (J-I)$	SAT Date.	RT	U#4							
	Device			A / 畫面	SCADA	4/畫面	SCADA	4/畫面	SCADA	(/畫面	
no.	Manual 敘述	中文敘述		不正確							備註
031	VCB3_27	VCB3_27									
032	VCB3_59	VCB3_59									
033	TR5_Temp_H	TR5_Temp_H									
034	ACB1_Keyswitch_Local_Remote	ACB1_Keyswitch_Local_Remote									
035	ACB1_VCB_ON	ACB1_VCB_ON									
036	ACB1_VCB_OFF	ACB1_VCB_OFF									
037	ACB1_Breaker_equipment_failure	ACB1_Breaker_equipment_failure									
038	SC_VCB_ON_OFF	SC_VCB_ON_OFF									
039	SC_Keyswitch_Local_Remote	SC_Keyswitch_Local_Remote									
040	SC_Breaker_equipment_failure	SC_Breaker_equipment_failure									
041	c_MHP_VCB_ON	c_MHP_VCB_ON									
042	c_MHP_VCB_OFF	c_MHP_VCB_OFF									
043	c_VCB1_VCB_ON	c_VCB1_VCB_ON									
044	c_VCB1_VCB_OFF	c_VCB1_VCB_OFF									
045	c_VCB2_VCB_ON	c_VCB2_VCB_ON									
046	c_VCB2_VCB_OFF	c_VCB2_VCB_OFF									
047	c_VCB3_VCB_ON	c_VCB3_VCB_ON									
048	c_VCB3_VCB_OFF	c_VCB3_VCB_OFF									
049	c_ACB1_VCB_ON	c_ACB1_VCB_ON									
050	c_ACB1_VCB_OFF	c_ACB1_VCB_OFF									
051	c_SC_VCB_ON	c_SC_VCB_ON									
052	c_SC_VCB_OFF	c_SC_VCB_OFF									
	_ComFault	通訊異常									

工程師簽章:

DOC name: Issued Date:

SIEMENS

Project name:

Version:

Typical Type:PLC

Station: SCADA #4 (1F 配電室)

SAT Date:

button. b	CIDITIT (II 出电主)	SAT Daic.									
				C#1							
	Device		SCADA	A/畫面	SCADA	A/畫面	SCADA	A/畫面	SCADA	1/畫面	
no.	Manual 敘述	中文敘述	正確	不正確	正確	不正確	正確	不正確	正確	不正確	備註
001	FAF-001-Fan System Running/Stop	FAF-001-Fan System Run									
002	FAF-001-Wind pressure Switch	FAF-001-Wind pressure Switch									
003	FAF-001-Fan Auto Control	FAF-001-Fan Auto									
004	FAF-001-Fan Manual Control	FAF-001-Fan Manual									
005	FAF-001-Fan System trip	FAF-001-Fan System trip									
006	FAF-001-Fan System Fire Alarm	FAF-001-Fan System Fire Alarm									
007	FAF-101-Fan System Running/Stop	FAF-101-Fan System Run									
008	FAF-101-Wind pressure Switch	FAF-101-Wind pressure Switch									
009	FAF-101-Fan Auto Control	FAF-101-Fan Auto									
010	FAF-101-Fan Manual Control	FAF-101-Fan Manual									
011	FAF-101-Fan System trip	FAF-101-Fan System trip									
012	FAF-101-Fan System Fire Alarm	FAF-101-Fan System Fire Alarm									
013	MCD-111-Electric Damper Running/Stop	MCD-111-Electric Damper Run									
014	FAF-102-Fan System Running/Stop	FAF-102-Fan System Run									
015	FAF-102-Wind pressure Switch	FAF-102-Wind pressure Switch									
016	FAF-102-Fan Auto Control	FAF-102-Fan Auto									
017	FAF-102-Fan Manual Control	FAF-102-Fan Manual									
018	FAF-102-Fan System trip	FAF-102-Fan System trip									
019	FAF-102-Fan System Fire Alarm	FAF-102-Fan System Fire Alarm									
020	FAF-201-Fan System Running/Stop	FAF-201-Fan System Run									
021	FAF-201-Wind pressure Switch	FAF-201-Wind pressure Switch									
022	FAF-201-Fan Auto Control	FAF-201-Fan Auto									
023	FAF-201-Fan Manual Control	FAF-201-Fan Manual									
024	FAF-201-Fan System trip	FAF-201-Fan System trip									
025	FAF-201-Fan System Fire Alarm	FAF-201-Fan System Fire Alarm									
026	FAF-201-Fan System Running/Stop	FAF-201-Fan System Run									
027	FAF-201-Wind pressure Switch	FAF-201-Wind pressure Switch									
028	FAF-201-Fan Auto Control	FAF-201-Fan Auto									
029	FAF-201-Fan Manual Control	FAF-201-Fan Manual									
030	FAF-201-Fan System trip	FAF-201-Fan System trip									

DOC name: Issued Date:

Version:

自主 SAT 測試表格

SIEMENS

Project name:

Typical Type:PLC

Station: SCADA #4 (1F 配電室)

Julioni St	III ili 电主)	SAT Date.	PI.	C#1							
	Device					A / 書面	SCADA/畫面		SCADA/畫面		
no.	Manual 叙述	中文敘述		不正確		不正確		不正確		不正確	備註
031	FAF-201-Fan System Fire Alarm	FAF-201-Fan System Fire Alarm									
032	MCD-211-Electric Damper Running/Stop	MCD-211-Electric Damper Run									
033	MCD-212-Electric Damper Running/Stop	MCD-212-Electric Damper Run									
034	MCD-2B-Electric Damper Running/Stop	MCD-2B-Electric Damper Run									
035	EAF-001-Fan System Running/Stop	EAF-001-Fan System Run									
036	EAF-001-Wind pressure Switch	EAF-001-Wind pressure Switch									
037	EAF-001-Fan Auto Control	EAF-001-Fan Auto									
038	EAF-001-Fan Manual Control	EAF-001-Fan Manual									
039	EAF-001-Fan System trip	EAF-001-Fan System trip									
040	EAF-001-Fan System Fire Alarm	EAF-001-Fan System Fire Alarm									
041	EAF-101-Fan System Running/Stop	EAF-101-Fan System Run									
042	EAF-101-Wind pressure Switch	EAF-101-Wind pressure Switch									
043	EAF-101-Fan Auto Control	EAF-101-Fan Auto									
044	EAF-101-Fan Manual Control	EAF-101-Fan Manual									
045	EAF-101-Fan System trip	EAF-101-Fan System trip									
046	EAF-101-Fan System Fire Alarm	EAF-101-Fan System Fire Alarm									
047	MCD-11A-Electric Damper Running/Stop	MCD-11A-Electric Damper Run									
048	EAF-102-Fan System Running/Stop	EAF-102-Fan System Run									
049	EAF-102-Wind pressure Switch	EAF-102-Wind pressure Switch									
050	EAF-102-Fan Auto Control	EAF-102-Fan Auto									
051	EAF-102-Fan Manual Control	EAF-102-Fan Manual									
052	EAF-102-Fan System trip	EAF-102-Fan System trip									
053	EAF-102-Fan System Fire Alarm	EAF-102-Fan System Fire Alarm									
054	EAF-103-Fan System Running/Stop	EAF-103-Fan System Run									
055	EAF-103-Wind pressure Switch	EAF-103-Wind pressure Switch									
056	EAF-103-Fan Auto Control	EAF-103-Fan Auto									
057	EAF-103-Fan Manual Control	EAF-103-Fan Manual									
058	EAF-103-Fan System trip	EAF-103-Fan System trip									
059	EAF-103-Fan System Fire Alarm	EAF-103-Fan System Fire Alarm									
060	EAF-104-Fan System Running/Stop	EAF-104-Fan System Run									

DOC name: Issued Date:

Version:

自主 SAT 測試表格

SIEMENS

Project name:

Typical Type:PLC

Station: SCADA #4 (1F 配電室)

bunon. by		SAT Date.									
			PL	C#1							
	Device		SCADA	1/畫面	SCADA	A/畫面	SCADA	1/畫面	SCADA/畫面		
no.	Manual 敘述	中文敘述	正確	不正確	正確	不正確	正確	不正確	正確	不正確	備註
061	EAF-104-Wind pressure Switch	EAF-104-Wind pressure Switch									
062	EAF-104-Fan Auto Control	EAF-104-Fan Auto									
063	EAF-104-Fan Manual Control	EAF-104-Fan Manual									
064	EAF-104-Fan System trip	EAF-104-Fan System trip									
065	EAF-104-Fan System Fire Alarm	EAF-104-Fan System Fire Alarm									
066	EAF-105-Fan System Running/Stop	EAF-105-Fan System Run									
067	EAF-105-Wind pressure Switch	EAF-105-Wind pressure Switch									
068	EAF-105-Fan Auto Control	EAF-105-Fan Auto									
069	EAF-105-Fan Manual Control	EAF-105-Fan Manual									
070	EAF-105-Fan System trip	EAF-105-Fan System trip									
071	EAF-105-Fan System Fire Alarm	EAF-105-Fan System Fire Alarm									
072	EAF-201-Fan System Running/Stop	EAF-201-Fan System Run									
073	EAF-201-Wind pressure Switch	EAF-201-Wind pressure Switch									
074	EAF-201-Fan Auto Control	EAF-201-Fan Auto									
075	EAF-201-Fan Manual Control	EAF-201-Fan Manual									
076	EAF-201-Fan System trip	EAF-201-Fan System trip									
077	EAF-201-Fan System Fire Alarm	EAF-201-Fan System Fire Alarm									
078	MCD-21A-Electric Damper Running/Stop	MCD-21A-Electric Damper Run									
079	MCD-21B-Electric Damper Running/Stop	MCD-21B-Electric Damper Run									
080	WF-102-Fan System Running/Stop	WF-102-Fan System Run									
081	WF-102-Fan Auto Control	WF-102-Fan Auto									
082	WF-102-Fan Manual Control	WF-102-Fan Manual									
083	WF-102-Fan System trip	WF-102-Fan System trip									
084	WF-102-Fan System Fire Alarm	WF-102-Fan System Fire Alarm									
085	MCD-1B-Electric Damper Running/Stop	MCD-1B-Electric Damper Run									
086	WF-102-Fan System Running/Stop	WF-102-Fan System Run									
087	WF-102-Fan Auto Control	WF-102-Fan Auto									
088	WF-102-Fan Manual Control	WF-102-Fan Manual									
089	WF-102-Fan System trip	WF-102-Fan System trip									
090	WF-102-Fan System Fire Alarm	WF-102-Fan System Fire Alarm									

DOC name: Issued Date:

Version:

自主 SAT 測試表格

SIEMENS

Project name:

Typical Type:PLC

Station: SCADA #4 (1F 配電室)

SAT Date:

				C#1							
	Device			4/畫面	SCADA/畫面		SCADA/畫面		面 SCADA/畫面		
no.	Manual 敘述	中文敘述	正確	不正確	正確	不正確	正確	不正確	正確	不正確	備註
091	MCD-1B-Electric Damper Running/Stop	MCD-1B-Electric Damper Run									
092	WF-102-Fan System Running/Stop	WF-102-Fan System Run									
093	WF-102-Fan Auto Control	WF-102-Fan Auto									
094	WF-102-Fan Manual Control	WF-102-Fan Manual									
095	WF-102-Fan System trip	WF-102-Fan System trip									
096	WF-102-Fan System Fire Alarm	WF-102-Fan System Fire Alarm									
097	MCD-1B-Electric Damper Running/Stop	MCD-1B-Electric Damper Run									
098	WF-102-Fan System Running/Stop	WF-102-Fan System Run									
099	WF-102-Fan Auto Control	WF-102-Fan Auto									
100	WF-102-Fan Manual Control	WF-102-Fan Manual									
	WF-102-Fan System trip	WF-102-Fan System trip									
	WF-102-Fan System Fire Alarm	WF-102-Fan System Fire Alarm									
	MCD-1B-Electric Damper Running/Stop	MCD-1B-Electric Damper Run									
104	WF-103-Fan System Running/Stop	WF-103-Fan System Run									
105	WF-103-Fan Auto Control	WF-103-Fan Auto									
106	WF-103-Fan Manual Control	WF-103-Fan Manual									
107	WF-103-Fan System trip	WF-103-Fan System trip									
108	WF-103-Fan System Fire Alarm	WF-103-Fan System Fire Alarm									
109	MCD-1B-Electric Damper Running/Stop	MCD-1B-Electric Damper Run									
110	WF-104-Fan System Running/Stop	WF-104-Fan System Run									
111	WF-104-Fan Auto Control	WF-104-Fan Auto									
112	WF-104-Fan Manual Control	WF-104-Fan Manual									
113	WF-104-Fan System trip	WF-104-Fan System trip									
114	WF-104-Fan System Fire Alarm	WF-104-Fan System Fire Alarm									
115	OU-301-Air Conditioner System Running/Stop	OU-301-Air Auto System Run									
116	OU-301-Air Conditioner Wind pressure Switch	OU-301-Air pressure switch									
	OU-301-Air Conditioner Auto Control	OU-301-Air Auto Auto									
118	OU-301-Air Conditioner Manual Control	OU-301-Air Auto Manual									
	OU-301-Air Conditioner System Trip	OU-301-Air Auto System Trip									
120	OU-301-Air Conditioner System Fire Alarm	OU-301-Air Fire Alarm									

工程師簽章:

DOC name: Issued Date:

Version:

自主 SAT 測試表格

SIEMENS

Project name:

Typical Type:PLC

Station: SCADA #4 (1F 配電室)

Station, Sc	m (if de生)	SAT Date.	PL	C#1							
	Device S			SCADA/畫面		4/畫面	SCADA	4/畫面	SCADA/畫面		
no.	Manual 敘述	中文敘述		不正確		不正確		不正確		不正確	備註
121	OU-302-Air Conditioner System Running/Stop	OU-302-Air Auto System Run									
122	OU-302-Air Conditioner Wind pressure Switch	OU-302-Air pressure switch									
123	OU-302-Air Conditioner Auto Control	OU-302-Air Auto Auto									
124	OU-302-Air Conditioner Manual Control	OU-302-Air Auto Manual									
125	OU-302-Air Conditioner System Trip	OU-302-Air Auto System Trip									
126	OU-302-Air Conditioner System Fire Alarm	OU-302-Air Fire Alarm									
127	OU-303-Air Conditioner System Running/Stop	OU-303-Air Auto System Run									
128	OU-303-Air Conditioner Wind pressure Switch	OU-303-Air pressure switch									
129	OU-303-Air Conditioner Auto Control	OU-303-Air Auto Auto									
130	OU-303-Air Conditioner Manual Control	OU-303-Air Auto Manual									
131	OU-303-Air Conditioner System Trip	OU-303-Air Auto System Trip									
132	OU-303-Air Conditioner System Fire Alarm	OU-303-Air Fire Alarm									
133	LFAP-Fire System Comprehensive Alarm	LFAP-Fire System Comprehensive Alarm									
134	LFAP-Fire System equipment fault	LFAP-Fire System equipment fault									
135	LFAP-Fire System Fire Alarm	LFAP-Fire System Fire Alarm									
136	WP-1,2-System Running/Stop	WP-1,2-System Run									
137	WP-1,2-System Auto Control	WP-1,2-System Auto									
138	WP-1,2-System Manual Control	WP-1,2-System Manual									
139	WP-1,2-System equipment fault	WP-1,2-System equipment fault									
140	WT-01-Water Level H	WT-11-Water Level H									
141	WT-01-Water Level L	WT-11-Water Level L									
142	WT-02-Water Level H	WT-02-Water Level H									
143	WT-02-Water Level L	WT-02-Water Level L									
144	BP-1,2-System Running/Stop	BP-1,2-System Run									
145	BP-1,2-System Auto Control	BP-1,2-System Auto									
146	BP-1,2-System Manual Control	BP-1,2-System Manual									
147	BP-1,2-System equipment fault	BP-1,2-System equipment fault									
148	BP-3-System Running/Stop	BP-3-System Run									
149	BP-3-System Auto Control	BP-3-System Auto									
150	BP-3-System Manual Control	BP-3-System Manual									

DOC name: Issued Date:

Version:

自主 SAT 測試表格

SIEMENS

Project name:

Typical Type:PLC

Station: SCADA #4 (1F 配電室)

ounon. oc	IDIIII (II 电电子)	SAT Date.	DI	C#1							
	Device S				SCAD/	/ 書而	SCADA / 書商		A/畫面 SCADA/畫面		
no	Manual		SCADE	1/ 里川	SCADE	1/ 里田	SCADE	1/ 画田	SCADE	1/ 里田	備註
no.	敘述	中文敘述	正確	不正確	正確	不正確	正確	不正確	正確	不正確	用 正
151	BP-3-System equipment fault	BP-3-System equipment fault									
152	DP-1,2-System Running/Stop	DP-1,2-System Running/Stop									
153	DP-1,2-System Auto Control	DP-1,2-System Auto Control									
154	DP-1,2-System Manual Control	DP-1,2-System Manual Control									
155	DP-1,2-System equipment fault	DP-1,2-System equipment fault									
156	WT-11-Water Level H	WT-11-Water Level H									
157	WT-11-Water Level L	WT-11-Water Level L									
158	WT-11-Water Level LL	WT-11-Water Level LL									
159	DP-3,4-System Running/Stop	DP-3,4-System Running/Stop									
160	DP-3,4-System Auto Control	DP-3,4-System Auto Control									
161	DP-3,4-System Manual Control	DP-3,4-System Manual Control									
162	DP-3,4-System equipment fault	DP-3,4-System equipment fault									
163	WT-12-Water Level H	WT-12-Water Level H									
164	WT-12-Water Level L	WT-12-Water Level L									
165	WT-12-Water Level LL	WT-12-Water Level LL									
166	UPS#2 in By-Pass mode	UPS#2 旁路模式									
167	UPS#2 in Battery mode	UPS#2 電池供電									
168	UPS#2 Comm Alarm	UPS#2 異常警報									
169	c_FAF-001-Fan System Running/Stop	c_FAF-001-Fan System Run									
170	c_FAF-101-Fan System Running/Stop	c_FAF-101-Fan System Run									
171	c_MCD-111-Electric Damper Running/Stop	c_MCD-111-Electric Damper Run									
172	c_FAF-102-Fan System Running/Stop	c_FAF-102-Fan System Run									
173	c_FAF-201-Fan System Running/Stop	c_FAF-201-Fan System Run									
174	c_FAF-201-Fan System Running/Stop	c_FAF-201-Fan System Run									
175	c_MCD-211-Electric Damper Running/Stop	c_MCD-211-Electric Damper Run									
176	c_MCD-212-Electric Damper Running/Stop	c_MCD-212-Electric Damper Run									
177	c_MCD-2B-Electric Damper Running/Stop	c_MCD-2B-Electric Damper Run									
178	c_EAF-001-Fan System Running/Stop	c_EAF-001-Fan System Run									
179	c_EAF-101-Fan System Running/Stop	c_EAF-101-Fan System Run									
180	c_MCD-11A-Electric Damper Running/Stop	c_MCD-11A-Electric Damper Run									

DOC name: Issued Date:

Version:

自主 SAT 測試表格

SIEMENS

Project name:

Typical Type:PLC

Station: SCADA #4 (1F 配電室)

			PL	C#1							
	Device S			A/畫面	SCADA	A/畫面	SCADA/畫面		DA/畫面 SCADA/畫面		
no.	Manual 叙述	中文敘述	正確	不正確	正確	不正確	正確	不正確	正確	不正確	備註
181	c_EAF-102-Fan System Running/Stop	c_EAF-102-Fan System Run									
182	c_EAF-103-Fan System Running/Stop	c_EAF-103-Fan System Run									
183	c_EAF-104-Fan System Running/Stop	c_EAF-104-Fan System Run									
184	c_EAF-105-Fan System Running/Stop	c_EAF-105-Fan System Run									
185	c_EAF-201-Fan System Running/Stop	c_EAF-201-Fan System Run									
186	c_MCD-21A-Electric Damper Running/Stop	c_MCD-21A-Electric Damper Run									
187	c_MCD-21B-Electric Damper Running/Stop	c_MCD-21B-Electric Damper Run									
188	c_WF-102-Fan System Running/Stop	c_WF-102-Fan System Run									
189	c_MCD-1B-Electric Damper Running/Stop	c_MCD-1B-Electric Damper Run									
190	c_WF-102-Fan System Running/Stop	c_WF-102-Fan System Run									
191	c_MCD-1B-Electric Damper Running/Stop	c_MCD-1B-Electric Damper Run									
192	c_WF-102-Fan System Running/Stop	c_WF-102-Fan System Run									
193	c_MCD-1B-Electric Damper Running/Stop	c_MCD-1B-Electric Damper Run									
194	c_WF-102-Fan System Running/Stop	c_WF-102-Fan System Run									
195	c_MCD-1B-Electric Damper Running/Stop	c_MCD-1B-Electric Damper Run									
196	c_WF-103-Fan System Running/Stop	c_WF-103-Fan System Run									
197	c_MCD-1B-Electric Damper Running/Stop	c_MCD-1B-Electric Damper Run									
198	c_WF-104-Fan System Running/Stop	c_WF-104-Fan System Run									
199	c_OU-301-Air Conditioner System Running/Stop	c_OU-301-Air Conditioner System Run									
200	c_OU-302-Air Conditioner System Running/Stop	c_OU-302-Air Conditioner System Run									
201	c_OU-303-Air Conditioner System Running/Stop	c_OU-303-Air Conditioner System Run									
202	c_WP-1,2-System Running/Stop	c_WP-1,2-System Run									
203	c_BP-1,2-System Running/Stop	c_BP-1,2-System Run									
204	c_BP-3-System Running/Stop	c_BP-3-System Run									
205	c_DP-1,2-System Running/Stop	c_DP-1,2-System Run									
206	c_DP-3,4-System Running/Stop	c_DP-3,4-System Run									
207	TSM-Temp【變壓器室(一)】	TSM-Temp【變壓器室(一)】									
208	TSM-Temp【變壓器室(二)】	TSM-Temp【變壓器室(二)】									
209	TSM-Temp【變壓器室(三)】	TSM-Temp【變壓器室(三)】									
210	TSM-Temp【變壓器室(四)】	TSM-Temp【變壓器室(四)】									

Version:

DOC name: Issued Date:

SIEMENS

Project name:

Typical Type:PLC

Station: SCADA #4 (1F 配電室)

SAT Date:

		5.11 2 me.	PL	C#1							
	Device		SCADA	A/畫面	SCADA	A/畫面	SCADA/畫面		SCADA/畫面		
no.	Manual 敘述	中文敘述	正確	不正確	正確	不正確	正確	不正確	正確	不正確	備註
211	TSM-Temp【氣體絕緣開關室】	TSM-Temp【氣體絕緣開關室】									
212	TSM-Temp【氣體絕緣開關室】	TSM-Temp【氣體絕緣開關室】									
213	TSM-Temp【1F發電機室】	TSM-Temp【1F發電機室】									
214	Counter	通訊異常									
215											
216											
217											
218											
219											
220											
221											
222											
223											
224											
225											
226											
227											
228											
229											
230											
231											
232											
233											
234											
235		1	-								
236		1	-								
237		1									
238		1									
239											
240											