Project name:IDB-E2

DOC name: Issued Date:

SIEMENS

Project name:

Version:

Typical Type: GEC7-404-0150

Station: 161kV Room SAT Date:

					rger1	Charger2						
	Device			SCADA	A/畫面	SCADA/畫面		SCADA/畫面		SCADA/畫面		
no.	Manual 敘述	中文敘述	/	正確	不正確	正確	不正確	正確	不正確	正確	不正確	備註
001	Charger AC Input failure	充電機交流輸入-已故障										
002	Charger AC Input power cut	充電機交流輸入-停電										
003	Charger over temperature	充電機溫度過高										
004	Output condition - voltage too high	充電機輸出狀態-電壓過高										
005	Output condition - voltage too low	充電機輸出狀態-電壓過低										
006	Output condition - Floating charge	充電機輸出狀態-浮動充電										
007	Output condition - Equalizer charge	充電機輸出狀態-均等充電										
800	Output condition - Fast charge	充電機輸出狀態-快速充電										
009	Output condition - Manual test	充電機輸出狀態-手動測試										
010	Battery liquid level too low	電池液位過低										
011	Output ripple too high	輸出漣波過高										
012	Charger failure	充電機故障										
013	Fan failure	散熱風扇故障										
014	_Error	通訊異常										

自主 SAT 測試表格

工程師簽章:

業主簽章: