

MANGALORE REFINERY AND PETROCHEMICALS LIMITED

Crude Distillation Unit - 2 (CDU-2)

SHIFT HANDOVER LOG - FORM OPS/CDU2/F-07 Rev 2

CONFIDENTIAL - INTERNAL USE ONLY

SHL-2026-08-27

Page 1 of 1

DATE
2026-08-27SHIFT
Night (22:00 - 06:00)OUTGOING SHIFT IN-CHARGE
R. KulkarniINCOMING SHIFT IN-CHARGE
D. Prabhu**SECTION A - CHRONOLOGICAL LOG OF EVENTS**

TIME	OBSERVATION / ACTION TAKEN
22:15	Unit stable at 96% rate. C-2101 top temp 118 degC, flash zone 352 degC.
23:40	P-2104B - oil mist / weeping seen at seal area. Wiped and cleaned. Plan 52 pot level LOW, approx 20%. Topped up manually with 2 litre.
00:30	P-2104B vibration checked with handheld: 9.4 mm/s DE horizontal. Above alert. Informed panel and rotating equipment engineer on phone.
01:10	Advised by rotating eqpt engineer to continue monitoring and keep P-2104A ready for hot standby changeover. No work order raised in this shift.
02:45	F-2101 pass 3 skin temp 618 degC, within limit. Soot blow done.
04:20	P-2104B seal area re-checked. Slight weeping continues. Bearing temp 91 degC.
05:50	Handover to day shift. FLAGGED: P-2104B seal condition and high vibration. Recommend early changeover to P-2104A.

SECTION B - STANDBY EQUIPMENT STATUS

P-2104A confirmed on auto-start, suction and discharge lined up, warm-up line cracked open. Ready for changeover.

SECTION C - SIGN OFF
R. Kulkarni
Outgoing (sign)
D. Prabhu
Incoming (sign)