ELECTRICAL EQUIPMENT HEALTH AUDIT REPORT

December, 2023

Abstract

This report summarizes a facility-wide audit aimed at assessing the operational health and longevity of critical electrical equipment; through detailed inspections, diagnostic evaluations, and thermal imaging, several high-risk issues—such as insulation deterioration, contactor overheating, and corrosion—were identified, prompting risk-based maintenance recommendations to ensure sustained reliability and safety.

Yash Parmar

Prepared by: Electrical Maintenance Team

Date: 18.12.2023

INDEX

1. Summary

The Electrical Equipment Health Audit was conducted to comprehensively evaluate the condition, performance, and remaining service life of key electrical assets across the facility. This initiative focused on enhancing system reliability, safety, and efficiency through early detection of potential failure points and degradation trends.

The audit covered three main components: **switchgear systems**, **power transformers**, and **motor control center (MCC) panels**. A structured methodology was employed, including visual inspections, mechanical assessments, diagnostic testing, and thermal imaging. Specific tests included insulation resistance testing, oil quality analysis, partial discharge detection, and infrared thermography.

Key findings included:

- Four transformers with insulation resistance values approaching end-of-life thresholds.
- Two MCC panels with signs of thermal stress due to overheating contactors.
- One switchgear unit with early-stage corrosion on busbars. These issues were documented with photographic evidence and categorized by risk levels—critical, moderate, and low—based on their impact and urgency.

A **risk-rated summary** table was compiled, enabling targeted maintenance and capital planning. The audit recommended immediate repairs for high-risk equipment, short-term monitoring and upgrades for moderate issues, and long-term asset replacement strategies. Specific actions include component replacements, re-insulation, lubrication of mechanical parts, and enhancements to predictive maintenance systems.

In conclusion, the audit emphasizes the importance of regular condition-based assessments to prevent unplanned outages, ensure electrical safety, and optimize asset lifecycle management. The findings serve as a roadmap for prioritizing maintenance and capital investments in the facility's electrical infrastructure.

2. Objectives

The primary objective of this Electrical Equipment Health Audit is to perform a thorough evaluation of the operational status, safety, and longevity of critical electrical infrastructure across the facility. This includes switchgear assemblies, power transformers, and motor control center (MCC) panels.

The audit seeks to achieve the following goals:

1. **Assess Equipment Health:**
   Determine the current physical and functional condition of electrical components, identifying signs of wear, degradation, or emerging faults.

2. **Identify and Quantify Risks:**
   Detect potential failure points such as insulation breakdown, thermal stress, mechanical fatigue, and corrosion, and classify them by severity to prioritize maintenance needs.

3. **Estimate Remaining Service Life:**
   Analyze condition data and test results to forecast the expected remaining lifespan of equipment, aiding in planning for refurbishment or replacement.

4. **Enhance System Reliability and Safety:**
   Support the development of proactive maintenance strategies that reduce downtime, prevent safety incidents, and extend equipment life.

5. **Support Strategic Planning:**
   Provide data-driven insights for capital investment decisions, maintenance scheduling, and lifecycle asset management.

6. **Document and Track Equipment Condition:**
   Establish a baseline for future comparisons and continuous monitoring by recording findings with photographic evidence and technical documentation.

By fulfilling these objectives, the audit aims to contribute significantly to operational excellence, compliance with safety standards, and cost-effective infrastructure management.

3. Scope of Audit

This Electrical Equipment Health Audit encompasses a structured evaluation of the facility's key electrical infrastructure to ensure operational reliability, safety, and long-term performance. The audit covers the following dimensions:

1. Equipment Categories Assessed

- **Switchgear Systems:**
  Including low-, medium-, and high-voltage switchgear used for power distribution and control. Inspection focuses on mechanical integrity, corrosion, insulation, and operational safety.

- **Power Transformers:**
  Evaluation of both oil-filled and dry-type transformers. Tests include insulation resistance, oil quality (where applicable), temperature profiling, and partial discharge detection.

- **Motor Control Centers (MCCs):**
  Covering MCC panels that house contactors, relays, and protective devices. Emphasis is placed on connection integrity, component functionality, and thermal condition.

2. Facilities and Locations

- All main substations, distribution rooms, and motor control stations throughout the site.
- Both indoor and outdoor electrical installations are included.

3. Testing and Diagnostic Methods

- **Visual Inspections** for physical wear, damage, and corrosion.
- **Electrical Testing** such as insulation resistance, continuity checks, and IR thermography.
- **Advanced Diagnostics** including partial discharge analysis and dissolved gas analysis (for transformers).
- **Thermal Imaging** detects hot spots and thermal imbalances.

4. Frequency and Timeline

- **Annual and Bi-Annual Audits:**
  Routine audits are conducted every 6 to 12 months depending on equipment criticality and past performance trends.

5. Documentation and Reporting

1. All findings are recorded with **photographic evidence**, annotated observations, and **risk classifications** (critical, moderate, low).
2. A final report is generated outlining identified issues, prioritized maintenance actions, and lifecycle recommendations.

4. Methodology

The audit was carried out using a structured and systematic approach to ensure a thorough and consistent evaluation of all major electrical equipment. The methodology combines visual inspection, diagnostic testing, thermal analysis, and performance evaluation to accurately assess the condition and operational reliability of electrical assets. The audit methodology is divided into the following key components:

1. Preliminary Planning and Audit Preparation

- **Data Collection:** Existing equipment documentation, maintenance records, single-line diagrams, and historical failure logs were reviewed.
- **Site Walkdowns:** Initial walk-throughs were performed to identify critical assets, plan testing sequences, and schedule access based on operational priorities.
- **Safety Planning:** Hazard identification and risk assessments were completed. All activities followed applicable electrical safety procedures and lockout/tagout protocols.

2. Switchgear Inspection

- **Visual Inspection:** Evaluation for physical damage, corrosion, water ingress, and general cleanliness of panels and enclosures.
- **Mechanical Assessment:** Checks on operating mechanisms, interlocks, hinges, and latching systems to assess wear and functionality.
- **Insulation Condition:** Inspection of insulation barriers, bushings, and support structures for signs of tracking, discoloration, or cracking.
- **Contact Surface Check:** Examination of busbars, terminals, and circuit breaker contacts for pitting, corrosion, or excessive wear.

3. Transformer Testing

- **Insulation Resistance Testing (IR):** Measurement of insulation health using a megohmmeter to detect deterioration in winding insulation.
- **Oil Quality Analysis:** Sampling of transformer oil (for oil-immersed units) to analyze dielectric strength, moisture content, and presence of dissolved gases (DGA).
- **Thermal Scanning:** Infrared thermography to identify hot spots, uneven temperature distributions, and potential internal faults.
- **Partial Discharge (PD) Monitoring:** Advanced detection of internal discharges that indicate localized breakdowns in insulation.

4. MCC Panel Review

- **Connection Integrity:** Verification of all cable and terminal tightness using torque testing or thermographic scans.
- **Contactor and Relay Assessment:** Functional testing and physical inspection for signs of arcing, sticking, or worn-out contacts.
- **Thermal Imaging:** Detection of hotspots due to loose connections, unbalanced loads, or failing components.

- **General Panel Condition:** Review of cleanliness, cable route, ventilation, labeling, and internal panel layout.

5. Diagnostic Tools and Technologies Used

- Digital multimeters and insulation resistance testers
- Infrared thermal imaging cameras
- Oil sampling kits and DGA analysis tools
- Partial discharge detection equipment
- Visual inspection cameras and borescopes (where required)

6. Documentation and Risk Evaluation

- **Risk-Based Classification:** Each piece of equipment was assigned a condition rating (Critical, Moderate, or Low Risk) based on severity and urgency.
- **Data Logging:** All measurements and visual observations were logged and compared to baseline values or manufacturer standards.

7. Reporting and Recommendations

- A final report was generated that includes:
  - Summary of findings for each equipment category
  - Tabulated condition ratings
  - Detailed observations and measurement results
  - Specific, actionable maintenance and replacement recommendations
  - Timeline guidance for corrective actions (Immediate, Short-Term, Long-Term)

This methodology ensures a comprehensive and repeatable process for evaluating electrical equipment health, enabling the facility to take informed decisions regarding maintenance prioritization and asset lifecycle planning.

5. KEY FINDINGS

The audit identified several critical and moderate-risk issues across the facility's electrical infrastructure. These findings highlight the importance of timely maintenance and risk mitigation to avoid operational downtime, equipment failure, or safety hazards. Below is a summary of key observations categorized by equipment type:

1. Transformers

- **Insulation Degradation:**
  Four transformers exhibited insulation resistance values approaching or below the acceptable threshold, indicating advanced insulation aging. This could compromise dielectric strength and increase failure probability during voltage surges or operational stress.



- **Oil Contamination:**
  Oil analysis of two transformers revealed elevated moisture content and dissolved gas levels, suggestive of internal overheating or early-stage arcing. This condition poses a risk of insulation breakdown and transformer failure if not addressed.

- **Temperature Irregularities:**
  Thermal scanning showed uneven heat distribution in one unit, possibly due to winding imbalance or poor cooling system performance.

2. MCC (Motor Control Center) Panels



- **Overheating Components:**
  Two MCC panels exhibited significant hotspots in thermal imaging, traced to contactors showing signs of arcing and thermal fatigue. Continued operation under these conditions increases the risk of fire or power disruption.

- **Loose Connections and Aged Insulation:**
  Several panels had loose terminals and deteriorating cable insulation, particularly in older installations. These issues can cause voltage drops, contact resistance heating, or short circuits.

- **Dust and Ventilation Issues:**
  A few panels had compromised ventilation due to clogged filters and dust accumulation, impacting heat dissipation and contributing to higher operating temperatures.

3. Switchgear Assemblies

- **Corroded Busbars:**
  One switchgear unit was found with visible corrosion on busbar surfaces. While caught early, this condition could escalate into contact resistance issues or arcing faults if not cleaned and re-coated promptly.

- **Mechanical Wear:**
  Mild wear was observed on breaker operating mechanisms in multiple units, likely due to age and repeated cycling. While not immediately critical, this requires attention to avoid future operational failures.

- **Protective Relays and Indicators:**
  Some protective relays showed inconsistent response times during functional checks, suggesting possible calibration drift or age-related performance degradation.

4. Risk Classification Summary
Each piece of equipment was categorized based on severity of findings:

EQUIPMENT TYPE	INSPECTED UNITS	CRITICAL ISSUES	MODERATE ISSUES	LOW-RISK/NORMAL
TRANSFORMERS	13	4	4	5
MCC PANELS	22	2	5	15
SWITCHGEAR UNITS	10	1	2	7

These findings provide a clear picture of the facility's electrical equipment health and emphasize the importance of immediate attention to critical items, especially those affecting transformers and MCC safety.

Let me know if you want this added to the Word file or want supporting photos and data tables formatted as appendices.

6. Recommendations

Based on the audit findings, the following recommendations are provided to address identified issues, reduce operational risks, and enhance the overall reliability of the facility's electrical infrastructure. Recommendations are grouped by priority and equipment type for clear implementation planning.

1. Immediate Actions (0–1 Month)
Transformers:

- Replace or refurbish transformers showing critically low insulation resistance.
- Perform oil filtration or complete oil replacement for units with contaminated insulation oil and elevated gas levels.
- Inspect cooling systems for irregular heat profiles and perform corrective cleaning or repairs.

MCC Panels:

- Replace overheating contactors to prevent fire hazards or equipment failure.
- Tighten all loose terminals and connections identified in thermal scans.
- Clean panels and restore proper airflow by replacing clogged filters and verifying ventilation paths.

Switchgear:

- Remove corrosion from busbars using chemical treatment or mechanical cleaning; apply anti-corrosive coating.
- Lubricate and service mechanical parts to restore reliable operation.

2. Short-Term Recommendations (1–3 Months)

- Conduct follow-up IR and thermographic testing to monitor moderately affected components.
- Perform preventive maintenance on MCCs showing signs of insulation aging and component fatigue.
- Recalibrate or replace protective relays with inconsistent response times.
- Implement arc flash mitigation solutions where thermal stress or electrical faults have been identified.

3. Long-Term Recommendations (3–12 Months)

- Develop a phased transformer replacement plan based on remaining insulation life and operational criticality.
- Upgrade aged MCC panels with modern, better-rated equipment to improve energy efficiency and safety.
- Integrate online condition monitoring tools for transformers and switchgear, such as:
- Partial discharge sensors
- Continuous thermal monitoring
- Oil quality analyzers
- Schedule the next audit cycle to assess equipment performance and confirm remediation effectiveness.

4. Strategic Recommendations

- Establish a **predictive maintenance program** leveraging data from this audit to proactively manage asset health.
- Digitize all audit records and equipment condition reports for future reference and trend analysis.
- Train facility staff on early symptom detection, thermal imaging interpretation, and basic corrective actions.

By addressing the above recommendations, the facility can reduce the risk of unplanned downtime, extend equipment lifespan, ensure personnel safety, and enhance the overall efficiency and reliability of its electrical infrastructure.

7. Conclusion

The Electrical Equipment Health Audit has provided a thorough and data-driven assessment of the operational condition, safety, and remaining lifespan of the facility's key electrical assets. By systematically evaluating switchgear assemblies, power transformers, and MCC panels through a combination of visual inspections, diagnostic testing, and thermal imaging, the audit has successfully identified both critical and developing issues that could compromise the reliability and safety of the electrical infrastructure if left unaddressed.

Key issues such as **aging insulation in transformers**, **overheating contactors in MCC panels**, and **early-stage corrosion in switchgear components** were detected and documented. The classification of each issue by risk level allows for targeted intervention, helping maintenance teams prioritize corrective actions based on severity and urgency.

This audit highlights the **importance of proactive maintenance practices**. Equipment exhibiting critical signs of wear or failure risk must be addressed immediately to prevent unplanned outages, safety incidents, or costly breakdowns. Equally, assets showing moderate degradation should be closely monitored and included in a strategic maintenance or upgrade plan.

The recommendations offered in this report provide a clear and actionable roadmap for remediation. These include short-term corrective actions, long-term asset replacement strategies, and the integration of condition monitoring technologies to support predictive maintenance.

Moreover, the audit reinforces the need for a **structured, recurring audit schedule** (annual or bi-annual), which ensures continuous monitoring, early detection of issues, and data-informed asset management. This approach will not only extend the life of critical equipment but will also improve the overall resilience, efficiency, and safety of the facility's electrical systems.

In conclusion, the audit has fulfilled its objective of providing a transparent, comprehensive, and practical evaluation of the electrical infrastructure. By implementing the findings and recommendations of this report, the facility can make informed decisions to optimize reliability, enhance safety, reduce downtime, and support long-term operational excellence.

Prepared By**:**
Yash Parmar, Electrical Engineer
[yashparmar151201@gmail.com]