



Rooter-Man
P.O. Box 30098
Charleston, SC 29417
843-766-3311

Invoice 26226506
Invoice Date 4/5/2022
Terms Net 30
Completed Date 4/5/2022
Customer PO

Billing Address

New Heights Property Management
237 Old Summerville Road #Suite F
Summerville, SC 29483 USA

Job Address

Tenant
628 Constant Drive
Charleston, SC 29412 USA

Description of Work

Anna approved to pull toilet to clear mainline \$325.00

Cleared back bathroom having issue. Line is cast iron with slight belly. Tampons were stuck in line. Pulled back 5 tampons and when clog released it carried the rest.

No warranty due to pitted, bellied cast iron.

Recommnd, No Frminine Products, No wipes, No thick toilet paper.

Task #	Description	Quantity	Your Price	Your Total
Drc016	3"-6" pipe size. Using up to 100 ft of cable. Create access to open stoppage through toilet flange or exterior patch up to 24 inches deep in rock free soil. Camera inspection is included. Sewer patches are not preferred access points. Sewer clean outs must be installed at an additional charge.	1.00	\$325.00	\$325.00
				Sub-Total \$325.00
				Tax \$0.00
				Total Due \$325.00
				Balance Due \$325.00

If you have any questions about the work that was performed, want to compliment an employee, or suggest a way we can improve our service, please call 843-766-3311. We appreciate your business and feedback.

I authorize Rooter-Man to perform the described services and I agree to pay the amount of \$325.00 indicated. I understand the Rooter-Man is not responsible for broken, settled, rusted, or lead pipes, fixtures, or clean outs and any damage resulting from cleaning or such line.

I agree that the price quoted prior to start of work does not include and additional or unforeseen tasks nor materials which may be found to be necessary to complete repairs or replacements.

4/5/2022

I acknowledge completion of the above described work which has been done to my satisfaction.

4/5/2022