



**D.V. Electromatic (P) Ltd.**



AN ISO 9001:2008 CERTIFIED CO.

REF NO: **DVEPL/20-21/6570/0**

Date – 13-July-2024

TO,

Kind Attn.:

Mobile No.:

Email ID:

Sub: **QUOTATION FOR GE\_JULL\_ET-30\_2024-25**

Dear Sir,

We acknowledge with thanks the receipt of your valued enquiry regarding above mentioned subject. We are pleased to furnish our most competitive offer for your favorable consideration as under.

**ANNEXURE - I: FABRICATION DETAILS & TECHNICAL SPECIFICATIONS**

**ANNEXURE - II: BILL OF MATERIAL**

**ANNEXURE- III: PRICE SCHEDULE**

**ANNEXURE- IV: TERMS AND CONDITIONS**

We hope the detailed BOQ & Tech Specs here under is as per your requirement.

Should you need any further clarification(s) please feel free to contact us. We look forward for an opportunity to serve you.

Thanking you,

Yours faithfully,

For **D.V. ELECTROMATIC PVT. LTD.**

Authorized Signatory

**MANUFACTURERS OF LT CONTROL PANELS**

**Regd. - Administrative Office :**  
Prabhu Niwas Building, Near Ranbir (Kalu) Petrol Pump,  
Dalhousie Road, Pathankot - 145001.  
Tel-Fax : +91 186 2231231

**Factory :**  
F03, F04, F21, Industrial Growth  
Centre, Pathankot - 145001  
Tel.: +91 92572 17609

**Sales Office**  
202 2nd Floor, Golden Square Building,  
Chandigarh, Amabala Highway Zirakpur.

M : +91 94170 21685, +91 94176 01244  
E : dvepl@yahoo.in, office@dvepl.com  
W : www.dvepl.com



**ANNEXURE – I**

**TECHNICAL SPECIFICATIONS**

- 1. Material of Sheet:** CRCA sheet
- 2. Sheet thickness:** AS PER TENDER thickness for All Panels.
- 3. Material treatment:** Thorough chemical treatment with 7 tank process method for degreasing, derusting and phosphating powder coating shall not be less than 40 microns.
- SIEMENS GREY (RAL-7032) shade powder coating paint will be applied.
- 4. Bus bar:** The bus bars will be insulated with PVC heat shrinkable sleeves and supported SMC/DMC at Suitable intervals so as to withstand dynamic stresses developed in the event of short circuit of 50ka (RMS) and will withstand following standard tests:-
- (a) Continuity tests  
(b) No load operation test  
(c) H.T Test (2kV) for one minute.  
(d) Insulation resistance test.
- 6. Fault Level:** 35 KA
- 7. Bus Bar Size:** As per BOQ
- 8. Current Density:** 0.8A/Sq. mm. Current Density.
- 9. Bus bar insulation** Heat Shrinkable Sleeves

**MANUFACTURERS OF LT CONTROL PANELS**

**ANNEXURE – II****BILL OF MATERIALS**

1	SR NO 23		BOARD QTY		
A	INCOMER MCCB 630A		1	FEEDER QTY	1
SR. NO.	BOQDESCRIPTION	MAKE	CATALOG NUMBER	QTY	TOTAL QTY
1	630A 4P 36kA MCCB (with Spreaders), TM Release (Adj Thermal & Adj Magnetic), Type : TAB3	HPL	TAB630NX630AC4P	1	1
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 630A TAB3 MCCB	HPL	TAB3630ST4P	1	1
B	METERING	MAKE	1	FEEDER QTY	1
1	Multifunction Meter (LCD display), 3Ph, Parameters: V, A, F, PF, kW, kVA, Old energy, On hours, site selectable kWh/ kVAh, CL: 1, Aux Sup: 90-300V AC/DC, Size: 96X96	L&T	WC4400100000	1	1
2	Red Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLR240A	1	1
3	Yellow Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLY240A	1	1
4	Blue Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLB240A	1	1
5	32A Neutral Link, Color: Black/Khaki	FTC	FNL 32	1	1
6	680/5A 15VA Acc. Cl: 1, ABS Insulated Bar Primary Rectangular Current Transformer, ID: 68x10mm	NIPPEN	NE 681	3	3
7	6 Sq.mm Disconnecting Terminal (Std. Color),Type: KUTSD 6	ELMEX	KUTSD 6	3	3
8	6A 1P 10kA C-Curve Techno MCB	HPL	NTSPC06	3	3
C	OUTGOING MCCB 400A	MAKE	1	FEEDER QTY	1
1	400A 4P 36kA MCCB (with Spreaders), TM Release (Adj Thermal & Adj Magnetic), Type : TAB3	HPL	TAB630NX400AC4P	1	1
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 400A TAB3 MCCB	HPL	TAB3400ST4P	1	1
D	OUTGOING MCCB 200A	MAKE	1	FEEDER QTY	1
1	200A 4P 25kA MCCB (with Spreaders), TA Release (Adj Thermal & Fixed Magnetic), Type : TAB2	HPL	TAB250CX200AC4P	1	1
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 168-200A TAB2 MCCB	HPL	TAB2200ST4P	1	1
E	OUTGOING MCCB 100A	MAKE	1	FEEDER QTY	2
1	100A 4P 16kA MCCB (with Spreaders), TA Release (Adj Thermal & Fixed Magnetic), Type : TAB1	HPL	TAB168DX100AC4P	1	2
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 20-100A TAB1 MCCB	HPL		1	2
F	OUTGOING MCCB 63A	MAKE	1	FEEDER QTY	1
1	63A 4P 16kA MCCB, TA Release (Adj Thermal & Fixed Magnetic), Type : TAB1	HPL	TAB168DX063AC4P	1	1
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 20-100A TAB1 MCCB	HPL	TAB1100ST4P	1	1
G	OUTGOING MCB 40A	MAKE	1	FEEDER QTY	2
1	40A 3PN 10kA C-Curve Techno MCB	HPL	NTTPNC40	1	2
S.N.	FABRICATION DETAILS	MAKE	TYPE/MATERIAL	QTY	UNIT
1	FABRICATION : 3.15MM CRCA Sheet PRE TREATMENT: 7 TANK PROCESS PAINTING: POWDER COATED WITH SIEMENS GREY SHED (RAL 7032) TYPE: INDOOR TYPE, FREE FLOOR RESTING, FIX TYPE, SINGLE FRONT, COMPARTMENTLISED DESIGN, SINGLE DOOR CABLE ENTRY: TOP/BOTTOM (DETACHABLE GLAND PLATE UNDRILLED)	DVEPL	MS/CRCA	1	JOB
2	BASE FRAME: 40X40X5MM & 800MM	DVEPL	ISMC	1	JOB

**MANUFACTURERS OF LT CONTROL PANELS**

**Regd. - Administrative Office :**  
Prabhu Niwas Building, Near Ranbir (Kalu) Petrol Pump,  
Dalhousie Road, Pathankot - 145001.  
Tel-Fax : +91 186 2231231

**Factory :**  
F03, F04, F21, Industrial Growth  
Centre, Pathankot - 145001  
Tel.: +91 92572 17609

**Sales Office**  
202 2nd Floor, Golden Square Building,  
Chandigarh, Amabala Highway Zirakpur.

M : +91 94170 21685, +91 94176 01244  
E : dvepl@yahoo.in, office@dvepl.com  
W : www.dvepl.com



3	<b>BUSBAR: PH: 1x50x10, N: 1X50X10</b> Current Density: 1 Amp/Sq. mm Insulation: Color coded heat shrinkable Sleeves	DVEPL	Copper	1	JOB
4	<b>WIRING HARNESS (METERING STARTERS)</b>	DVEPL	CU- WIRE	1	LOT
5	<b>HARDWARE &amp; ACCESSORIES (LOCKS, GASKET, NUT BOLT ETC)</b>	DVEPL	NUT, BOLTS, LUGS ETC.	1	LOT
6	<b>LABOUR</b>	DVEPL		1	JOB
2	<b>SR NO 24</b>		<b>BOARD QTY</b>		
A	<b>INCOMER MCCB 200A</b>		1	FEEDER QTY	1
SR. NO.	BOQDESCRIPTION	MAKE	CATALOG NUMBER	QTY	TOTAL QTY
1	200A 4P 25kA MCCB (with Spreaders), TA Release (Adj Thermal & Fixed Magnetic), Type : TAB2	HPL	TAB250CX200AC4P	1	1
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 168-200A TAB2 MCCB	HPL	TAB2200ST4P	1	1
B	<b>METERING</b>	MAKE	1	FEEDER QTY	1
1	Multifunction Meter (LCD display), 3Ph, Parameters: V, A, F, PF, kW, kVA, Old energy, On hours, site selectable kWh/ kVAh, CL: 1, Aux Sup: 90-300V AC/DC, Size: 96X96	OUTGOING MCCB 100A	WC4400100000	1	1
2	Red Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLR240A	1	1
3	Yellow Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLY240A	1	1
4	Blue Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLB240A	1	1
5	32A Neutral Link, Color: Black/Khaki	FTC	FNL 32	1	1
6	200/5A 5VA Acc. Cl: 1, ABS Insulated Bar Primary Ring Type Current Transformer, ID: 34mm	NIPPEN	NA	3	3
7	6 Sq.mm Disconnecting Terminal (Std. Color),Type: KUTSD 6	ELMEX	KUTSD 6	3	3
8	6A 1P 10kA C-Curve Techno MCB	HPL	NTSPC06	3	3
C	<b>OUTGOING MCCB 100A</b>	MAKE	1	FEEDER QTY	1
1	100A 4P 16kA MCCB (with Spreaders), TA Release (Adj Thermal & Fixed Magnetic), Type : TAB1	HPL	TAB168DX100AC4P	1	1
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 20-100A TAB1 MCCB	HPL	TAB1100ST4P	1	1
D	<b>OUTGOING MCCB 63A</b>	MAKE	1	FEEDER QTY	2
1	63A 4P 16kA MCCB, TA Release (Adj Thermal & Fixed Magnetic), Type : TAB1	HPL	TAB168DX063AC4P	1	2
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 20-100A TAB1 MCCB	HPL	TAB1100ST4P	1	2
E	<b>OUTGOING MCCB 40A</b>	MAKE	1	FEEDER QTY	1
1	40A 4P 16kA MCCB, TA Release (Adj Thermal & Fixed Magnetic), Type : TAB1	HPL	TAB168DX040AC4P	1	1
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 20-100A TAB1 MCCB	HPL	TAB1100ST4P	1	1
S.N.	FABRICATION DETAILS	MAKE	TYPE/MATERIAL	QTY	UNIT
1	FABRICATION : 3.15MM CRCA Sheet PRE TREATMENT: 7 TANK PROCESS PAINTING: POWDER COATED WITH SIEMENS GREY SHED (RAL 7032) TYPE: INDOOR TYPE, FREE FLOOR RESTING, FIX TYPE, SINGLE FRONT, COMPARTMENTLISED DESIGN, SINGLE DOOR CABLE ENTRY: TOP/BOTTOM (DETACHABLE GLAND PLATE UNDRILLED)	DVEPL	MS/CRCA	1	JOB
2	<b>BASE FRAME: 40X40X5MM &amp; 800MM</b>	DVEPL	ISMC	1	JOB
3	<b>BUSBAR: PH: 1x30x5, N: 1X30X5</b> Current Density: 1 Amp/Sq. mm Insulation: Color coded heat shrinkable Sleeves	DVEPL	Copper	1	JOB
4	<b>WIRING HARNESS (METERING STARTERS)</b>	DVEPL	CU- WIRE	1	LOT
5	<b>HARDWARE &amp; ACCESSORIES (LOCKS, GASKET, NUT BOLT ETC)</b>	DVEPL	NUT, BOLTS, LUGS ETC.	1	LOT
6	<b>LABOUR</b>	DVEPL		1	JOB
3	<b>SR NO 25</b>		<b>BOARD QTY</b>		
A	<b>INCOMER MCCB 100A</b>		1	FEEDER QTY	1

## MANUFACTURERS OF LT CONTROL PANELS

**Regd. - Administrative Office :**  
Prabhu Niwas Building, Near Ranbir (Kalu) Petrol Pump,  
Dalhousie Road, Pathankot - 145001.  
Tel-Fax I +91 186 2231231

**Factory :**  
F03, F04, F21, Industrial Growth  
Centre, Pathankot - 145001  
Tel.: +91 92572 17609

**Sales Office**  
202 2nd Floor, Golden Square Building,  
Chandigarh, Amabala Highway Zirakpur.

M I +91 94170 21685, +91 94176 01244  
E I dvepl@yahoo.in, office@dvepl.com  
W I www.dvepl.com



SR. NO.	BOQDESCRIPTION	MAKE	CATALOG NUMBER	QTY	TOTAL QTY
1	100A 4P 16kA MCCB (with Spreaders), TA Release (Adj Thermal & Fixed Magnetic), Type : TAB1	HPL	TAB168DX100AC4P	1	1
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 20-100A TAB1 MCCB	HPL	TAB1100ST4P	1	1
<b>B</b>	<b>METERING</b>	<b>MAKE</b>	<b>1</b>	<b>FEEDER QTY</b>	<b>1</b>
1	Multifunction Meter (LCD display), 3Ph, Parameters: V, A, F, PF, kW, kVA, Old energy, On hours, site selectable kWh/ kVAh, CL: 1, Aux Sup: 90-300V AC/DC, Size: 96X96	L&T	WC4400100000	1	1
2	Red Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLR240A	1	1
3	Yellow Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLY240A	1	1
4	Blue Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLB240A	1	1
5	32A Neutral Link, Color: Black/Khaki	FTC	FNL 32	1	1
6	100/5A 5VA Acc. Cl: 1, ABS Insulated Bar Primary Ring Type Current Transformer, ID: 33mm	NIPPEN	NA	3	3
7	6 Sq.mm Disconnecting Terminal (Std. Color),Type: KUTSD 6	ELMEX	KUTSD 6	3	3
8	6A 1P 10kA C-Curve Techno MCB	HPL	NTSPC06	3	3
<b>C</b>	<b>OUTGOING MCCB 40A</b>	<b>MAKE</b>	<b>1</b>	<b>FEEDER QTY</b>	<b>4</b>
1	40A 4P 16kA MCCB, TA Release (Adj Thermal & Fixed Magnetic), Type : TAB1	HPL	TAB168DX040AC4P	1	4
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 20-100A TAB1 MCCB	HPL	TAB1100ST4P	1	4
<b>D</b>	<b>OUTGOING MCB 63A</b>	<b>MAKE</b>	<b>1</b>	<b>FEEDER QTY</b>	<b>2</b>
1	63A 1PN 10kA C-Curve Techno MCB	HPL	NTSPNC63	1	2
<b>S.N.</b>	<b>FABRICATION DETAILS</b>	<b>MAKE</b>	<b>TYPE/MATERIAL</b>	<b>QTY</b>	<b>UNIT</b>
1	FABRICATION : 3.15MM CRCA Sheet PRE TREATMENT: 7 TANK PROCESS PAINTING: POWDER COATED WITH SIEMENS GREY SHED (RAL 7032) TYPE: INDOOR TYPE, FREE FLOOR RESTING, FIX TYPE, SINGLE FRONT, COMPARTMENTLISED DESIGN, SINGLE DOOR CABLE ENTRY: TOP/BOTTOM (DETACHABLE GLAND PLATE UNDRILLED)	DVEPL	MS/CRCA	1	JOB
2	<b>BASE FRAME: 40X40X5MM &amp; 800MM</b>	DVEPL	ISMC	1	JOB
3	<b>BUSBAR: PH: 1x20x5, N: 1X20X5</b> Current Density: 1 Amp/Sq. mm Insulation: Color coded heat shrinkable Sleeves	DVEPL	Copper	1	JOB
4	<b>WIRING HARNESS (METERING STARTERS)</b>	DVEPL	CU- WIRE	1	LOT
5	<b>HARDWARE &amp; ACCESSORIES (LOCKS, GASKET, NUT BOLT ETC)</b>	DVEPL	NUT, BOLTS, LUGS ETC.	1	LOT
6	<b>LABOUR</b>	DVEPL		1	JOB
<b>4</b>	<b>SR NO 26</b>		<b>BOARD QTY</b>		
<b>A</b>	<b>INCOMER MCCB 200A</b>		<b>1</b>	<b>FEEDER QTY</b>	<b>1</b>
SR. NO.	BOQDESCRIPTION	MAKE	CATALOG NUMBER	QTY	TOTAL QTY
1	200A 4P 25kA MCCB (with Spreaders), TA Release (Adj Thermal & Fixed Magnetic), Type : TAB2	HPL	TAB250CX200AC4P	1	1
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 168-200A TAB2 MCCB	HPL	TAB2200ST4P	1	1
<b>B</b>	<b>METERING</b>	<b>MAKE</b>	<b>1</b>	<b>FEEDER QTY</b>	<b>1</b>
1	Multifunction Meter (LCD display), 3Ph, Parameters: V, A, F, PF, kW, kVA, Old energy, On hours, site selectable kWh/ kVAh, CL: 1, Aux Sup: 90-300V AC/DC, Size: 96X96	L&T	WC4400100000	1	1
2	Red Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLR240A	1	1
3	Yellow Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLY240A	1	1
4	Blue Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLB240A	1	1
5	32A Neutral Link, Color: Black/Khaki	FTC	FNL 32	1	1

## MANUFACTURERS OF LT CONTROL PANELS

**Regd. - Administrative Office :**  
Prabhu Niwas Building, Near Ranbir (Kalu) Petrol Pump,  
Dalhousie Road, Pathankot - 145001.  
Tel-Fax : +91 186 2231231

**Factory :**  
F03, F04, F21, Industrial Growth  
Centre, Pathankot - 145001  
Tel.: +91 92572 17609

**Sales Office**  
202 2nd Floor, Golden Square Building,  
Chandigarh, Amabala Highway Zirakpur.

M : +91 94170 21685, +91 94176 01244  
E : dvepl@yahoo.in, office@dvepl.com  
W : www.dvepl.com





6	200/5A 5VA Acc. Cl: 1, ABS Insulated Bar Primary Ring Type Current Transformer, ID: 34mm	NIPPEN	NA	3	3
7	6 Sq.mm Disconnecting Terminal (Std. Color),Type: KUTSD 6	ELMEX	KUTSD 6	3	3
8	6A 1P 10kA C-Curve Techno MCB	HPL	NTSPC06	3	3
C	<b>OUTGOING MCC 63A</b>	<b>MAKE</b>	<b>1</b>	<b>FEEDER QTY</b>	<b>1</b>
1	63A 4P 16kA MCCB, TA Release (Adj Thermal & Fixed Magnetic), Type : TAB1	HPL	TAB168DX063AC4P	1	1
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 20-100A TAB1 MCCB	HPL	TAB1100ST4P	1	1
D	<b>OUTGOING MCCB 40A</b>	<b>MAKE</b>	<b>1</b>	<b>FEEDER QTY</b>	<b>1</b>
1	40A 4P 16kA MCCB, TA Release (Adj Thermal & Fixed Magnetic), Type : TAB1	HPL	TAB168DX040AC4P	1	1
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 20-100A TAB1 MCCB	HPL	TAB1100ST4P	1	1
E	<b>OUTGOING MCB 63A</b>	<b>MAKE</b>	<b>1</b>	<b>FEEDER QTY</b>	<b>1</b>
1	63A 1PN 10kA C-Curve Techno MCB	HPL	NTSPNC63	1	1
S.N.	<b>FABRICATION DETAILS</b>	<b>MAKE</b>	<b>TYPE/MATERIAL</b>	<b>QTY</b>	<b>UNIT</b>
1	FABRICATION : 3.15MM CRCA Sheet PRE TREATMENT: 7 TANK PROCESS PAINTING: POWDER COATED WITH SIEMENS GREY SHED (RAL 7032) TYPE: INDOOR TYPE, FREE FLOOR RESTING, FIX TYPE, SINGLE FRONT, COMPARTMENTLISED DESIGN, SINGLE DOOR CABLE ENTRY: TOP/BOTTOM (DETACHABLE GLAND PLATE UNDRILLED)	DVEPL	MS/CRCA	1	JOB
2	<b>BASE FRAME: 40X40X5MM &amp; 800MM</b>	DVEPL	ISMC	1	JOB
3	<b>BUSBAR: PH: 1x30x5, N: 1X30X5</b> Current Density: 1 Amp/Sq. mm Insulation: Color coded heat shrinkable Sleeves	DVEPL	Copper	1	JOB
4	<b>WIRING HARNESS (METERING STARTERS)</b>	DVEPL	CU- WIRE	1	LOT
5	<b>HARDWARE &amp; ACCESSORIES (LOCKS, GASKET, NUT BOLT ETC)</b>	DVEPL	NUT, BOLTS, LUGS ETC.	1	LOT
6	<b>LABOUR</b>	DVEPL		1	JOB
5	<b>SR NO 27</b>		<b>BOARD QTY</b>		
A	<b>INCOMER MCCB 400A</b>		<b>1</b>	<b>FEEDER QTY</b>	<b>1</b>
SR. NO.	<b>BOQDESCRIPTION</b>	<b>MAKE</b>	<b>CATALOG NUMBER</b>	<b>QTY</b>	<b>TOTAL QTY</b>
1	400A 4P 36kA MCCB (with Spreaders), TM Release (Adj Thermal & Adj Magnetic), Type : TAB3	HPL	TAB630NX400AC4P	1	1
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 400A TAB3 MCCB	HPL	TAB3400ST4P	1	1
B	<b>METERING</b>	<b>MAKE</b>	<b>1</b>	<b>FEEDER QTY</b>	<b>1</b>
1	Multifunction Meter (LCD display), 3Ph, Parameters: V, A, F, PF, kW, kVA, Old energy, On hours, site selectable kWh/ kVAh, CL: 1, Aux Sup: 90-300V AC/DC, Size: 96X96	L&T	WC4400100000	1	1
2	Red Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLR240A	1	1
3	Yellow Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLY240A	1	1
4	Blue Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLB240A	1	1
5	32A Neutral Link, Color: Black/Khaki	FTC	FNL 32	1	1
6	400/5A 10VA Acc. Cl: 1, ABS Insulated Bar Primary Ring Type Current Transformer, ID: 68mm	NIPPEN	NA	3	3
7	6 Sq.mm Disconnecting Terminal (Std. Color),Type: KUTSD 6	ELMEX	KUTSD 6	3	3
8	6A 1P 10kA C-Curve Techno MCB	HPL	NTSPC06	3	3
	<b>ON LOAD C/O 400A</b>	<b>MAKE</b>	<b>1</b>	<b>FEEDER QTY</b>	<b>1</b>
1	400A 4P Front Operated On Load Changeover Switch, Open Execution	HPL	C04004POAV	1	1
C	<b>OUTGOING MCCB 200A</b>	<b>MAKE</b>	<b>1</b>	<b>FEEDER QTY</b>	<b>2</b>
1	200A 4P 25kA MCCB (with Spreaders), TA Release (Adj Thermal & Fixed Magnetic), Type : TAB2	HPL	TAB250CX200AC4P	1	2

## MANUFACTURERS OF LT CONTROL PANELS

**Regd. - Administrative Office :**  
Prabhu Niwas Building, Near Ranbir (Kalu) Petrol Pump,  
Dalhousie Road, Pathankot - 145001.  
Tel-Fax : +91 186 2231231

**Factory :**  
F03, F04, F21, Industrial Growth  
Centre, Pathankot - 145001  
Tel. : +91 92572 17609

**Sales Office**  
202 2nd Floor, Golden Square Building,  
Chandigarh, Amabala Highway Zirakpur.

M : +91 94170 21685, +91 94176 01244  
E : dvepl@yahoo.in, office@dvepl.com  
W : www.dvepl.com



2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 168-200A TAB2 MCCB	HPL	TAB2200ST4P	1	2
<b>D</b>	<b>OUTGOING MCCB 100A</b>	<b>MAKE</b>	<b>1</b>	<b>FEEDER QTY</b>	<b>1</b>
1	100A 4P 16kA MCCB (with Spreaders), TA Release (Adj Thermal & Fixed Magnetic), Type : TAB1	HPL	TAB168DX100AC4P	1	1
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 20-100A TAB1 MCCB	HPL	TAB1100ST4P	1	1
<b>E</b>	<b>OUTGOING MCCB 63A</b>	<b>MAKE</b>	<b>1</b>	<b>FEEDER QTY</b>	<b>1</b>
1	63A 4P 16kA MCCB, TA Release (Adj Thermal & Fixed Magnetic), Type : TAB1	HPL	TAB168DX063AC4P	1	1
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 20-100A TAB1 MCCB	HPL	TAB1100ST4P	1	1
<b>F</b>	<b>OUTGOING MCCB 40A</b>	<b>MAKE</b>	<b>1</b>	<b>FEEDER QTY</b>	<b>2</b>
1	40A 4P 16kA MCCB, TA Release (Adj Thermal & Fixed Magnetic), Type : TAB1	HPL	TAB168DX040AC4P	1	2
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 20-100A TAB1 MCCB	HPL	TAB1100ST4P	1	2
<b>S.N.</b>	<b>FABRICATION DETAILS</b>	<b>MAKE</b>	<b>TYPE/MATERIAL</b>	<b>QTY</b>	<b>UNIT</b>
1	FABRICATION : 3.15MM CRCA Sheet PRE TREATMENT: 7 TANK PROCESS PAINTING: POWDER COATED WITH SIEMENS GREY SHED (RAL 7032) TYPE: INDOOR TYPE, FREE FLOOR RESTING, FIX TYPE, SINGLE FRONT, COMPARTMENTLISED DESIGN, SINGLE DOOR CABLE ENTRY: TOP/BOTTOM (DETACHABLE GLAND PLATE UNDRILLED)	DVEPL	MS/CRCA	1	JOB
2	<b>BASE FRAME: 40X40X5MM &amp; 800MM</b>	DVEPL	ISMC	1	JOB
3	<b>BUSBAR: PH: 1x30x10, N: 1X30X10</b> Current Density: 1 Amp/Sq. mm Insulation: Color coded heat shrinkable Sleeves	DVEPL	Copper	1	JOB
4	<b>WIRING HARNESS (METERING STARTERS)</b>	DVEPL	CU- WIRE	1	LOT
5	<b>HARDWARE &amp; ACCESSORIES (LOCKS, GASKET, NUT BOLT ETC)</b>	DVEPL	NUT, BOLTS, LUGS ETC.	1	LOT
6	<b>LABOUR</b>	DVEPL		1	JOB
<b>6</b>	<b>SR NO 28</b>		<b>BOARD QTY</b>		
<b>A</b>	<b>INCOMER MCCB 200A</b>		<b>1</b>	<b>FEEDER QTY</b>	<b>1</b>
<b>SR. NO.</b>	<b>BOQDESCRIPTION</b>	<b>MAKE</b>	<b>CATALOG NUMBER</b>	<b>QTY</b>	<b>TOTAL QTY</b>
1	200A 4P 25kA MCCB (with Spreaders), TA Release (Adj Thermal & Fixed Magnetic), Type : TAB2	HPL	TAB250CX200AC4P	1	1
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 168-200A TAB2 MCCB	HPL	TAB2200ST4P	1	1
<b>B</b>	<b>METERING</b>	<b>MAKE</b>	<b>1</b>	<b>FEEDER QTY</b>	<b>1</b>
1	Multifunction Meter (LCD display), 3Ph, Parameters: V, A, F, PF, kW, kVA, Old energy, On hours, site selectable kWh/ kVAh, CL: 1, Aux Sup: 90-300V AC/DC, Size: 96X96	L&T	WC4400100000	1	1
2	Red Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLR240A	1	1
3	Yellow Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLY240A	1	1
4	Blue Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLB240A	1	1
5	32A Neutral Link, Color: Black/Khaki	FTC	FNL 32	1	1
6	200/5A 5VA Acc. Cl: 1, ABS Insulated Bar Primary Ring Type Current Transformer, ID: 34mm	NIPPEN	NA	3	3
7	6 Sq.mm Disconnecting Terminal (Std. Color),Type: KUTSD 6	ELMEX	KUTSD 6	3	3
8	6A 1P 10kA C-Curve Techno MCB	HPL	NTSPC06	3	3
<b>C</b>	<b>OUTGOING MCCB 100A</b>	<b>MAKE</b>	<b>1</b>	<b>FEEDER QTY</b>	<b>1</b>
1	100A 4P 16kA MCCB (with Spreaders), TA Release (Adj Thermal & Fixed Magnetic), Type : TAB1	HPL	TAB168DX100AC4P	1	1
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 20-100A TAB1 MCCB	HPL	TAB1100ST4P	1	1
<b>D</b>	<b>OUTGOING MCCB 63A</b>	<b>MAKE</b>	<b>1</b>	<b>FEEDER QTY</b>	<b>2</b>
1	63A 4P 16kA MCCB, TA Release (Adj Thermal & Fixed Magnetic), Type : TAB1	HPL	TAB168DX063AC4P	1	2

## MANUFACTURERS OF LT CONTROL PANELS

**Regd. - Administrative Office :**  
Prabhu Niwas Building, Near Ranbir (Kalu) Petrol Pump,  
Dalhousie Road, Pathankot - 145001.  
Tel-Fax I +91 186 2231231

**Factory :**  
F03, F04, F21, Industrial Growth  
Centre, Pathankot - 145001  
Tel.: +91 92572 17609

**Sales Office**  
202 2nd Floor, Golden Square Building,  
Chandigarh, Amabala Highway Zirakpur.

M I +91 94170 21685, +91 94176 01244  
E I dvepl@yahoo.in, office@dvepl.com  
W I www.dvepl.com



2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 20-100A TAB1 MCCB	HPL	TAB1100ST4P	1	2
E	<b>OUTGOING MCCB 40A</b>	<b>MAKE</b>	<b>1</b>	<b>FEEDER QTY</b>	<b>1</b>
1	40A 4P 16kA MCCB, TA Release (Adj Thermal & Fixed Magnetic), Type : TAB1	HPL	TAB168DX040AC4P	1	1
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 20-100A TAB1 MCCB	HPL	TAB1100ST4P	1	1
S.N.	<b>FABRICATION DETAILS</b>	<b>MAKE</b>	<b>TYPE/MATERIAL</b>	<b>QTY</b>	<b>UNIT</b>
1	FABRICATION : 3.15MM CRCA Sheet PRE TREATMENT: 7 TANK PROCESS PAINTING: POWDER COATED WITH SIEMENS GREY SHED (RAL 7032) TYPE: INDOOR TYPE, FREE FLOOR RESTING, FIX TYPE, SINGLE FRONT, COMPARTMENTLISED DESIGN, SINGLE DOOR CABLE ENTRY: TOP/BOTTOM (DETACHABLE GLAND PLATE UNDRILLED)	DVEPL	MS/CRCA	1	JOB
2	<b>BASE FRAME: 40X40X5MM &amp; 800MM</b>	DVEPL	ISMC	1	JOB
3	<b>BUSBAR: PH: 1x30X5, N: 1X30X5</b> Current Density: 1 Amp/Sq. mm Insulation: Color coded heat shrinkable Sleeves	DVEPL	Copper	1	JOB
4	<b>WIRING HARNESS (METERING STARTERS)</b>	DVEPL	CU- WIRE	1	LOT
5	<b>HARDWARE &amp; ACCESSORIES (LOCKS, GASKET, NUT BOLT ETC)</b>	DVEPL	NUT, BOLTS, LUGS ETC.	1	LOT
6	<b>LABOUR</b>	DVEPL		1	JOB
7	<b>SR NO 29</b>		<b>BOARD QTY</b>		
A	<b>INCOMER MCCB 200A</b>		<b>1</b>	<b>FEEDER QTY</b>	<b>1</b>
SR. NO.	<b>BOQDESCRIPTION</b>	<b>MAKE</b>	<b>CATALOG NUMBER</b>	<b>QTY</b>	<b>TOTAL QTY</b>
1	200A 4P 25kA MCCB (with Spreaders), TA Release (Adj Thermal & Fixed Magnetic), Type : TAB2	HPL	TAB250CX200AC4P	1	1
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 168-200A TAB2 MCCB	HPL	TAB2200ST4P	1	1
B	<b>METERING</b>	<b>MAKE</b>	<b>1</b>	<b>FEEDER QTY</b>	<b>1</b>
1	Multifunction Meter (LCD display), 3Ph, Parameters: V, A, F, PF, kW, kVA, Old energy, On hours, site selectable kWh/ kVAh, CL: 1, Aux Sup: 90-300V AC/DC, Size: 96X96	L&T	WC4400100000	1	1
2	Red Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLR240A	1	1
3	Yellow Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLY240A	1	1
4	Blue Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLB240A	1	1
5	32A Neutral Link, Color: Black/Khaki	FTC	FNL 32	1	1
6	200/5A 5VA Acc. Cl: 1, ABS Insulated Bar Primary Ring Type Current Transformer, ID: 34mm	NIPPEN	NA	3	3
7	6 Sq.mm Disconnecting Terminal (Std. Color),Type: KUTSD 6	ELMEX	KUTSD 6	3	3
8	6A 1P 10kA C-Curve Techno MCB	HPL	NTSPC06	3	3
C	<b>OUTGOING MCCB 100A</b>	<b>MAKE</b>	<b>1</b>	<b>FEEDER QTY</b>	<b>1</b>
1	100A 4P 16kA MCCB (with Spreaders), TA Release (Adj Thermal & Fixed Magnetic), Type : TAB1	HPL	TAB168DX100AC4P	1	1
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 20-100A TAB1 MCCB	HPL	TAB1100ST4P	1	1
D	<b>OUTGOING MCCB 63A</b>	<b>MAKE</b>	<b>1</b>	<b>FEEDER QTY</b>	<b>1</b>
1	63A 4P 16kA MCCB, TA Release (Adj Thermal & Fixed Magnetic), Type : TAB1	HPL	TAB168DX063AC4P	1	1
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 20-100A TAB1 MCCB	HPL	TAB1100ST4P	1	1
E	<b>OUTGOING MCCB 40A</b>	<b>MAKE</b>	<b>1</b>	<b>FEEDER QTY</b>	<b>2</b>
1	40A 4P 16kA MCCB, TA Release (Adj Thermal & Fixed Magnetic), Type : TAB1	HPL	TAB168DX040AC4P	1	2
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 20-100A TAB1 MCCB	HPL	TAB1100ST4P	1	2
F	<b>OUTGOING MCB 63A</b>	<b>MAKE</b>	<b>1</b>	<b>FEEDER QTY</b>	<b>3</b>
1	63A 1PN 10kA C-Curve Techno MCB	HPL	NTSPNC63	1	3
S.N.	<b>FABRICATION DETAILS</b>	<b>MAKE</b>	<b>TYPE/MATERIAL</b>	<b>QTY</b>	<b>UNIT</b>

## MANUFACTURERS OF LT CONTROL PANELS

**Regd. - Administrative Office :**  
Prabhu Niwas Building, Near Ranbir (Kalu) Petrol Pump,  
Dalhousie Road, Pathankot - 145001.  
Tel-Fax : +91 186 2231231

**Factory :**  
F03, F04, F21, Industrial Growth  
Centre, Pathankot - 145001  
Tel.: +91 92572 17609

**Sales Office**  
202 2nd Floor, Golden Square Building,  
Chandigarh, Amabala Highway Zirakpur.

M : +91 94170 21685, +91 94176 01244  
E : dvepl@yahoo.in, office@dvepl.com  
W : www.dvepl.com





1	FABRICATION : 3.15MM CRCA Sheet PRE TREATMENT: 7 TANK PROCESS PAINTING: POWDER COATED WITH SIEMENS GREY SHED (RAL 7032) TYPE: INDOOR TYPE, FREE FLOOR RESTING, FIX TYPE, SINGLE FRONT, COMPARTMENTLISED DESIGN, SINGLE DOOR CABLE ENTRY: TOP/BOTTOM (DETACHABLE GLAND PLATE UNDRILLED)	DVEPL	MS/CRCA	1	JOB
2	<b>BASE FRAME: 40X40X5MM &amp; 800MM</b>	DVEPL	ISMC	1	JOB
3	<b>BUSBAR: PH: 1x30x5, N: 1X30X5</b> Current Density: 1 Amp/Sq. mm Insulation: Color coded heat shrinkable Sleeves	DVEPL	Copper	1	JOB
4	<b>WIRING HARNESS (METERING STARTERS)</b>	DVEPL	CU- WIRE	1	LOT
5	<b>HARDWARE &amp; ACCESSORIES (LOCKS, GASKET, NUT BOLT ETC)</b>	DVEPL	NUT, BOLTS, LUGS ETC.	1	LOT
6	<b>LABOUR</b>	DVEPL		1	JOB
8	<b>SR NO 30</b>		<b>BOARD QTY</b>		
A	<b>INCOMER MCCB 400A</b>		1	FEEDER QTY	1
SR. NO.	BOQDESCRIPTION	MAKE	CATALOG NUMBER	QTY	TOTAL QTY
1	400A 4P 36kA MCCB (with Spreaders), TM Release (Adj Thermal & Adj Magnetic), Type : TAB3	HPL	TAB630NX400AC4P	1	1
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 400A TAB3 MCCB	HPL	TAB3400ST4P	1	1
B	<b>METERING</b>	MAKE	1	FEEDER QTY	1
1	Multifunction Meter (LCD display), 3Ph, Parameters: V, A, F, PF, kW, kVA, Old energy, On hours, site selectable kWh/ kVAh, CL: 1, Aux Sup: 90-300V AC/DC, Size: 96X96	L&T	WC4400100000	1	1
2	Red Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLR240A	1	1
3	Yellow Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLY240A	1	1
4	Blue Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLB240A	1	1
5	32A Neutral Link, Color: Black/Khaki	FTC	FNL 32	1	1
6	400/5A 10VA Acc. Cl: 1, ABS Insulated Bar Primary Ring Type Current Transformer, ID: 68mm	NIPPEN	NA	3	3
7	6 Sq.mm Disconnecting Terminal (Std. Color),Type: KUTSD 6	ELMEX	KUTSD 6	3	3
8	6A 1P 10kA C-Curve Techno MCB	HPL	NTSPC06	3	3
C	<b>OUTGOING MCCB 200A</b>	MAKE	1	FEEDER QTY	2
1	200A 4P 25kA MCCB (with Spreaders), TA Release (Adj Thermal & Fixed Magnetic), Type : TAB2	HPL	TAB250CX200AC4P	1	2
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 168-200A TAB2 MCCB	HPL	TAB2200ST4P	1	2
D	<b>OUTGOING MCCB 100A</b>	MAKE	1	FEEDER QTY	1
1	100A 4P 16kA MCCB (with Spreaders), TA Release (Adj Thermal & Fixed Magnetic), Type : TAB1	HPL	TAB168DX100AC4P	1	1
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 20-100A TAB1 MCCB	HPL	TAB1100ST4P	1	1
F	<b>OUTGOING MCCB 40A</b>	MAKE	1	FEEDER QTY	3
1	40A 4P 16kA MCCB, TA Release (Adj Thermal & Fixed Magnetic), Type : TAB1	HPL	TAB168DX040AC4P	1	3
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 20-100A TAB1 MCCB	HPL	TAB1100ST4P	1	3
S.N.	FABRICATION DETAILS	MAKE	TYPE/MATERIAL	QTY	UNIT
1	FABRICATION : 3.15MM CRCA Sheet PRE TREATMENT: 7 TANK PROCESS PAINTING: POWDER COATED WITH SIEMENS GREY SHED (RAL 7032) TYPE: INDOOR TYPE, FREE FLOOR RESTING, FIX TYPE, SINGLE FRONT, COMPARTMENTLISED DESIGN, SINGLE DOOR CABLE ENTRY: TOP/BOTTOM (DETACHABLE GLAND PLATE UNDRILLED)	DVEPL	MS/CRCA	1	JOB
2	<b>BASE FRAME: 40X40X5MM &amp; 800MM</b>	DVEPL	ISMC	1	JOB

## MANUFACTURERS OF LT CONTROL PANELS

**Regd. - Administrative Office :**  
Prabhu Niwas Building, Near Ranbir (Kalu) Petrol Pump,  
Dalhousie Road, Pathankot - 145001.  
Tel-Fax I +91 186 2231231

**Factory :**  
F03, F04, F21, Industrial Growth  
Centre, Pathankot - 145001  
Tel.: +91 92572 17609

**Sales Office**  
202 2nd Floor, Golden Square Building,  
Chandigarh, Amabala Highway Zirakpur.

M I +91 94170 21685, +91 94176 01244  
E I dvepl@yahoo.in, office@dvepl.com  
W I www.dvepl.com



3	<b>BUSBAR: PH: 1x30x10, N: 1X30X10</b> Current Density: 1 Amp/Sq. mm Insulation: Color coded heat shrinkable Sleeves	DVEPL	Copper	1	JOB
4	<b>WIRING HARNESS (METERING STARTERS)</b>	DVEPL	CU- WIRE	1	LOT
5	<b>HARDWARE &amp; ACCESSORIES (LOCKS, GASKET, NUT BOLT ETC)</b>	DVEPL	NUT, BOLTS, LUGS ETC.	1	LOT
6	<b>LABOUR</b>	DVEPL		1	JOB
9	<b>SR NO 31</b>		<b>BOARD QTY</b>		
A	<b>INCOMER MCCB 200A</b>		1	FEEDER QTY	1
SR. NO.	BOQDESCRIPTION	MAKE	CATALOG NUMBER	QTY	TOTAL QTY
1	200A 4P 25kA MCCB (with Spreaders), TA Release (Adj Thermal & Fixed Magnetic), Type : TAB2	HPL	TAB250CX200AC4P	1	1
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 168-200A TAB2 MCCB	HPL	TAB2200ST4P	1	1
B	<b>METERING</b>	MAKE	1	FEEDER QTY	1
1	Multifunction Meter (LCD display), 3Ph, Parameters: V, A, F, PF, kW, kVA, Old energy, On hours, site selectable kWh/ kVAh, CL: 1, Aux Sup: 90-300V AC/DC, Size: 96X96	L&T	WC4400100000	1	1
2	Red Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLR240A	1	1
3	Yellow Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	HPL	EPLY240A	1	1
4	Blue Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLB240A	1	1
5	32A Neutral Link, Color: Black/Khaki	FTC	FNL 32	1	1
6	200/5A 5VA Acc. Cl: 1, ABS Insulated Bar Primary Ring Type Current Transformer, ID: 34mm	NIPPEN	NA	3	3
7	6 Sq.mm Disconnecting Terminal (Std. Color),Type: KUTSD 6	ELMEX	KUTSD 6	3	3
8	6A 1P 10kA C-Curve Techno MCB	HPL	NTSPC06	3	3
C	<b>OUTGOING MCCB 100A</b>	MAKE	1	FEEDER QTY	2
1	100A 4P 16kA MCCB (with Spreaders), TA Release (Adj Thermal & Fixed Magnetic), Type : TAB1	HPL	TAB168DX100AC4P	1	2
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 20-100A TAB1 MCCB	HPL	TAB1100ST4P	1	2
D	<b>OUTGOING MCCB 40A</b>	MAKE	1	FEEDER QTY	2
1	40A 4P 16kA MCCB, TA Release (Adj Thermal & Fixed Magnetic), Type : TAB1	HPL	TAB168DX040AC4P	1	2
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 20-100A TAB1 MCCB	HPL	TAB1100ST4P	1	2
S.N.	FABRICATION DETAILS	MAKE	TYPE/MATERIAL	QTY	UNIT
1	FABRICATION : 3.15MM CRCA Sheet PRE TREATMENT: 7 TANK PROCESS PAINTING: POWDER COATED WITH SIEMENS GREY SHED (RAL 7032) TYPE: INDOOR TYPE, FREE FLOOR RESTING, FIX TYPE, SINGLE FRONT, COMPARTMENTLISED DESIGN, SINGLE DOOR CABLE ENTRY: TOP/BOTTOM (DETACHABLE GLAND PLATE UNDRILLED)	DVEPL	MS/CRCA	1	JOB
2	<b>BASE FRAME: 40X40X5MM &amp; 800MM</b>	DVEPL	ISMC	1	JOB
3	<b>BUSBAR: PH: 1x30x5, N: 1X30X5, E: 1X00X10</b> Current Density: 1 Amp/Sq. mm Insulation: Color coded heat shrinkable Sleeves	DVEPL	Copper	1	JOB
4	<b>WIRING HARNESS (METERING STARTERS)</b>	DVEPL	CU- WIRE	1	LOT
5	<b>HARDWARE &amp; ACCESSORIES (LOCKS, GASKET, NUT BOLT ETC)</b>	DVEPL	NUT, BOLTS, LUGS ETC.	1	LOT
6	<b>LABOUR</b>	DVEPL		1	JOB
10	<b>SR NO 32</b>		<b>BOARD QTY</b>		
A	<b>INCOMER MCCB 200A</b>		1	FEEDER QTY	1
SR. NO.	BOQDESCRIPTION	MAKE	CATALOG NUMBER	QTY	TOTAL QTY
1	200A 4P 25kA MCCB (with Spreaders), TA Release (Adj Thermal & Fixed Magnetic), Type : TAB2	HPL	TAB250CX200AC4P	1	1

## MANUFACTURERS OF LT CONTROL PANELS

**Regd. - Administrative Office :**  
Prabhu Niwas Building, Near Ranbir (Kalu) Petrol Pump,  
Dalhousie Road, Pathankot - 145001.  
Tel-Fax I +91 186 2231231

**Factory :**  
F03, F04, F21,Industrial Growth  
Centre,Pathankot - 145001  
Tel.: +91 92572 17609

**Sales Office**  
202 2nd Floor, Golden Square Building,  
Chandigarh, Amabala Highway Zirakpur.

M I +91 94170 21685, +91 94176 01244  
E I dvepl@yahoo.in, office@dvepl.com  
W I www.dvepl.com



2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 168-200A TAB2 MCCB	HPL	TAB2200ST4P	1	1
<b>B</b>	<b>METERING</b>	<b>MAKE</b>	<b>1</b>	<b>FEEDER QTY</b>	<b>1</b>
1	Multifunction Meter (LCD display), 3Ph, Parameters: V, A, F, PF, kW, kVA, Old energy, On hours, site selectable kWh/ kVAh, CL: 1, Aux Sup: 90-300V AC/DC, Size: 96X96	L&T	WC4400100000	1	1
2	Red Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLR240A	1	1
3	Yellow Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLY240A	1	1
4	Blue Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLB240A	1	1
5	32A Neutral Link, Color: Black/Khaki	FTC	FNL 32	1	1
6	200/5A 5VA Acc. CL: 1, ABS Insulated Bar Primary Ring Type Current Transformer, ID: 34mm	NIPPEN	NA	3	3
7	6 Sq.mm Disconnecting Terminal (Std. Color),Type: KUTSD 6	ELMEX	KUTSD 6	3	3
8	6A 1P 10kA C-Curve Techno MCB	HPL	NTSPC06	3	3
	<b>ON LOAD C/O 200A</b>	<b>MAKE</b>	<b>1</b>	<b>FEEDER QTY</b>	<b>1</b>
1	200A 4P Front Operated On Load Changeover Switch, Open Execution	HPL	C02004POAV	1	1
<b>C</b>	<b>OUTGOING MCCB 168A</b>	<b>MAKE</b>	<b>1</b>	<b>FEEDER QTY</b>	<b>1</b>
1	168A 4P 25kA MCCB (with Spreaders), TA Release (Adj Thermal & Fixed Magnetic), Type : TAB1	HPL	TAB168CY168AC4P	1	1
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 125-168A TAB1 MCCB	HPL	TAB1168ST4P	1	1
<b>D</b>	<b>OUTGOING MCCB 100A</b>	<b>MAKE</b>	<b>1</b>	<b>FEEDER QTY</b>	<b>1</b>
1	100A 4P 16kA MCCB (with Spreaders), TA Release (Adj Thermal & Fixed Magnetic), Type : TAB1	HPL	TAB168DX100AC4P	1	1
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 20-100A TAB1 MCCB	HPL	TAB1100ST4P	1	1
<b>E</b>	<b>OUTGOING MCCB 40A</b>	<b>MAKE</b>	<b>1</b>	<b>FEEDER QTY</b>	<b>1</b>
1	40A 4P 16kA MCCB, TA Release (Adj Thermal & Fixed Magnetic), Type : TAB1	HPL	TAB168DX040AC4P	1	1
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 20-100A TAB1 MCCB	HPL	TAB1100ST4P	1	1
<b>S.N.</b>	<b>FABRICATION DETAILS</b>	<b>MAKE</b>	<b>TYPE/MATERIAL</b>	<b>QTY</b>	<b>UNIT</b>
1	FABRICATION : 3.15MM CRCA Sheet PRE TREATMENT: 7 TANK PROCESS PAINTING: POWDER COATED WITH SIEMENS GREY SHED (RAL 7032) TYPE: INDOOR TYPE, FREE FLOOR RESTING, FIX TYPE, SINGLE FRONT, COMPARTMENTLISED DESIGN, SINGLE DOOR CABLE ENTRY: TOP/BOTTOM (DETACHABLE GLAND PLATE UNDRILLED)	DVEPL	MS/CRCA	1	JOB
2	<b>BASE FRAME: 40X40X5MM &amp; 800MM</b>	DVEPL	ISMC	1	JOB
3	<b>BUSBAR: PH: 1x000x10, N: 1X000X10, E: 1X00X10</b> Material: Electrolytic grade Aluminum Current Density: 1 Amp/Sq. mm Insulation: Color coded heat shrinkable Sleeves	DVEPL	Aluminum	1	JOB
4	<b>WIRING HARNESS (METERING STARTERS)</b>	DVEPL	CU- WIRE	1	LOT
5	<b>HARDWARE &amp; ACCESSORIES (LOCKS, GASKET, NUT BOLT ETC)</b>	DVEPL	NUT, BOLTS, LUGS ETC.	1	LOT
6	<b>LABOUR</b>	DVEPL		1	JOB
<b>11</b>	<b>SR NO 33</b>		<b>BOARD QTY</b>		
<b>A</b>	<b>INCOMING MCCB 168A</b>		<b>1</b>	<b>FEEDER QTY</b>	<b>1</b>
<b>SR. NO.</b>	<b>BOQDESCRIPTION</b>	<b>MAKE</b>	<b>CATALOG NUMBER</b>	<b>QTY</b>	<b>TOTAL QTY</b>
1	168A 4P 25kA MCCB (with Spreaders), TA Release (Adj Thermal & Fixed Magnetic), Type : TAB1	HPL	TAB168CY168AC4P	1	1
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 125-168A TAB1 MCCB	HPL	TAB1168ST4P	1	1
<b>B</b>	<b>METERING</b>	<b>MAKE</b>	<b>1</b>	<b>FEEDER QTY</b>	<b>1</b>

## MANUFACTURERS OF LT CONTROL PANELS

**Regd. - Administrative Office :**  
Prabhu Niwas Building, Near Ranbir (Kalu) Petrol Pump,  
Dalhousie Road, Pathankot - 145001.  
Tel-Fax I +91 186 2231231

**Factory :**  
F03, F04, F21,Industrial Growth  
Centre,Pathankot - 145001  
Tel.: +91 92572 17609

**Sales Office**  
202 2nd Floor, Golden Square Building,  
Chandigarh, Amabala Highway Zirakpur.

M I +91 94170 21685, +91 94176 01244  
E I dvepl@yahoo.in, office@dvepl.com  
W I www.dvepl.com



1	Multifunction Meter (LCD display), 3Ph, Parameters: V, A, F, PF, kW, kVA, Old energy, On hours, site selectable kWh/ kVAh, CL: 1, Aux Sup: 90-300V AC/DC, Size: 96X96	L&T	WC4400100000	1	1
2	Red Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLR240A	1	1
3	Yellow Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLY240A	1	1
4	Blue Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLB240A	1	1
5	32A Neutral Link, Color: Black/Khaki	FTC	FNL 32	1	1
6	200/5A 5VA Acc. CL: 1, ABS Insulated Bar Primary Ring Type Current Transformer, ID: 34mm	NIPPEN	NA	3	3
7	6 Sq.mm Disconnecting Terminal (Std. Color),Type: KUTSD 6	ELMEX	KUTSD 6	3	3
8	6A 1P 10kA C-Curve Techno MCB	HPL	NTSPC06	3	3
C	<b>OUTGOING MCCB 100A</b>	<b>MAKE</b>	<b>1</b>	<b>FEEDER QTY</b>	<b>1</b>
1	40A 4P 16kA MCCB, TA Release (Adj Thermal & Fixed Magnetic), Type : TAB1	HPL	TAB168DX040AC4P	1	1
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 20-100A TAB1 MCCB	HPL	TAB1100ST4P	1	1
D	<b>OUTGOING MCCB 40A</b>	<b>MAKE</b>	<b>1</b>	<b>FEEDER QTY</b>	<b>2</b>
1	40A 4P 16kA MCCB, TA Release (Adj Thermal & Fixed Magnetic), Type : TAB1	HPL	TAB168DX040AC4P	1	2
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 20-100A TAB1 MCCB	HPL	TAB1100ST4P	1	2
E	<b>OUTGOING MCB 63</b>	<b>MAKE</b>	<b>1</b>	<b>FEEDER QTY</b>	<b>6</b>
1	63A 1PN 10kA C-Curve Techno MCB	HPL	NTSPNC63	1	6
S.N.	<b>FABRICATION DETAILS</b>	<b>MAKE</b>	<b>TYPE/MATERIAL</b>	<b>QTY</b>	<b>UNIT</b>
1	FABRICATION : 3.15MM CRCA Sheet PRE TREATMENT: 7 TANK PROCESS PAINTING: POWDER COATED WITH SIEMENS GREY SHED (RAL 7032) TYPE: INDOOR TYPE, FREE FLOOR RESTING, FIX TYPE, SINGLE FRONT, COMPARTMENTLISED DESIGN, SINGLE DOOR CABLE ENTRY: TOP/BOTTOM (DETACHABLE GLAND PLATE UNDRILLED)	DVEPL	MS/CRCA	1	JOB
2	<b>BASE FRAME: 40X40X5MM &amp; 800MM</b>	DVEPL	ISMC	1	JOB
3	<b>BUSBAR: PH: 1x30x5, N: 1X30X5</b> Current Density: 1 Amp/Sq. mm Insulation: Color coded heat shrinkable Sleeves	DVEPL	Copper	1	JOB
4	<b>WIRING HARNESS (METERING STARTERS)</b>	DVEPL	CU- WIRE	1	LOT
5	<b>HARDWARE &amp; ACCESSORIES (LOCKS, GASKET, NUT BOLT ETC)</b>	DVEPL	NUT, BOLTS, LUGS ETC.	1	LOT
6	<b>LABOUR</b>	DVEPL		1	JOB
12	<b>SR NO 37</b>		<b>BOARD QTY</b>		
A	<b>INCOMER MCCB 63A</b>		<b>3</b>	<b>FEEDER QTY</b>	<b>1</b>
SR. NO.	<b>BOQDESCRIPTION</b>	<b>MAKE</b>	<b>CATALOG NUMBER</b>	<b>QTY</b>	<b>TOTAL QTY</b>
1	63A 4P 16kA MCCB, TA Release (Adj Thermal & Fixed Magnetic), Type : TAB1	HPL	TAB168DX063AC4P	1	3
2	Spreader Terminals (4 Pole - Set of 8 Nos.) for 20-100A TAB1 MCCB	HPL	TAB1100ST4P	1	3
B	<b>METERING</b>	<b>MAKE</b>	<b>3</b>	<b>FEEDER QTY</b>	<b>1</b>
1	Ammeter with Inbuilt selector switch, 3Ph, Acc. CL: 1, Aux Supply: 80-300V AC, Size: 96X96	L&T	WL1310100000	1	3
2	Voltmeter with Inbuilt selector switch, 3Ph, Acc. CL: 1, Aux Supply: 80-300V AC, Size: 96X96	L&T	WL1320100000	1	3
3	Red Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLR240A	1	3
4	Yellow Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLY240A	1	3
5	Blue Gen Next Pro LED Indicator 22.5 mm, Voltage: 240V AC	ESBEE	EPLB240A	1	3
6	32A Neutral Link, Color: Black/Khaki	FTC	FNL 32	3	9
7	100/5A 5VA Acc. CL: 1, ABS Insulated Bar Primary Ring Type Current Transformer, ID: 33mm	NIPPEN	NA	3	9
8	6 Sq.mm Disconnecting Terminal (Std. Color),Type: KUTSD 6	ELMEX	KUTSD 6	3	9
S.N.	<b>FABRICATION DETAILS</b>	<b>MAKE</b>	<b>TYPE/MATERIAL</b>	<b>QTY</b>	<b>UNIT</b>

## MANUFACTURERS OF LT CONTROL PANELS

**Regd. - Administrative Office :**  
Prabhu Niwas Building, Near Ranbir (Kalu) Petrol Pump,  
Dalhousie Road, Pathankot - 145001.  
Tel-Fax : +91 186 2231231

**Factory :**  
F03, F04, F21, Industrial Growth  
Centre, Pathankot - 145001  
Tel.: +91 92572 17609

**Sales Office**  
202 2nd Floor, Golden Square Building,  
Chandigarh, Amabala Highway Zirakpur.

M : +91 94170 21685, +91 94176 01244  
E : dvepl@yahoo.in, office@dvepl.com  
W : www.dvepl.com



# D.V. Electromatic (P) Ltd.



AN ISO 9001:2008 CERTIFIED CO.

1	PANEL ENCLOUSER : 750MM (W) x 750MM (H) x 400MM (D) FABRICATION : 3.15MM CRCA Sheet PRE TREATMENT: 7 TANK PROCESS PAINTING: POWDER COATED WITH SIEMENS GREY SHED (RAL 7032) TYPE: INDOOR TYPE, FREE FLOOR RESTING, FIX TYPE, SINGLE FRONT, COMPARTMENTLISED DESIGN, SINGLE DOOR CABLE ENTRY: TOP/BOTTOM (DETACHABLE GLAND PLATE UNDRILLED)	DVEPL	MS/CRCA	1	JOB
2	<b>BASE FRAME: 40X40X5MM &amp; 800MM</b>	DVEPL	ISMC	1	JOB
3	<b>BUSBAR: PH: 1x20x5, N: 1X20X5</b> Current Density: 1 Amp/Sq. mm Insulation: Color coded heat shrinkable Sleeves	DVEPL	Copper	1	JOB
4	<b>WIRING HARNESS (METERING STARTERS)</b>	DVEPL	CU- WIRE	1	LOT
5	<b>HARDWARE &amp; ACCESSORIES (LOCKS, GASKET, NUT BOLT ETC)</b>	DVEPL	NUT, BOLTS, LUGS ETC.	1	LOT
6	<b>LABOUR</b>	DVEPL		1	JOB

DVEPL

## MANUFACTURERS OF LT CONTROL PANELS

**Regd. - Administrative Office :**  
Prabhu Niwas Building, Near Ranbir (Kalu) Petrol Pump,  
Dalhousie Road, Pathankot - 145001.  
Tel-Fax | +91 186 2231231

**Factory :**  
F03, F04, F21, Industrial Growth  
Centre, Pathankot - 145001  
Tel.: +91 92572 17609

**Sales Office**  
202 2nd Floor, Golden Square Building,  
Chandigarh, Amabala Highway Zirakpur.

M | +91 94170 21685, +91 94176 01244  
E | dvepl@yahoo.in, office@dvepl.com  
W | www.dvepl.com





**ANNEXURE - III**

**PRICE SCHEDULE**

SR. NO.	DESCRIPTION OF ITEM	QTY	UNIT RATE (INR)	AMOUNT (INR)
1	SR NO 23	1	1,63,900.00	1,63,900.00
2	SR NO 24	1	68,600.00	68,600.00
3	SR NO 25	1	58,300.00	58,300.00
4	SR NO 26	1	64,500.00	64,500.00
5	SR NO 27	1	1,50,900.00	1,50,900.00
6	SR NO 28	1	73,200.00	73,200.00
7	SR NO 29	1	70,200.00	70,200.00
8	SR NO 30	1	1,25,700.00	1,25,700.00
9	SR NO 31	1	73,000.00	73,000.00
10	SR NO 32	1	73,600.00	73,600.00
11	SR NO 33	1	69,400.00	69,400.00
12	SR NO 37	3	31,833.33	95,500.00
<b>TOTAL QUANTITY</b>		<b>14</b>	<b>TOTAL COST (INR)</b>	<b>10,86,800.00</b>

**In words: Rupees Ten Lac Eighty Six Thousand Eight Hundred Only**

**NOTES:**

**MANUFACTURERS OF LT CONTROL PANELS**

**Regd. - Administrative Office :**  
Prabhu Niwas Building, Near Ranbir (Kalu) Petrol Pump,  
Dalhousie Road, Pathankot - 145001.  
Tel-Fax | +91 186 2231231

**Factory :**  
F03, F04, F21, Industrial Growth  
Centre, Pathankot - 145001  
Tel.: +91 92572 17609

**Sales Office**  
202 2nd Floor, Golden Square Building,  
Chandigarh, Amabala Highway Zirakpur.

M | +91 94170 21685, +91 94176 01244  
E | dvepl@yahoo.in, office@dvepl.com  
W | www.dvepl.com



**ANNEXURE – IV**

**COMMERCIAL TERMS AND CONDITIONS**

<b>PRICE:</b>	Ex works – IGC PATHANKOT (PB.)
<b>PACKING &amp; FORWARDING:</b>	Extra as per actual
<b>FREIGHT &amp; INSURANCE:</b>	Extra Freight & insurance.
<b>GST:</b>	18% or Actual As per Gst Taxation.
<b>OCTROI:</b>	Extra as applicable.
<b>PAYMENT TERMS:</b>	50% in advance with confirmed order and balance against Performa invoice before dispatch.
<b>ORDER PLACEMENT:</b>	<b>D.V. ELECTROMATIC PVT.LTD</b>
<b>DELIVERY:</b>	6-8 Weeks from the date of approval of drawings.
<b>VALIDITY</b>	Our offer is valid for 15 Days from the date of this offer and thereafter subject to our confirmation.
<b>WARRANTY:</b>	18 Months from the date of supply or 12 months from the commissioning whichever ends earlier.
<b>INSPECTION:</b>	On intimation, prior inspection of the panels, if required, may be carried out by the buyers authorized representative at our works at IGC - Pathankot (pb.)
<b>ORDER AMENDMENTS:</b>	Any change in specifications & other terms shall entail revision of delivery and prices including statutory variations.
<b>FORCE MAJEURE:</b>	We shall not be responsible for the failure or delay in order due to acts beyond our control such as war, fire, labour problems, accidents, natural calamities, government acts or shortage of material.
<b>COMMISSIONING CHARGES</b>	2500/Men days Testing, Commissioning and programming with Logging, fooding and boarding in Customer scope. Unloading, Fixing, Laying cables and Installation of panels at site are not in our scope.

**Our Bank Details:**

HDFC Bank  
DALHOUSIE ROAD, PATHANKOT-145001  
A/c # 50200012824476  
IFSC Code: HDFC0002459

**MANUFACTURERS OF LT CONTROL PANELS**

Regd. - Administrative Office :  
Prabhu Niwas Building, Near Ranbir (Kalu) Petrol Pump,  
Dalhousie Road, Pathankot - 145001.  
Tel-Fax | +91 186 2231231

Factory :  
F03, F04, F21, Industrial Growth  
Centre, Pathankot - 145001  
Tel.: +91 92572 17609

Sales Office  
202 2nd Floor, Golden Square Building,  
Chandigarh, Amabala Highway Zirakpur.

M | +91 94170 21685, +91 94176 01244  
E | dvepl@yahoo.in, office@dvepl.com  
W | www.dvepl.com