

Please quote your best price for our Jammu project with Jammu Power Distribution Corporation Ltd., Bhagthali Kathua. As per details given below.

S. No	DISCRIPTION OF MATERIAL
1	66KV 1- PHASE, 125X62.5/5-5-5 AMP. CURRENT TRANSFORMER OUTDOORTYPE ALONG WITH (1 O. JUNCTION BOX FOR 3 NO. CTs).
2	66KV, 1-PHASE 66KV/ROUTE 3 /110VOLT SINGLE CORE OUT DOOR TYPE POTENTIAL TRANSFORMER ALONG WITH JUNCTION BOX (1NO. JUNCTION BOX FOR 3NO.PTs)
3	CONTROL AND RELAY PANEL FOR 66X11KV POWER TRANSFORMER, INDOOR TYPE SCADA COMPATIBLE,REMOTE/MANUAL SWITCH ,ALONG WITH E/F AND OVER CURRENT RELAYS AND DIFFERENTIAL RELAYS (IEC 61850) VOLTMETER,AMMETER,ENERGYMETER-5A,DLMS COMPLAINT WITH RS -485PORT,ANNUNCIATION WINDOWS WITH ANNUNCIATION RELAYS AND OTHER COMPONENTS .
4	CONTROL AND RELAY PANEL FOR 66KV LINE,INDOOR TYPE SCADA COMPATIBLE,REMOTE/MANUAL SWITCH ,ALONG WITH E/F AND OVER CURRENT RELAYS AND VOLTMETER,AMMETER,ENERGYMETER- 5A,DLMS COMPLAINT WITH RS - 485PORT,ANNUNCIATION WINDOWS WITH ANNUNCIATION RELAYS AND OTHER COMPONENTS .
5	11KV VCB PANEL SETS, (INCOMER ,1600A, 25KA, 750/375/5-5A AND OUTGOING 12KV,1250A,25KA, 400/200/5-5 A WITH VACCUM CIRCUIT BREAKER AND CONTROL PANEL INCLUDING CAST RESIN CT,PT,E/F AND O/C RELAYS (IEC61850) MIMIC DIAGRAM ,VOLTMETER,3-PHASE TRIVECTOR METER - 5A,DLMS COMPLAINT WITH RS 485 PORT, ANNUNCIATION WINDOWS WITH ANNUNCIATION RELAYS AND OTHER ACCESSORIES (1 + 5 i.e 1 INCOMER AND 5 OUTGOING ).

Regd. Office : 569/100 A, Barigawan, Power House Road, Lucknow-226012(U.P.)  
 Corporate Office : A-41, Hiralal Nagar, Near Dixit Sweet House, Sarojani Nagar Lucknow-226008(U.P.)  
 Contact : Phone:+91-0522-4105001/+91-8800713001, Email: transco@alliancecorp.co.in

## ALLIANCE TRANSCON PVT. LTD.

6	11KV VCB PANEL ,1250A,25KA, 400/200/5-5 A WITH VACCUM CIRCUIT BREAKER AND CONTROL PANEL INCLUDING CAST RESIN CT,PT,E/F AND O/C RELAYS (IEC61850) MIMIC DIAGRAM ,VOLTMETER,3-PHASE TRIVECTOR METER - 5A,DLMS COMPLAINT WITH RS 485 PORT, ANNUNCIATION WINDOWS WITH ANNUNCIATION RELAYS AND OTHER ACCESSORIES (FOR CAPACITOR BANK).
7	MCCB - 200A BOX.
8	BATTERY CHARGER 30 VOLTS, 200AH FLOAT CUM BOOST WITH FULL WAVE RECTIFICATION FOR 220V ,1-PHASE ,50HZ AC INPUT
9	415 VOLTS AC DISTRIBUTION BOARD MADE OF CRCA THICKNESS NOT LESS THAN 2MM ,POWDER COATED DEGREE OF PROTECTION IP43 ALONG WITH VOLTMETER , AMMETER AND SELECTOR SWITCHS , 200A FUSE DISCONNECTOR FOR INCOMING SUPPLY AND 5 NO. TPN MCB (16-125A) AND 5 NO.s DPMCB (0-32A), RECTANGULAR BUS BAR SUITABLE FOR 200A CONTINUOUS SUPPLY INCLUDING INDICATION LAMPS.
10	DISTRIBUTION PANEL (30V, DC) MADE OF CRCA THICKNESS NOT LESS THAN 2MM. POWDER COATED DEGREE OF PROTECTION FOR IP43 FOR 2 NO.s BATTERY INCOMING SUPPLY WITH 2 NO.s 63A ,DP MCBFOR INCOMING SUPPLY DOUBLE BUS BAR OF ADEQUATE SIZE ,12 NO.DP DC MCBs (0 TO 32A ) INCLUDING INDICATION LAMPS.
11.	Protective relay over current + earth fault type SCADA compatible
12	11Kv PT Set indoor type for 11kV VCB Panels
13.	11kV CT Set indoor type for 11kV VCB Panels

Kindly provide complete details of delivery schedule, payment terms and any other terms and conditions.

Please feel free to call us if you need any further information.

In case of any queries, you may directly contact Mr. J. S. Rathore (Vice President), Mobile No. 9419188014, 7006489160.

Thanks and Regards,

Your Faithfully

Alliance Transcon Pvt. Ltd.

  
 Ashish Singh  
 Director