

Bid Document/ बिड दस्तावेज़

Bid Details/बिड विवरण	
Bid End Date/Time/बिड बंद होने की तारीख/समय	23-05-2025 18:00:00
Bid Opening Date/Time/बिड खुलने की तारीख/समय	23-05-2025 18:30:00
Bid Offer Validity (From End Date)/बिड पेशकश वैधता (बंद होने की तारीख से)	150 (Days)
Ministry/State Name/मंत्रालय/राज्य का नाम	Ministry Of Defence
Department Name/विभाग का नाम	Department Of Military Affairs
Organisation Name/संगठन का नाम	Indian Army
Office Name/कार्यालय का नाम	*****
क्रेता ईमेल/Buyer Email	bhmahendra225-cgo@gov.in
Total Quantity/कुल मात्रा	5484
Item Category/मद केटगरी	LED Batten (Q2) , XLPE Cable for Working Voltages up to and Including 1.1 KV as per IS 7098 (Part 1) (Q2) , Self Ballasted LED Lamps for General Lighting Services (V2) Conforming to IS 16102 (Q2) , Molded Case Circuit Breakers (MCCB) as per IS / IEC 60947 (Q3) , MCB - Miniature Circuit - Breakers for A.C. Operation as per IS / IEC 60898 (Part 1) (Q2) , LED Tube Light (Retrofit Type) (Q2) , LED Garden Light (V2) (Q2) , Piano Type Non Modular Domestic Electrical sockets - IS 1293 (Q3) , Non - Modular Piano Type Domestic Electrical Switches as per IS 3854 (Q3) , Piano Type Non Modular Electrical Switch Socket Combination as per IS 3854 and IS 1293 (Q3) , Piano Type Non Modular Domestic Fan Regulator as per IS 11037 (Q3) , Electrical Plugs (V2) ISI Marked to IS 1293 (Q2) , Ceiling rose - IS 371 (Q3) , Elecric Bells and Accessories as per IS 2268 (Q3)
Years of Past Experience Required for same/similar service/उन्हीं/समान सेवाओं के लिए अपेक्षित विगत अनुभव के वर्ष	3 Year (s)
MSE Exemption for Years of Experience and Turnover/ अनुभव के वर्षों से एमएसई छूट	No
Startup Exemption for Years of Experience and Turnover/ अनुभव के वर्षों से स्टार्टअप छूट	No

Bid Details/बिड विवरण	
Document required from seller/विक्रेता से मांगे गए दस्तावेज़	Experience Criteria,Past Performance,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,OEM Annual Turnover,Additional Doc 1 (Requested in ATC),Additional Doc 2 (Requested in ATC),Additional Doc 3 (Requested in ATC),Additional Doc 4 (Requested in ATC),Compliance of BoQ specification and supporting document *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Do you want to show documents uploaded by bidders to all bidders participated in bid?/	No
Past Performance/विगत प्रदर्शन	80 %
Bid to RA enabled/बिड से रिवर्स नीलामी सक्रिय किया	Yes
RA Qualification Rule	50% Lowest Priced Technically Qualified Bidders
Type of Bid/बिड का प्रकार	Two Packet Bid
Primary product category	XLPE Cable for Working Voltages up to and Including 1.1 KV as per IS 7098 (Part 1)
Time allowed for Technical Clarifications during technical evaluation/तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय	2 Days
Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
Evaluation Method/मूल्यांकन पद्धति	Total value wise evaluation
Arbitration Clause	No
Mediation Clause	No

EMD Detail/ईएमडी विवरण

Advisory Bank/एडवाइजरी बैंक	State Bank of India
EMD Amount/ईएमडी राशि	78638

ePBG Detail/ईपीबीजी विवरण

Advisory Bank/एडवाइजरी बैंक	State Bank of India
ePBG Percentage(%) /ईपीबीजी प्रतिशत (%)	0.01
Duration of ePBG required (Months)/ईपीबीजी की अपेक्षित अवधि (महीने).	12

(a). EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy./जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित केटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज़ प्रस्तुत करने हैं। एमएसई केटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।

(b). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable./ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए।

Beneficiary/लाभार्थी :

SBSO CWE JRC

HQ CWE JALANDHAR ZONE, Department of Military Affairs, Indian Army, Ministry of Defence

(B.h. Mahendra Kumar)

MII Purchase Preference/एमआईआई खरीद वरीयता

MII Purchase Preference/एमआईआई खरीद वरीयता	Yes
--	-----

MSE Purchase Preference/एमएसई खरीद वरीयता

MSE Purchase Preference/एमएसई खरीद वरीयता	Yes
---	-----

1. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM of the product offered in the bid {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts and delivery acceptance certificates like CRAC to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

2. Preference to Make In India products (For bids < 200 Crore):Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate .The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023.

[OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.

3. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in

this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

4. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

5. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 80% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

6. Reverse Auction would be conducted amongst first 50% of the technically qualified bidders arranged in the order of prices from lowest to highest. Number of sellers eligible for participating in RA would be rounded off to next higher integer value if number of technically qualified bidders is odd (e.g. if 7 bids are technically qualified, then RA will be conducted amongst L-1 to L-4). In case number of technically qualified bidders are 2 or 3, RA will be between all without any elimination. If Buyer has chosen to split the bid amongst N sellers, then minimum N sellers would be taken to RA round. In case Primary products of only one OEM are left in contention for participation in RA based on lowest 50% bidders qualifying for RA, the number of sellers qualifying for RA would be increased to get at least products of one more OEM (directly participated or through its reseller) if available. Further, if bid(s) of any seller(s) eligible for MSE preference is / are coming within price band of 15% of Non MSE L-1 or if bid of any seller(s) eligible for Make in India preference is / are coming within price band of 20% of non MII L-1, then such MSE / Make in India seller shall also be allowed to participate in the RA process.

LED Batten (364 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/कमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	LED Batten Rating (in Watts)	20.0
	Length of LED Batten (Nominal) (in mm)	1150.0
	Lamp Efficacy (Lumen / Watt), Minimum	100, 110 Or higher
	Warranty for free replacement (in Years)	1, 2, 3 Or higher
CONSTRUCTIONAL	Housing Material	Polycarbonate

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	364	15

XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (51 meter)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No
	Cables suitable for use in low temperature applications	No
GENERIC	Classification of cables for improved fire performance category	01
	Nominal Area of Conductor (in Sq mm)	185
	Number of core (in Nos)	3.5
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized round steel wire
	Type of armouring	Single wire
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	51	15

XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (64 meter)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No
	Cables suitable for use in low temperature applications	No
GENERIC	Classification of cables for improved fire performance category	C1 - FR
	Nominal Area of Conductor (in Sq mm)	120
	Number of core (in Nos)	3.5
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized round steel wire
	Type of armouring	Single strip
CERTIFICATION	Availability of Optional Test Reports	Not applicable

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	64	15

Self Ballasted LED Lamps For General Lighting Services (V2) Conforming To IS 16102 (194 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
RATING	Rated wattage of LED lamp (in Watts)	9
	Star Rating of LED Lamp	1 Star
	Rated luminous efficacy (Lumen/Watt)	? 90 and < 105
	Colour Temperature, CCT (in K)	6500
	Type of LED Lamp Cap	B 22 d
CONSTRUCTION	Warranty for free replacement (in months)	12, 24, 36 Or higher

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	194	15

Self Ballasted LED Lamps For General Lighting Services (V2) Conforming To IS 16102 (

132 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
RATING	Rated wattage of LED lamp (in Watts)	12
	Star Rating of LED Lamp	1 Star
	Rated luminous efficacy (Lumen/Watt)	? 90 and < 105
	Colour Temperature, CCT (in K)	6500
	Type of LED Lamp Cap	B 22 d
CONSTRUCTION	Warranty for free replacement (in months)	12, 24, 36 Or higher

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	132	15

Self Ballasted LED Lamps For General Lighting Services (V2) Conforming To IS 16102 (159 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
RATING	Rated wattage of LED lamp (in Watts)	5

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Star Rating of LED Lamp	1 Star
	Rated luminous efficacy (Lumen/Watt)	? 90 and < 105
	Colour Temperature, CCT (in K)	6500
	Type of LED Lamp Cap	B 22 d
CONSTRUCTION	Warranty for free replacement (in months)	12, 24, 36 Or higher

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	159	15

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (2 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	ISI marked	NO
	Rated Current (in Ampere)	100A
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35/50/65 KA tripping range
	Breaking current (in KA)	16 KA
	Rated Voltage	240/415 Volt 50 Hz AC

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	2	15

LED Batten (55 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	LED Batten Rating (in Watts)	20.0
	Length of LED Batten (Nominal) (in mm)	1150.0
	Lamp Efficacy (Lumen / Watt), Minimum	100, 110 Or higher
	Warranty for free replacement (in Years)	2, 3 Or higher
CONSTRUCTIONAL	Housing Material	Polycarbonate

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	55	15

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (37 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	2 P with 1 PP
	Rated voltage (in Volts)	240 / 415 V, AC
	Rated Current (in Ampere)	32
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	37	15

XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (51 meter)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No
	Cables suitable for use in low temperature applications	Yes
GENERIC	Classification of cables for improved fire performance category	01
	Nominal Area of Conductor (in Sq mm)	70
	Number of core (in Nos)	3.5
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Aluminium flat strip
	Type of armouring	Single strip
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	51	15

XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (47 meter)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No
	Cables suitable for use in low temperature applications	No
GENERIC	Classification of cables for improved fire performance category	C1 - FR
	Nominal Area of Conductor (in Sq mm)	150
	Number of core (in Nos)	3.5
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized steel formed wire
	Type of armouring	Single wire
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	47	15

Self Ballasted LED Lamps For General Lighting Services (V2) Conforming To IS 16102 (90 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
RATING	Rated wattage of LED lamp (in Watts)	6
	Star Rating of LED Lamp	2 Star
	Rated luminous efficacy (Lumen/Watt)	? 105 and < 120
	Colour Temperature, CCT (in K)	6500
	Type of LED Lamp Cap	B 22 d
CONSTRUCTION	Warranty for free replacement (in months)	12, 24, 36 Or higher

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	90	15

XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (355 meter)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No
	Cables suitable for use in low temperature applications	No

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	Classification of cables for improved fire performance category	C2 - FR-LSH
	Nominal Area of Conductor (in Sq mm)	10
	Number of core (in Nos)	2
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized steel formed wire
	Type of armouring	Single wire
CERTIFICATION	Availability of Optional Test Reports	Not applicable

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	355	15

XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (74 meter)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Cables suitable for use in low temperature applications	No
GENERIC	Classification of cables for improved fire performance category	01
	Nominal Area of Conductor (in Sq mm)	95
	Number of core (in Nos)	3.5
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized steel formed wire
	Type of armouring	Single wire
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	74	15

LED Tube Light (Retrofit Type) (101 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	LED Tube light Rating (in Watts)	20.0

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Length of LED tube light (Nominal) (in feet)	4.0
	Lamp Efficacy (Lumen / Watt), Minimum	100
	Warranty for free replacement (Years)	1
CONSTRUCTIONAL	Type of Tube Light	T-5
	Cap designation	G5
	Type of Driver	Inbuilt (for T5)
	Lamp Shell material	Polycarbonate Or higher

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	101	15

XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (560 meter)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No
	Cables suitable for use in low temperature applications	No

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	Classification of cables for improved fire performance category	C2 - FR-LSH
	Nominal Area of Conductor (in Sq mm)	6
	Number of core (in Nos)	2
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized steel formed wire
	Type of armouring	Single wire
CERTIFICATION	Availability of Optional Test Reports	Not applicable

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	560	15

XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (297 meter)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	Yes

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Cables suitable for use in low temperature applications	Yes
GENERIC	Classification of cables for improved fire performance category	01
	Nominal Area of Conductor (in Sq mm)	25
	Number of core (in Nos)	3.5
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Aluminium flat strip
	Type of armouring	Double strip
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	297	15

XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (244 meter)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
---------------	------------------------------------	--

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No
	Cables suitable for use in low temperature applications	No
GENERIC	Classification of cables for improved fire performance category	C2 - FR-LSH
	Nominal Area of Conductor (in Sq mm)	35
	Number of core (in Nos)	3.5
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Aluminium flat strip
	Type of armouring	Single strip
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	244	15

LED Tube Light (Retrofit Type) (79 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* जेम कटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	LED Tube light Rating (in Watts)	18.0
	Length of LED tube light (Nominal) (in feet)	4.0
	Lamp Efficacy (Lumen / Watt), Minimum	120
	Warranty for free replacement (Years)	2
CONSTRUCTIONAL	Type of Tube Light	T-5
	Cap designation	G5
	Type of Driver	Without any driver (for T5)
	Lamp Shell material	Polycarbonate Or higher

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	79	15

XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (158 meter)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Cables suitable for use in low temperature applications	No
GENERIC	Classification of cables for improved fire performance category	C2 - FR-LSH
	Nominal Area of Conductor (in Sq mm)	50
	Number of core (in Nos)	3.5
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized round steel wire
	Type of armouring	Single wire
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	158	15

LED Garden Light (V2) (9 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	Type of Garden Light	LED post top lantern/luminaire with pole

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Material of Garden Lighting pole including lighting system (lantern/luminaire) (Note: Wherever GI, MS, CI materials used, materials shall be ISI Marked)	Aluminium casting
	Pole height including lantern/luminaire (in m)	3
	No. of lantern/luminaire with each pole (in m)	1
LIGHT SOURCE	Type of light source - BEE star rating of LED Bulb	SMD LED Chip
	LED Rating in each lantern/luminaire/lighting system (in Watts)	15.0
	LED Lamp/System efficacy in each lantern / luminaire (in lumen / watt)	? 105 and < 120
	In case of LED bulb - Cap designation of each lamp and holder in each lantern / luminaire	Not applicable (for SMP LED Chip)
PROTECTION	Automatic Lower / Higher Cut off voltage	Yes. Lower cut off 120 V, Higher cut off 300 V
	Protection against surges and transients - External	> / = 10 KV Or higher
THERMAL MANAGEMENT	Minimum Operating Temperature (in deg. C)	-10
	Maximum Operating Temperature (in deg. C)	55
LANTERN/LUMINAIRE - CONSTRUCTION	Impact resistance on diffuser material (in IK)	0
	Protection of the entire housing (in IP) Protection of the entire housing as per IS:10322 (Part 1):1982 latest	65
	Length of ISI marked three core connecting wire (Provided along with each lantern/luminaire) - (in m)	0.5
CERTIFICATIONS	Warranty for free replacement of lighting systems including lightsource (in years)	1

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
ADVANCE SAMPLE	Agreed to provide Advance Sample(s) for buyer's approval before commencement of supply. (hint: Applicable in case of orders placed against bid and not applicable in case of Direct Buying)	Yes

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	9	15

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (2 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	ISI marked	NO
	Rated Current (in Ampere)	200A
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35/50/65 KA tripping range
	Breaking current (in KA)	25 KA
	Rated Voltage	240 Volt 50 Hz AC

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	2	15

Piano Type Non Modular Domestic Electrical Sockets - IS 1293 (544 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
Performance Parameters	Rated Current	6.0 (Ampère)
Generic	Socket type based on existence of shutter	Without Shutter
	Current Carrying Material	Copper
	According to type of Terminal	Screw Type Terminal
	Number of Modules	1
	Number of Poles	3
	Number of Pins	3
	Warranty	1.0 (year)

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	544	15

Piano Type Non Modular Domestic Electrical Sockets - IS 1293 (213 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
Performance Parameters	Rated Current	16.0 (Ampère)
Generic	Socket type based on existence of shutter	Without Shutter
	Current Carrying Material	Brass
	According to type of Terminal	Screwless Type Terminal
	Number of Modules	2
	Number of Poles	2
	Number of Pins	3
	Warranty	1.0 (year)

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	213	15

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (1 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	ISI marked	NO
	Rated Current (in Ampere)	320A

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity 10/16 KA tripping range
	Breaking current (in KA)	35 KA
	Rated Voltage	240/415 Volt 50 Hz AC

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	1	15

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (52 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	2 P with 1 PP
	Rated voltage (in Volts)	240 V, AC
	Rated Current (in Ampere)	40
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	52	15

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (8 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	ISI marked	NO
	Rated Current (in Ampere)	63A
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity 10/16 KA tripping range
	Breaking current (in KA)	16 KA
	Rated Voltage	240 Volt 50 Hz AC

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	8	15

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (2 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	ISI marked	NO
	Rated Current (in Ampere)	400A
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35 KA tripping range
	Breaking current (in KA)	50 KA
	Rated Voltage	240/415 Volt 50 Hz AC

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	2	15

XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (108 meter)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No
	Cables suitable for use in low temperature applications	No
GENERIC	Classification of cables for improved fire performance category	01
	Nominal Area of Conductor (in Sq mm)	16
	Number of core (in Nos)	2
CONSTRUCTION	Material of conductor	Plain Copper
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized steel formed wire
	Type of armouring	Single strip
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	108	15

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (54 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	1 P
	Rated voltage (in Volts)	240 / 415 V, AC
	Rated Current (in Ampere)	40
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	54	15

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (1 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	ISI marked	NO
	Rated Current (in Ampere)	160A
	No of poles/Protected poles(PP)	4 Pole

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35 KA tripping range
	Breaking current (in KA)	16 KA
	Rated Voltage	415 volt 50 Hz

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	1	15

XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (248 meter)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No
	Cables suitable for use in low temperature applications	Yes
GENERIC	Classification of cables for improved fire performance category	01
	Nominal Area of Conductor (in Sq mm)	240
	Number of core (in Nos)	3.5
CONSTRUCTION	Material of conductor	Aluminium

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized round steel wire
	Type of armouring	Single strip
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	248	15

Non - Modular Piano Type Domestic Electrical Switches As Per IS 3854 (171 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
Generic	Rated current	16A
	Nature of Switch	1 way switch
	Rated voltage	230.0 (Volt)
Switch classification	According to type of terminal	Screw type terminal
	No. of poles	Single pole
	According to type	surface type
Construction	Current carrying material	Brass
	Color of switch body	White

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
Certification & standards	Warranty	2.0 (year)

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	171	15

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (2 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	ISI marked	NO
	Rated Current (in Ampere)	200A
	No of poles/Protected poles(PP)	3 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity 10/16 KA tripping range
	Breaking current (in KA)	16 KA
	Rated Voltage	240/415 Volt 50 Hz AC

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	2	15

Piano Type Non Modular Electrical Switch Socket Combination As Per IS 3854 And IS 1293 (72 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
Generic	Rated current	16A
	Rated voltage	250.0 (Volt)
	Combination with Junction Box	Without Box
Construction	According to type of terminal	Screwless type terminal
	Current carrying material	Brass
	Color of switch body	White
Certification & standards	Warranty	2.0 (year)

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	72	15

LED Batten (27 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	LED Batten Rating (in Watts)	10.0
	Length of LED Batten (Nominal) (in mm)	560.0
	Lamp Efficacy (Lumen / Watt), Minimum	110 Or higher
	Warranty for free replacement (in Years)	2, 3 Or higher
CONSTRUCTIONAL	Housing Material	Polycarbonate

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	27	15

Non - Modular Piano Type Domestic Electrical Switches As Per IS 3854 (438 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
Generic	Rated current	6A
	Nature of Switch	1 way switch
	Rated voltage	250.0 (Volt)
Switch classification	According to type of terminal	Screwless type terminal
	No. of poles	Single pole
	According to type	surface type

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
Construction	Current carrying material	Brass
	Color of switch body	White
Certification & standards	Warranty	1.0 (year)

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	438	15

LED Garden Light (V2) (5 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	Type of Garden Light	Bollard type with Pole and LED lantern/luminaire, Architectural design with pole and LED lantern/luminaire, LED post top lantern/luminaire with pole
	Material of Garden Lighting pole including lighting system (lantern/luminaire) (Note: Wherever GI, MS, CI materials used, materials shall be ISI Marked)	Aluminium casting, Galvanised Iron, Mild steel, Cast iron, LED post top with out pole. Hence not applicable
	Pole height including lantern/luminaire (in m)	0.5, 1, 1.5, 3, 4, 5, 6, 7, 8, without pole
	No.of lantern/luminaire with each pole (in m)	1, 2, 3, 4, 5, LED post top with out pole. Hence not applicable
LIGHT SOURCE	Type of light source - BEE star rating of LED Bulb	SMD LED Chip

Specification	Specification Name/विशिष्ट का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	LED Rating in each lantern/luminaire/lighting system (in Watts)	25.0
	LED Lamp/System efficacy in each lantern / luminaire (in lumen / watt)	? 105 and < 120
	In case of LED bulb - Cap designation of each lamp and holder in each lantern / luminaire	Not applicable (for SMP LED Chip)
PROTECTION	Automatic Lower / Higher Cut off voltage	Yes. Lower cut off 120 V, Higher cut off 300 V
	Protection against surges and transients - External	> / = 10 KV, No Or higher
THERMAL MANAGEMENT	Minimum Operating Temperature (in deg. C)	-10
	Maximum Operating Temperature (in deg. C)	50
LANTERN/LUMINAIRE - CONSTRUCTION	Impact resistance on diffuser material (in IK)	7
	Protection of the entire housing (in IP) Protection of the entire housing as per IS:10322 (Part 1):1982 latest	65
	Length of ISI marked three core connecting wire (Provided along with each lantern/luminaire) - (in m)	1
CERTIFICATIONS	Warranty for free replacement of lighting systems including lightsource (in years)	2
ADVANCE SAMPLE	Agreed to provide Advance Sample(s) for buyer's approval before commencement of supply. (hint: Applicable in case of orders placed against bid and not applicable in case of Direct Buying)	Yes

Consignees/Reporting Officer/परेषित/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	5	15

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (4 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	3 P with 3 PP
	Rated voltage (in Volts)	240 V, AC
	Rated Current (in Ampere)	40
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	4	15

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (88 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	1 P
	Rated voltage (in Volts)	240 / 415 V, AC
	Rated Current (in Ampere)	20
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	88	15

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (46 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	1 P
	Rated voltage (in Volts)	240 V, AC
	Rated Current (in Ampere)	16
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	46	15

Piano Type Non Modular Domestic Fan Regulator As Per IS 11037 (36 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
Generic	BIS Marking	Yes
	Rated voltage	230.0 (Volt)
	Type of Regulator	socket size
	No of steps	5

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
Construction	Color of regulator body	Off-white
Certification & standards	Test report to be submitted to the Buyer on Demand	Yes

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	36	15

Electrical Plugs (V2) ISI Marked To IS 1293 (90 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
CONSTRUCTION	Number of poles	2 Pole + Earth
	Rated Current (in A)	16 A
	Number of Pins	3
	Plug Classification	For Class 1 Appliances

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	90	15

LED Tube Light (Retrofit Type) (11 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	LED Tube light Rating (in Watts)	20.0
	Length of LED tube light (Nominal) (in feet)	4.0
	Lamp Efficacy (Lumen / Watt), Minimum	120
	Warranty for free replacement (Years)	1
CONSTRUCTIONAL	Type of Tube Light	T-8
	Cap designation	G13
	Type of Driver	Inbuilt (for T8)
	Lamp Shell material	Polycarbonate Or higher

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	11	15

Ceiling Rose - IS 371 (26 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
Certification & standards	Warranty	1.0 (year)
	Product BIS Marked	No
Construction	Current carrying material	Copper
	No of Plate	3 plate

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	26	15

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (22 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	1 P
	Rated voltage (in Volts)	240 V, AC
	Rated Current (in Ampere)	25
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	22	15

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (21 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	1 P
	Rated voltage (in Volts)	415 V, AC
	Rated Current (in Ampere)	10
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	21	15

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (3 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	1 P
	Rated voltage (in Volts)	240 / 415 V, AC
	Rated Current (in Ampere)	63
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	3	15

Electrical Plugs (V2) ISI Marked To IS 1293 (24 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
CONSTRUCTION	Number of poles	2 Pole + Earth
	Rated Current (in A)	6 A
	Number of Pins	3
	Plug Classification	For Class 1 Appliances

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	24	15

Electric Bells And Accessories As Per IS 2268 (9 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	Product ISI marked	NO - But conforming to IS:2268

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Type of bell	Ding Dong type

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	9	15

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (4 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	1 P
	Rated voltage (in Volts)	415 V, AC
	Rated Current (in Ampere)	6
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	4	15

Non - Modular Piano Type Domestic Electrical Switches As Per IS 3854 (18 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
Generic	Rated current	6A
	Nature of Switch	bell push switch
	Rated voltage	230.0 (Volt)
Switch classification	According to type of terminal	Screw type terminal
	No. of poles	Single pole
	According to type	surface type
Construction	Current carrying material	Copper
	Color of switch body	White
Certification & standards	Warranty	1.0 (year)

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	18	15

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (3

pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	2 P with 1 PP
	Rated voltage (in Volts)	240 / 415 V, AC
	Rated Current (in Ampere)	63
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	3	15

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (2 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	2 P with 1 PP
	Rated voltage (in Volts)	230 / 415 V, AC
	Rated Current (in Ampere)	16
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	2	15

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (2 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	2 P with 1 PP
	Rated voltage (in Volts)	240 V, AC

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Rated Current (in Ampere)	25
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	2	15

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (2 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	2 P with 1 PP
	Rated voltage (in Volts)	415 V, AC
	Rated Current (in Ampere)	10
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	2	15

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (2 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	1 P
	Rated voltage (in Volts)	415 V, AC
	Rated Current (in Ampere)	32
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Yes with 1.2 mm thick

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Jalandhar	2	15

Buyer Added Bid Specific Terms and Conditions/क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें**1. Generic**

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$, subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

2. Generic

Bidder shall submit the following documents along with their bid for Vendor Code Creation:

- Copy of PAN Card.
- Copy of GSTIN.
- Copy of Cancelled Cheque.
- Copy of EFT Mandate duly certified by Bank.

3. Generic

Experience Criteria: The Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for 3 years before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the year. In case of bunch bids, the primary product having highest value should meet this criterion.

4. Scope of Supply

Scope of supply (Bid price to include all cost components) : Only supply of Goods

5. Turnover

Bidder Turn Over Criteria: The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the

relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

6. **Turnover**

OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria. In case of bunch bids, the OEM of CATEGORY RELATED TO primary product having highest bid value should meet this criterion.

7. **Certificates**

Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.

8. **Certificates**

ISO 9001: The bidder or the OEM of the offered products must have ISO 9001 certification.

9. **Certificates**

Material Test Certificate Should Be Sent Along with The Supply. The Material Will Be Checked by Buyer's Lab & the Results of the Lab will be the Sole Criteria for Acceptance of the Item.

10. **Certificates**

The bidder is required to upload, along with the bid, all relevant certificates such as BIS licence, type test certificate, approval certificates and other certificates as prescribed in the Product Specification given in the bid document.

11. **Past Project Experience**

Proof for Past Experience and Project Experience clause: For fulfilling the experience criteria any one of the following documents may be considered as valid proof for meeting the experience criteria: a. Contract copy along with Invoice(s) with self-certification by the bidder that service/supplies against the invoices have been executed. b. Execution certificate by client with contract value. c. Any other document in support of contract execution like Third Party Inspection release note, etc. **Proof for Past Experience and Project Experience clause:** For fulfilling the experience criteria any one of the following documents may be considered as valid proof for meeting the experience criteria: a. Contract copy along with Invoice(s) with self-certification by the bidder that service/supplies against the invoices have been executed. b. Execution certificate by client with contract value. c. Any other document in support of contract execution like Third Party Inspection release note, etc.

12. **Past Project Experience**

The Bidder / OEM {themselves or through reseller(s)}, should have executed project for supply and installation / commissioning of same or similar Category Products during preceding 3 financial years (i.e. current year and three previous financial years) as on opening of bid, as per following criteria:

- (i) Single order of at least 35% of estimated bid value; or
- (ii) Two orders of at least 20% each of estimated bid value; or
- (iii) Three orders of at least 15% each of estimated bid value.

Satisfactory Performance certificate issued by respective Buyer Organization for the above Orders should be uploaded with bid. In case of bunch bids, the Category related to primary product having highest bid value should meet this criterion

13. **Buyer Added Bid Specific ATC**

Disclaimer/अस्वीकरण

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers / Service Providers are mandated to ensure compliance with all the applicable laws / acts / rules including but not limited to all Labour Laws such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972 etc. Any non-compliance will be treated as breach of contract and Buyer may take suitable actions as per GeM Contract.

[This Bid is also governed by the General Terms and Conditions/ यह बिड सामान्य शर्तों के अंतर्गत भी शासित है](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws./जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।

---Thank You/धन्यवाद---