

Bid Document/ बिड दस्तावेज़

Bid Details/बिड विवरण	
Bid End Date/Time/बिड बंद होने की तारीख/समय	30-05-2025 12:00:00
Bid Opening Date/Time/बिड खुलने की तारीख/समय	30-05-2025 12:30:00
Bid Offer Validity (From End Date)/बिड पेशकश वैधता (बंद होने की तारीख से)	45 (Days)
Ministry/State Name/मंत्रालय/राज्य का नाम	Ministry Of Defence
Department Name/विभाग का नाम	Department Of Military Affairs
Organisation Name/संगठन का नाम	Indian Army
Office Name/कार्यालय का नाम	*****
क्रेता ईमेल/Buyer Email	twangyal.424w@gov.in
Total Quantity/कुल मात्रा	2272
Item Category/मद केटेगरी	XLPE Cable for Working Voltages up to and Including 1.1 KV as per IS 7098 (Part 1) (Q2) , Molded Case Circuit Breakers (MCCB) as per IS / IEC 60947 (Q3) , MCB - Miniature Circuit Breakers for A.C. Operation as per IS / IEC 60898 (Part 1) (Q2) , Miniature Circuit Breakers Distribution Boards as per IS 13032 (Q3)
Minimum Average Annual Turnover of the bidder (For 3 Years)/बिडर का न्यूनतम औसत वार्षिक टर्नओवर (3 वर्षों का)	5 Lakh (s)
Years of Past Experience Required for same/similar service/उन्हीं/समान सेवाओं के लिए अपेक्षित विगत अनुभव के वर्ष	2 Year (s)
MSE Exemption for Years Of Experience/अनुभव के वर्षों से एमएसई छूट/ and Turnover/टर्नओवर के लिए एमएसई को छूट प्राप्त है	Yes
Startup Exemption for Years Of Experience/अनुभव के वर्षों से स्टार्टअप छूट/ and Turnover/ टर्नओवर के लिए स्टार्टअप को छूट प्राप्त है	Yes

Bid Details/बिड विवरण	
Document required from seller/विक्रेता से मांगे गए दस्तावेज़	Experience Criteria,Past Performance,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,Additional Doc 1 (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Do you want to show documents uploaded by bidders to all bidders participated in bid?/	No
Past Performance/विगत प्रदर्शन	30 %
Bid to RA enabled/बिड से रिवर्स नीलामी सक्रिय किया	Yes
RA Qualification Rule	H1-Highest Priced Bid Elimination
Type of Bid/बिड का प्रकार	Two Packet Bid
Primary product category	Molded Case Circuit Breakers (MCCB) as per IS / IEC 60947
Time allowed for Technical Clarifications during technical evaluation/तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय	2 Days
Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
Evaluation Method/मूल्यांकन पद्धति	Total value wise evaluation
Arbitration Clause	No
Mediation Clause	No

EMD Detail/ईएमडी विवरण

Advisory Bank/एडवाइजरी बैंक	State Bank of India
EMD Amount/ईएमडी राशि	40000

ePBG Detail/ईपीबीजी विवरण

Advisory Bank/एडवाइजरी बैंक	State Bank of India
ePBG Percentage(%) / ईपीबीजी प्रतिशत (%)	3.00
Duration of ePBG required (Months)/ईपीबीजी की अपेक्षित अवधि (महीने).	15

(a). EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this

Policy./जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित केटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज़ प्रस्तुत करने हैं। एमएसई केटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।

(b). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable./ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए।

Beneficiary/लाभार्थी :

cwe

Commander Works Engineer (army) Mumbai, Department of Military Affairs, Indian Army, Ministry of Defence (Cwe)

MII Purchase Preference/एमआईआई खरीद वरीयता

MII Purchase Preference/एमआईआई खरीद वरीयता	Yes
--	-----

MSE Purchase Preference/एमएसई खरीद वरीयता

MSE Purchase Preference/एमएसई खरीद वरीयता	Yes
---	-----

1. If the bidder is a Micro or Small Enterprise as per latest definitions under MSME rules, the bidder shall be exempted from the requirement of "Bidder Turnover" criteria and "Experience Criteria" subject to meeting of quality and technical specifications. If the bidder is OEM of the offered products, it would be exempted from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. In case any bidder is seeking exemption from Turnover / Experience Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer.
2. If the bidder is a Startup, the bidder shall be exempted from the requirement of "Bidder Turnover" criteria and "Experience Criteria" subject to their meeting of quality and technical specifications. If the bidder is OEM of the offered products, it would be exempted from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. In case any bidder is seeking exemption from Turnover / Experience Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer.
3. The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated above in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3-year-old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
4. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM of the product offered in the bid {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts and delivery acceptance certificates like CRAC to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.
5. Preference to Make In India products (For bids < 200 Crore):Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate .The

buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023.

[OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.

6. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

7. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

8. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 30% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

9. Reverse Auction would be conducted amongst all the technically qualified bidders except the Highest quoting bidder. The technically qualified Highest Quoting bidder will not be allowed to participate in RA. However, H-1 will also be allowed to participate in RA in following cases:

- If number of technically qualified bidders are only 2 or 3.
- If Buyer has chosen to split the bid amongst N sellers, and H1 bid is coming within N.
- In case Primary product of only one OEM is left in contention for participation in RA on elimination of H-1.
- If L-1 is non-MSE and H-1 is eligible MSE and H-1 price is coming within price band of 15% of Non-MSE L-1
- If L-1 is non-MII and H-1 is eligible MII and H-1 price is coming within price band of 20% of Non-MII L-1

XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (200 meter)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Bis Required	Yes
--------------	-----

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Cables suitable for use in mines	Yes
	Cables suitable for use in low temperature applications	Yes
GENERIC	Classification of cables for improved fire performance category	01
	Nominal Area of Conductor (in Sq mm)	50
	Number of core (in Nos)	3.5
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized steel formed wire
	Type of armouring	Single wire
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Pune	200	15

XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (310 meter)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	Yes
	Cables suitable for use in low temperature applications	Yes
GENERIC	Classification of cables for improved fire performance category	C1 - FR
	Nominal Area of Conductor (in Sq mm)	16
	Number of core (in Nos)	4
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized steel formed wire
	Type of armouring	Single wire
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Pune	310	15

XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (202 meter)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No
	Cables suitable for use in low temperature applications	No
GENERIC	Classification of cables for improved fire performance category	C2 - FR-LSH
	Nominal Area of Conductor (in Sq mm)	35
	Number of core (in Nos)	3.5
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized round steel wire
	Type of armouring	Single strip
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Pune	202	15

XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (394 meter)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No
	Cables suitable for use in low temperature applications	No
GENERIC	Classification of cables for improved fire performance category	01
	Nominal Area of Conductor (in Sq mm)	10
	Number of core (in Nos)	2
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized steel formed wire
	Type of armouring	Single strip
CERTIFICATION	Availability of Optional Test Reports	Resistance test for Armour

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Pune	394	15

XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (150 meter)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	Yes
	Cables suitable for use in low temperature applications	Yes
GENERIC	Classification of cables for improved fire performance category	01
	Nominal Area of Conductor (in Sq mm)	70
	Number of core (in Nos)	3.5
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized round steel wire
	Type of armouring	Single wire
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Pune	150	15

XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (210 meter)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	Yes
	Cables suitable for use in low temperature applications	Yes
GENERIC	Classification of cables for improved fire performance category	C2 - FR-LSH
	Nominal Area of Conductor (in Sq mm)	25
	Number of core (in Nos)	4
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized steel formed wire
	Type of armouring	Single strip
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Pune	210	15

XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (100 meter)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	Yes
	Cables suitable for use in low temperature applications	No
GENERIC	Classification of cables for improved fire performance category	01
	Nominal Area of Conductor (in Sq mm)	95
	Number of core (in Nos)	3.5
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Un-vulcanized rubber
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized steel formed wire
	Type of armouring	Single strip
CERTIFICATION	Availability of Optional Test Reports	Not applicable

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Pune	100	15

XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (299 meter)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	Yes
	Cables suitable for use in low temperature applications	Yes
GENERIC	Classification of cables for improved fire performance category	01
	Nominal Area of Conductor (in Sq mm)	16
	Number of core (in Nos)	2
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized steel formed wire
	Type of armouring	Single strip
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Pune	299	15

XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (274 meter)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No
	Cables suitable for use in low temperature applications	Yes
GENERIC	Classification of cables for improved fire performance category	C2 - FR-LSH
	Nominal Area of Conductor (in Sq mm)	6
	Number of core (in Nos)	2
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized round steel wire
	Type of armouring	Single wire
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Pune	274	15

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (2 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	ISI marked	NO
	Rated Current (in Ampere)	320A
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35/50/65 KA tripping range
	Breaking current (in KA)	35 KA
	Rated Voltage	240/415 Volt 50 Hz AC

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Pune	2	15

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (86 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Bis Required	Yes
--------------	-----

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	2 P with 1 PP
	Rated voltage (in Volts)	240 V, AC, 415 V, AC, 230 / 415 V, AC, 240 / 415 V, AC
	Rated Current (in Ampere)	20

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Instantaneous tripping current type	D
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Pune	86	15

Miniature Circuit Breakers Distribution Boards As Per IS 13032 (19 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	Rated voltage of MCB Board (in Volts)	240
	Number of ways (in Nos)	8
	Rating of the Busbar (in Ampere)	100
	Material of Busbar	Copper
CONSTRUCTION	Material Of MCB Board Boxes	Mild Steel - Properly pretreated and stove enamelled/Powder Coated
	Thickness of material (in mm)	1.6 mm (MS sheet)
	Enclosure - Degree of Protection	IP 43

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Method of operating MCB's	Single Door (without opening of cover)
	Suitable to accommodates specified Number of poles	Single Pole MCBs as outgoing and Double pole MCB as incoming
	Additional requirement	NA
CERTIFICATION	Availability of type test report from Govt. Lab/ NABL accredited lab / ILAC accredited lab to prove conformity of the specification	No

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Pune	19	15

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (2 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	ISI marked	YES
	Rated Current (in Ampere)	400A
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity 10/16 KA tripping range
	Breaking current (in KA)	36 KA
	Rated Voltage	415 volt 50 Hz

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Pune	2	15

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (3 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	ISI marked	YES
	Rated Current (in Ampere)	200A
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35/50/65 KA tripping range
	Breaking current (in KA)	25 KA
	Rated Voltage	415 volt 50 Hz

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Pune	3	15

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (3 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	ISI marked	YES
	Rated Current (in Ampere)	250A
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35/50/65 KA tripping range
	Breaking current (in KA)	25 KA
	Rated Voltage	415 volt 50 Hz

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Pune	3	15

Miniature Circuit Breakers Distribution Boards As Per IS 13032 (18 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	Rated voltage of MCB Board (in Volts)	240
	Number of ways (in Nos)	4
	Rating of the Busbar (in Ampere)	100
	Material of Busbar	Copper

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
CONSTRUCTION	Material Of MCB Board Boxes	Mild Steel - Properly pretreated and stove enameled/Powder Coated
	Thickness of material (in mm)	1.4 mm (MS sheet)
	Enclosure - Degree of Protection	IP 43
	Method of operating MCB's	Double Door (after opening of top cover)
	Suitable to accommodates specified Number of poles	Single Pole MCBs as outgoing and Double pole MCB as incoming

Consignees/Reporting Officer/परिषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परिषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	*****	*****Pune	18	15

Buyer Added Bid Specific Terms and Conditions/क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें

1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$, subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

2. Generic

Bidder shall submit the following documents along with their bid for Vendor Code Creation:

- Copy of PAN Card.
- Copy of GSTIN.
- Copy of Cancelled Cheque.

d. Copy of EFT Mandate duly certified by Bank.

3. **Generic**

Manufacturer Authorization:Wherever Authorised Distributors/service providers are submitting the bid, Authorisation Form /Certificate with OEM/Original Service Provider details such as name, designation, address, e-mail Id and Phone No. required to be furnished along with the bid

4. **Scope of Supply**

Scope of supply (Bid price to include all cost components) : Only supply of Goods

5. **Certificates**

Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.

6. **Certificates**

ISO 9001: The bidder or the OEM of the offered products must have ISO 9001 certification.

7. **Certificates**

Material Test Certificate Should Be Sent Along with The Supply. The Material Will Be Checked by Buyer's Lab & the Results of the Lab will be the Sole Criteria for Acceptance of the Item.

8. **Certificates**

The bidder is required to upload, along with the bid, all relevant certificates such as BIS licence, type test certificate, approval certificates and other certificates as prescribed in the Product Specification given in the bid document.

9. **Certificates**

To be eligible for award of contract, Bidder / OEM must possess following Certificates / Test Reports on the date of bid opening (to be uploaded with bid):

yes

.

10. **Past Project Experience**

Proof for Past Experience and Project Experience clause: For fulfilling the experience criteria any one of the following documents may be considered as valid proof for meeting the experience criteria:a. Contract copy along with Invoice(s) with self-certification by the bidder that service/supplies against the invoices have been executed.b. Execution certificate by client with contract value.c. Any other document in support of contract execution like Third Party Inspection release note, etc.**Proof for Past Experience and Project Experience clause:** For fulfilling the experience criteria any one of the following documents may be considered as valid proof for meeting the experience criteria:a. Contract copy along with Invoice(s) with self-certification by the bidder that service/supplies against the invoices have been executed.b. Execution certificate by client with contract value.c. Any other document in support of contract execution like Third Party Inspection release note, etc.

Disclaimer/अस्वीकरण

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of

bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers / Service Providers are mandated to ensure compliance with all the applicable laws / acts / rules including but not limited to all Labour Laws such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972 etc. Any non-compliance will be treated as breach of contract and Buyer may take suitable actions as per GeM Contract.

[This Bid is also governed by the General Terms and Conditions/ यह बिड सामान्य शर्तों के अंतर्गत भी शासित है](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws./जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्यवाई का आधार होगा।

---Thank You/धन्यवाद---

