

SUBSTATION INSPECTION REPORT

Equipment: 132/33kV Power Transformer TR-502

Location: Main Substation B

Date: 2026-10-05

Inspector: A. Kumar (Electrical Division)

INSPECTION FINDINGS

1. PHYSICAL INSPECTION

- Minor oil seepage observed near the bottom radiator valve.
- Cooling fans operate normally in manual mode.
- Silica gel breather color: Dark Green.
- Main tank oil level: 65% (Normal).

2. TEMPERATURE METRICS

- Top Oil Temperature (TOT): 78°C.
- Winding Temperature Indicator (WTI): 82°C.
- Ambient temperature during inspection: 32°C.

3. DISSOLVED GAS ANALYSIS (DGA) RESULTS

- Hydrogen (H₂): 145 ppm (Elevated).
- Methane (CH₄): 15 ppm.
- Ethylene (C₂H₄): 10 ppm.
- Acetylene (C₂H₂): 0 ppm.
- Carbon Monoxide (CO): 200 ppm.