


# POLYCAB 3 CORE MV AS/NZS 1429.1 19/33 (36) KV

## MV Cable Cu Conductor, XLPE Insulation, Cu Screen and UA



Images not to scale. Follow table for dimensions

### APPLICATION

POLYCAB MV 19/33 KV XLPE insulated with Copper conductor Three core cable is suitable to use for power supply to wide networks i.e. Commercial, Industrial and Urban / Residential.

### CHARACTERISTICS

#### Voltage Rating

Nominal Voltage: : 19/33 (36) kV

#### Operation Temperature

Min. installation temperature: 0°C

Operating temperature: -25°C to +90°C

Emergency operating temperature: 105°C

(max. operation of 36hrs, at 3 periods for 12 consecutive months use)

Max. Short Circuit Temperature: 250°C

Fixed Installation: 12D (PVC) / 15D (HDPE)/20D (Nylon)

During Installation: 18D (PVC) / 25D (HDPE)/30D (Nylon)

D is overall diameter of cable

### CONSTRUCTION

- Conductor: Stranded Compacted Circular Copper conductor as per AS/NZS 1125
- Conductor Screen: Extruded Semi-conductive compound
- Insulation: XLPE
- Insulation Screen: Extruded Semi-conductive compound
- Longitudinal Water blocking : Water blocking tape below copper screen (Optional)
- Metallic Insulation Screen: Copper Wire Screen + helically applied copper tape (E/F current capacity – Based on requirement)
- binder tape / sheath over assembled cores
- Metallic Sheath: Lead Alloy (optional)
- Outer Sheath: Extruded Polyvinyl Chloride, Colour: Black
- Insect attack Protection: Polyamide Nylon (optional)
- (Alternative Sheath: PVC+HDPE Composite Sheath or PVC + Nylon + HDPE (composite sheath with anti-termite properties) or LSZH Outer sheath, and parameters will change accordingly)

### OUTSTANDING FEATURES

- Long life
- UV resistant
- Resistant to chemical exposure
- Resistant to water (AD7/AD8 with HDPE)
- Resistant to weather exposure
- Termite resistant (Optional)

### STANDARD FOLLOWS

AS/NZS 1429.1

AS/NZS 1125

AS/NZS 3808

### COMPLIANCE

- Conductor resistance AS/NZS 1125
- Insulation resistance AS/NZS 1429.1
- Voltage test AS/NZS 1429.1

### OUR ACCREDITATIONS



### APPROVAL



### NOTES

High Voltage Test (kV AC)	Partial discharge test (kV AC)		Impulse test Voltage (kV peak)
	200% to rated voltage	150% to rated voltage	
65	38	29	200

# POLYCAB 3 CORE MV AS/NZS 1429.1 19/33 (36) KV MV Cable Cu Conductor, XLPE Insulation, Cu Screen and UA



## DIMENSIONAL CHARACTERISTICS:

Product Code	No. of Cores	Core Cross sectional Area	Nominal Diameter		
	No.	mm <sup>2</sup>	Under metallic screen	Over metallic screen	Overall
MVNZ13CXUAPH003C050SAXXXX	3	50	27.2	28.7	68.0
MVNZ13CXUAPH003C070SAXXXX	3	70	28.9	30.4	72.0
MVNZ13CXUAPH003C095SAXXXX	3	95	30.4	31.9	75.0
MVNZ13CXUAPH003C120SAXXXX	3	120	32	33.5	79.0
MVNZ13CXUAPH003C150SAXXXX	3	150	33.4	34.9	82.0
MVNZ13CXUAPH003C185SAXXXX	3	185	35.1	36.6	86.0
MVNZ13CXUAPH003C240SAXXXX	3	240	37.4	38.9	91.0
MVNZ13CXUAPH003C300SAXXXX	3	300	39.4	40.9	96.0
MVNZ13CXUAPH003C400SAXXXX	3	400	42.2	43.7	102.0
MVNZ13CXUAPH003C500SAXXXX	3	500	45.6	47.1	110.0

• Above mentioned parameters are based on 3kA/sec earth fault current capacity of copper screen

## ELECTRICAL CHARACTERISTICS:

No. of Cores	Core Cross sectional Area	Max. DC Resistance at 20°C	Max. AC Resistance at 90°C	Approx. Capacitance	Approx. Inductance	Approx. Reactance	Continuous Current Rating		
							Buried direct in ground	In a buried duct	In Air
No.	mm <sup>2</sup>	Ω/km	Ω/km	μF/km	mH/km	Ω/km	Amps		
3	50	0.387	0.494	0.14	0.642	0.202	181	158	204
3	70	0.268	0.342	0.15	0.605	0.190	221	193	253
3	95	0.193	0.246	0.17	0.585	0.184	262	231	304
3	120	0.153	0.196	0.18	0.565	0.178	298	264	351
3	150	0.124	0.159	0.19	0.552	0.173	334	297	398
3	185	0.0991	0.127	0.21	0.539	0.169	377	336	455
3	240	0.0754	0.097	0.23	0.523	0.164	434	390	531

Document No.: 00398.Rev No.: 00 Date: 05-01-2024 / We reserve the rights to make technical changes.

# POLYCAB 3 CORE MV AS/NZS 1429.1 19/33 (36) KV

## MV Cable Cu Conductor, XLPE Insulation, Cu Screen and UA

No. of Cores	Core Cross sectional Area	Max. DC Resistance at 20°C	Max. AC Resistance at 90°C	Approx. Capacitance	Approx. Inductance	Approx. Reactance	Continuous Current Rating		
							Buried direct in ground	In a buried duct	In Air
No.	mm <sup>2</sup>	Ω/km	Ω/km	μF/km	mH/km	Ω/km	Amps		
3	300	0.0601	0.078	0.25	0.510	0.160	489	441	606
3	400	0.047	0.062	0.27	0.497	0.156	553	501	696
3	500	0.0366	0.049	0.3	0.484	0.152	632	574	800

\*: Current Ratings are based on IEC 60502-2 & IEC 60287, Max. Conductor Temperature at 90°C, Ambient temperature at 30°C in Air / at 20°C in Ground, Thermal resistivity of Soil 1.5 k.m/W & for earthenware ducts 1.2k.m/W and Depth of Laying 0.8m.

Current rating de-rating factors for other than 30°C ambient air temperature.

20	25	35	40	45	50	55	60
1.08	1.04	0.96	0.91	0.87	0.82	0.76	0.71

Current rating de-rating factors for other than 20°C ground temperature.

10	15	25	30	35	40	45	50
1.07	1.04	0.96	0.93	0.89	0.85	0.80	0.76

No. of Cores	Core Cross sectional Area	Max. pulling tension on conductor	Charging Current per phase	Zero sequence impedance	Electric Stress at Conductor Screen	Short circuit rating of Phase conductor
No.	mm <sup>2</sup>	kN	Amps/Km	Ohms/Km	kV/mm	kA, 1 sec
3	50	3.5	0.84	1.66	4.1	7.2
3	70	4.9	0.9	1.50	3.9	10.0
3	95	6.65	1.01	1.41	3.7	13.6
3	120	8.4	1.07	1.36	3.6	17.1
3	150	10.5	1.13	1.32	3.5	21.4
3	185	12.95	1.25	1.29	3.4	26.4
3	240	16.8	1.37	1.26	3.3	34.3
3	300	21	1.49	1.24	3.2	42.8
3	400	28	1.61	1.22	3.1	56.9
3	500	35	1.79	1.21	3.0	71.5