

BDS SAMPLE PROJECT - OUTLINE SPECIFICATION

Document: BDS-SAMPLE-XX-XX-SP-A-0001 Revision: P01

1. EXTERNAL WALLS

All external walls (layer A-WALL-EXT) shall be 200 mm blockwork with a fire rating of FR60.

2. INTERNAL WALLS

Internal partitions (layer A-WALL-INT) shall be 100 mm stud and are not fire rated.

3. FLOORS

The ground floor slab (layer A-FLOR) shall be 200 mm reinforced concrete.

4. ENVELOPE ZONE

The zone drawn on layer EXT-ENVELOPE-2HR is the external envelope line and shall be treated as external walling, 2 hour fire rated.

5. DOORS

All doors (layer A-DOOR) shall be fire rated FD30.