

PVsyst - Simulation report

Grid-Connected System

Project: Santa Barbara AC

Variant: New simulation variant

Tables on a building

System power: 1540 kWp

Santa Barbara/La Patera - 美国

PVsyst student

PVsyst student

作者



Project: Santa Barbara AC

Variant: New simulation variant

University of Edinburgh (United kingdom)

VC1, Simulation date: 03/20/23 11:47 with v7.3.2

Project summary

Geographical Site

Santa Barbara/La Patera

Situation Latitude

34.43 °N -119.84 °W

Albedo

Project settings

0.20

美国

Longitude Altitude Time zone

2 m UTC-8

Meteo data

Santa Barbara/La Patera MeteoNorm 8.1 station - 合成的

System summary

Grid-Connected System

Simulation for year no 10

PV Field Orientation

Fixed plane Tilt/Azimuth

Tables on a building

Near Shadings Linear shadings

User's needs Ext. defined as file

EV load. CSV

System information

PV Array

Inverters

Nb. of units

21 units

Nb. of modules Pnom total

3460 units $1540~\mathrm{kWp}$

Pnom total

1386 kWac

Pnom ratio

1.111

Results summary

Produced Energy Used Energy

2520659 kWh/year 971465 kWh/year

Specific production

1637 kWh/kWp/year Perf. Ratio PR

Solar Fraction SF

81.30 % 60.13 %

Table of contents

Project and results summary	
General parameters, PV Array Characteristics, System losses	
Horizon definition	
Near shading definition - Iso-shadings diagram	
Main results	
Loss diagram	
Predef. graphs	
P50 - P90 evaluation	
Cost of the system	
Financial analysis	
CO ₂ Emission Balance	



Project: Santa Barbara AC

Variant: New simulation variant

University of Edinburgh (United kingdom)

VC1, Simulation date: 03/20/23 11:47 with v7.3.2

General parameters

Grid-Connected System Tables on a building

PV Field Orientation

Orientation **Sheds configuration** Models used

Fixed plane Nb. of sheds 54 units Transposition Perez Tilt/Azimuth 13 / 0 ° Sizes Diffuse Perez, Meteonorm

Sheds spacing 19.0 m Circumsolar separate

Collector width 13.7 m Ground Cov. Ratio (GCR) 72.0 %

User's needs Horizon **Near Shadings** 2.6° Ext. defined as file Average Height Linear shadings EV load. CSV

Jan.	Feb.	Mar.	Apr.	May	June	July	Aug.	Sep.	Oct.	Nov.	Dec.	Year	
82508	74524	82508	79847	82508	79847	82508	82508	79847	82508	79847	82508	971467	kWh

PV Array Characteristics

PV module Inverter

Manufacturer ${\tt Generic}$ Manufacturer Generic Mode1 SPR-X20-445-COM Mode1 CSI-66KTL-GS

(Original PVsyst database) (Original PVsyst database)

66.0 kWac Unit Nom. Power 445 Wp Unit Nom Power Number of PV modules 3460 units 84 * MPPT 25% Number of inverters 21 units Nominal (STC) 1540 kWpTotal power 1386 kWac

Modules 346 Strings x 10 In series Operating voltage 200-850 V

1.11 Pnom ratio (DC:AC) At operating cond. (50° C)

Pmpp 1433 kWp No power sharing between MPPTs 694 V U mpp

Total PV power Total inverter power

2066 A

Nominal (STC) 1540 kWp Total power 1386 kWac Total 3460 modules Number of inverters 21 units

 7481 m^2 Pnom ratio 1.11 Module area Cell area 6776 m^2

Array losses

 $0.0 \text{ W/m}^2 \text{ K/m/s}$

Array Soiling Losses

I mpp

Uv (wind)

Average loss Fraction

Jan.	Feb.	Mar.	Apr.	May	June	July	Aug.	Sep.	Oct.	Nov.	Dec.
2.0%	2.0%	2.0%	2.0%	4.3%	4.3%	4.3%	4.3%	4.3%	4.3%	2.0%	2.0%

Thermal Loss factor DC wiring losses **Module Quality Loss** Module temperature according to irradiance Global array res. 5.5 m Ω Loss Fraction

-0.8 %

29.0 $W/m^2 K$ Loss Fraction 1.5 % at STC Uc (const)

03/26/23 PVsyst Student License for University of Edinburgh (United kingdom)



VC1, Simulation date: 03/20/23 11:47 with v7.3.2

Project: Santa Barbara AC

Variant: New simulation variant

University of Edinburgh (United kingdom)

Array losses

0.1%

Module mismatch losses

Strings Mismatch loss

Year no

Module average degradation

Loss Fraction

2.0 % at MPP

Loss Fraction

Loss factor

0.4 %/year

Mismatch due to degradation

Imp RMS dispersion

0.4 %/year

Vmp RMS dispersion

0.4 %/year

IAM loss factor

Incidence effect (IAM): Fresnel, AR coating, n(glass)=1.526, n(AR)=1.290

0°	30°	50°	60°	70°	75°	80°	85°	90°
1.000	0. 999	0. 987	0.962	0.892	0.816	0.681	0. 440	0.000

System losses

Unavailability of the system

Time fraction 1.0 %

3.7 days,

3 periods



Variant: New simulation variant

Project: Santa Barbara AC

University of Edinburgh (United kingdom)

VC1, Simulation date: 03/20/23 11:47 with v7.3.2

Horizon definition


Horizon from PVGIS website API, Lat=34° 25"48', Long=-119° 50"24', Alt=2m

Average Height	2.6°	Albedo Factor	0.94
Diffuse Factor	1.00	Albedo Fraction	100 %

Horizon profile

Azimuth [°]	-180	-173	-165	-150	-143	-135	-128	-120	-113	-105	-98
Height [°]	5. 7	5. 3	5. 0	5. 0	5. 7	4.6	5.0	4.6	3.4	2. 7	1.9
Azimuth [°]	-90	-83	-75	-45	-38	0	8	45	53	60	105
Height [°]	0.8	1.1	0.8	0.8	1.1	1.1	1.5	1.5	0.8	1.1	1.1
Azimuth [°]	113	120	128	135	150	158	165	173	180		
Height [°]	1.5	1.9	3.8	4.6	4.6	5. 7	6.1	6.1	5. 7		

Sun Paths (Height / Azimuth diagram)







Variant: New simulation variant

University of Edinburgh (United kingdom)

VC1, Simulation date: 03/20/23 11:47 with v7.3.2







Project: Santa Barbara AC

Variant: New simulation variant

University of Edinburgh (United kingdom)

VC1, Simulation date: 03/20/23 11:47 with v7.3.2

Main results

System Production

Produced Energy Used Energy 2520659 kWh/year 971465 kWh/year Specific production Performance Ratio PR Solar Fraction SF

7.5 years

 $1637~\mathrm{kWh/kWp/year}$

81. 30 % 60. 13 %

Economic evaluation

Investment Global

Specific

4, 693, 236. 82 USD 3. 05 USD/Wp Yearly cost


Annuities 0.00 USD/yr Run. costs 54,063.50 USD/yr LCOE

Energy cost


0.10 USD/kWh

Payback period

Normalized productions (per installed kWp)



Performance Ratio PR



Balances and main results

	GlobHor	DiffHor	T_Amb	Globinc	GlobEff	EArray	E_User	E_Solar	E_Grid	EFrGrid
	kWh/m²	kWh/m²	°C	kWh/m²	kWh/m²	kWh	kWh	kWh	kWh	kWh
January	89. 9	32. 10	12.00	114. 2	107.0	149984	82508	44007	103646	38501
February	99. 3	38. 50	11.80	118. 3	112.0	157036	74523	43014	111645	31509
March	144.9	57. 80	13. 40	159.8	151.9	210195	82508	50879	156046	31629
April	183. 1	64. 70	14. 10	193.5	184. 4	254679	79846	53098	197773	26749
May	222.4	64.00	15. 70	224.3	209.3	286940	82508	56377	225997	26130
June	223.6	70.40	16.80	220.3	205. 2	281229	79846	53757	206117	26089
July	218.9	82. 10	18.60	218.1	203.1	276858	82508	58009	214451	24499
August	212.6	60.30	18.80	220.5	205.8	279533	82508	53233	211092	29275
September	163.0	58. 10	18. 30	177.3	164.8	224300	79846	47992	172829	31854
October	119.6	48. 30	16.80	137.9	127.7	175988	82508	43264	121207	39244
November	102.4	28. 40	13. 70	129.4	122.1	169761	79846	40394	126774	39453
December	77. 2	28. 40	10. 90	100.0	93. 2	131178	82508	40125	88932	42383
Year	1856. 9	633. 10	15. 09	2013. 7	1886. 6	2597682	971465	584150	1936509	387315

Legends

GlobHor Global horizontal irradiation

DiffHor Horizontal diffuse irradiation

T_Amb Ambient Temperature

GlobInc Global incident in coll. plane

GlobEff Effective Global, corr. for IAM and shadings

EArray Effective energy at the output of the array
E_User Energy supplied to the user
E_Solar Energy from the sun
E_Grid Energy injected into grid
EFrGrid Energy from the grid




Variant: New simulation variant

University of Edinburgh (United kingdom)

VC1, Simulation date: 03/20/23 11:47 with v7.3.2


ibity of Edinbargh (onlived Kingdom)





Variant: New simulation variant

University of Edinburgh (United kingdom)





Project: Santa Barbara AC

Variant: New simulation variant

University of Edinburgh (United kingdom)

VC1, Simulation date: 03/20/23 11:47 with v7.3.2

P50 - P90 evaluation

	P50 - P9	u evaluation ————————————————————————————————————	
Meteo data		Simulation and parameters uncer	tainties
Source MeteoNo	orm 8.1 station	PV module modelling/parameters	1.0 %
Kind Mo	nthly averages	Inverter efficiency uncertainty	0.5 %
合成的 - Multi-year average		Soiling and mismatch uncertainties	1.0 %
Year-to-year variability(Variance)	2.5 %	Degradation uncertainty	1.0 %
Specified Deviation			
Climate change	0.0 %		
Global variability (meteo + sys	stem)	Annual production probability	
Variability (Quadratic sum)	3.1 %	Variability	78 MWh
		P50	2521 MWh
		P90	2421 MWh
		P95	2393 MWh
0.50	Probabili	ty distribution	
0.50		'	'
F			‡
0.45			7
E	P50 = 25	521 MWh	3
0.40		E_Grid simul = 2521 MWh	=
ļ.			‡
0.35 –			4
<u>-</u>		\	=
0.30		\	
F	/	\	1
ilid 0 35	/	\	1
Probability	/	\	3
<u> </u>	/	\]
0.20	/	\	
ţ.	P90 = 2421 MWh	\	‡
0.15		\	-]
E		\]
0.10	P95 = 2393 MWh	\	
<u>-</u>		\	‡
205			1
0.05			3
			_]
0.00	2400 2500	2600 2700	2800
2300		ystem production MWh	2000
	2_011d 3	, p	



Project: Santa Barbara AC

Variant: New simulation variant

University of Edinburgh (United kingdom)

VC1, Simulation date: 03/20/23 11:47 with v7.3.2

Cost of the system

Installation costs

Item	Quantity	Cost	Total
	units	USD	USD
PV modules			
SPR-X20-445-COM	3460	500.00	1,730,000.00
Supports for modules	3460	70.00	242, 200. 00
Inverters			
CSI-66KTL-GS	21	3, 870. 00	81, 270. 00
Other components			
Accessories, fasteners	6	50,000.00	300,000.00
Wiring	1	80, 000. 00	80, 000. 00
Combiner box	2	3, 500. 00	7, 000. 00
Monitoring system, display screen	1	10,000.00	10, 000. 00
Measurement system, pyranometer	-1	10, 000. 00	10, 000. 00
Surge arrester	6	2,000.00	12, 000. 00
Studies and analysis		·	
Engineering	1	30,000.00	30, 000. 00
Permitting and other admin. Fees	1	15, 000. 00	15, 000. 00
Environmental studies	1	15, 000. 00	15, 000. 00
Economic analysis	1	15, 000. 00	15, 000. 00
Installation		,	,
Global installation cost per module	3460	70.00	242, 200. 00
Global installation cost per inverter	21	500,00	10, 500. 00
Transport	1	20,000.00	20, 000. 00
Settings	1	20, 000. 00	20, 000. 00
Grid connection	1	150, 000. 00	150, 000. 00
Insurance			
Building insurance	-1	25, 000, 00	25, 000. 00
Transport insurance	1	10, 000. 00	10, 000. 00
Liability insurance	1	15, 000. 00	15, 000. 00
Land costs		10,000.00	10,000,00
Land purchase	1	1, 500, 000. 00	1, 500, 000. 00
Taxes		_, ,	_,,
VAT	1	0.00	93, 857. 93
Federal taxes	1	0.00	43, 870. 89
State taxes	1	0.00	12, 690. 00
Local taxes	1	0.00	2, 119. 00
Other taxes	1	0.00	529. 00
voire tunes	1	Total	4, 693, 236. 82
		Depreciable asset	2, 353, 470. 00

Operating costs

Item	Total
	USD/year
Maintenance	
Provision for inverter replacement	4, 063. 50
Cleaning	50, 000. 00
Total (OPEX)	54, 063. 50



VC1, Simulation date: 03/20/23 11:47 with v7.3.2

Project: Santa Barbara AC

Variant: New simulation variant

University of Edinburgh (United kingdom)

Cost of the system

System summary

Total installation cost
Operating costs
Unused energy
Energy sold to the grid
Cost of produced energy (LCOE)

4,693,236.82 USD 54,063.50 USD/year 584 MWh/year 1937 MWh/year 0.096 USD/kWh

PVsyst student

PVsyst student

PVsyst student



VC1, Simulation date: 03/20/23 11:47 with v7.3.2

Project: Santa Barbara AC

Variant: New simulation variant

University of Edinburgh (United kingdom)

Financial analysis

•		
Simil	lation	period
OIIIIA	ution	PULLUG

Project lifetime 25 years Start year 2024

Income variation over time

Inflation 0.00 %/year Production variation (aging) 0.00 %/year Discount rate 0.00 %/year

Income dependent expenses

0.00 %/year Income tax rate Other income tax 0.00 %/year Dividends 0.00 %/year

Depreciable assets

Asset	Depreciation	Depreciation	Salvage	Depreciable
	method	period	value	(USD)
		(years)	(USD)	
PV modules				
SPR-X20-445-COM	Straight-line	25	0.00	1, 730, 000. 00
Supports for modules	Straight-line	25	0.00	242, 200. 00
Inverters				
CSI-66KTL-GS	Straight-line	25	0.00	81, 270. 00
Accessories, fasteners	Straight-line	20	0.00	300, 000. 00
		Total	0.00	2, 353, 470. 00

Financing

4, 693, 236. 82 USD Own funds

Electricity sale

0. 2325 USD/kWh Feed-in tariff Duration of tariff warranty 20 years Annual connection tax 0.00 USD/kWh Annual tariff variation 0.0 %/year Feed-in tariff decrease after warranty 0.00 %

Self-consumption

 ${\tt Consumption}\ {\tt tariff}$ 0.4000 USD/kWh Tariff evolution 0.0 %/year

Return on investment

Payback period 7.5 years 11, 052, 773. 82 USD Net present value (NPV) Internal rate of return (IRR) 12.76 % Return on investment (ROI) 235.5 %



VC1, Simulation date: 03/20/23 11:47 with v7.3.2

Project: Santa Barbara AC

Variant: New simulation variant

University of Edinburgh (United kingdom)

Financial analysis

Detailed economic results (USD)

Year	Electricity sale	Own funds	Run. costs	Deprec. allow.	Taxable income	Taxes	After-tax profit	Self-cons. saving	Cumul. profit	% amorti.
1	450, 243	0	54, 064	97, 139	299, 041	0	396, 180	233, 661	-4, 063, 396	13.4%
2	450, 243	0	54, 064	97, 139	299, 041	0	396, 180	233, 661	-3, 433, 556	26.8%
3	450, 243	0	54, 064	97, 139	299, 041	0	396, 180	233, 661	-2, 803, 716	40.3%
4	450, 243	0	54, 064	97, 139	299, 041	0	396, 180	233, 661	-2, 173, 875	53. 7%
5	450, 243	0	54, 064	97, 139	299, 041	0	396, 180	233, 661	-1, 544, 035	67. 1%
6	450, 243	0	54, 064	97, 139	299, 041	0	396, 180	233, 661	-914, 194	80. 5%
7	450, 243	0	54, 064	97, 139	299, 041	0	396, 180	233, 661	-284, 354	93. 9%
8	450, 243	0	54, 064	97, 139	299, 041	0	396, 180	233, 661	345, 487	107.4%
9	450, 243	0	54, 064	97, 139	299, 041	0	396, 180	233, 661	975, 327	120.8%
10	450, 243	0	54, 064	97, 139	299, 041	0	396, 180	233, 661	1,605,167	134. 2%
11	450, 243	0	54, 064	97, 139	299, 041	0	396, 180	233, 661	2, 235, 008	147.6%
12	450, 243	0	54, 064	97, 139	299, 041	0	396, 180	233, 661	2, 864, 848	161.0%
13	450, 243	0	54, 064	97, 139	299, 041	0	396, 180	233, 661	3, 494, 689	174. 5%
14	450, 243	0	54, 064	97, 139	299, 041	0	396, 180	233, 661	4, 124, 529	187. 9%
15	450, 243	0	54, 064	97, 139	299, 041	0	396, 180	233, 661	4, 754, 370	201.3%
16	450, 243	0	54, 064	97, 139	299, 041	0	396, 180	233, 661	5, 384, 210	214. 7%
17	450, 243	0	54, 064	97, 139	299, 041	0	396, 180	233, 661	6, 014, 050	228. 1%
18	450, 243	0	54, 064	97, 139	299, 041	0	396, 180	233, 661	6, 643, 891	241.6%
19	450, 243	0	54, 064	97, 139	299, 041	0	396, 180	233, 661	7, 273, 731	255.0%
20	450, 243	0	54, 064	97, 139	299, 041	0	396, 180	233, 661	7, 903, 572	268. 4%
21	450, 243	0	54, 064	82, 139	314, 041	0	396, 180	233, 661	8, 533, 412	281.8%
22	450, 243	0	54, 064	82, 139	314, 041	0	396, 180	233, 661	9, 163, 253	295. 2%
23	450, 243	0	54, 064	82, 139	314, 041	0	396, 180	233, 661	9, 793, 093	308. 7%
24	450, 243	0	54, 064	82, 139	314, 041	0	396, 180	233, 661	10, 422, 933	322. 1%
25	450, 243	0	54, 064	82, 139	314, 041	0	396, 180	233, 661	11, 052, 774	335. 5%
Total	11,256,080	4,693,237	1,351,588	2,353,470	7,551,023	0	9,904,493	5,841,518	11,052,774	335.5%


PVsyst student



Variant: New simulation variant

University of Edinburgh (United kingdom)

VC1, Simulation date: 03/20/23 11:47 with v7.3.2





Project: Santa Barbara AC

Variant: New simulation variant

University of Edinburgh (United kingdom)

VC1, Simulation date: 03/20/23 11:47 with v7.3.2

CO₂ Emission Balance

Total: -3196.7 tCO₂

Generated emissions Total:

3196.66 tCO₂

Source: Detailed calculation from table below

Replaced Emissions


0.0 tCO₂ Total:

System production: 2520.66 MWh/yr

Grid Lifecycle Emissions: 0 gCO₂/kWh

Source: Custom value supplied by user

Lifetime: 30 years 1.0 % Annual degradation:



System Lifecycle Emissions Details

Item	LCE	Quantity	Subtotal	
			[kgCO ₂]	
Modules	1559 kgCO2/kWp	2051 kWp	3196347	
Supports	0.01 kgC02/kg	46080 kg	307	
Inverters	0.66 kgCO2/units	13.0 units	8. 59	