



City of Lauderdale Lakes
4300 NW 36th Street
Lauderdale Lakes, Fl., 33319

Department of Financial Services
Phone: [REDACTED]
Fax: [REDACTED]

ADDENDUM No. 2

ADDENDUM NO. 2

TITLE: Fuel Bay Overhead Canopy Replacement

DATE: May 5th, 2026

ITB NO.: 26-6310-25B

ITB CLOSING DATE: May 15th, 2026 @ 10:00AM

NUMBER OF PAGES: 3

This Addendum to the contract documents is issued to provide additional information and clarification to the original solicitation requirements and is hereby declared a part of the original contract documents. In case of conflict, this Addendum shall govern. Bidders shall acknowledge receipt of this Addendum by signature of this form to be included with their intended Bid submission. Failure to sign and provide with bid submission shall deem your company as non-responsive.

Clarifications & Announcements:

Mandatory Pre-Bid Conference Sign-in Sheet @ 10:00 AM

Project Title: ITB26-6310-25B Fuel Bay Overhead Canopy Replacement
Date: 4/30/2026

	Company/Representative	Address/Email	Phone #
1	[REDACTED]	[REDACTED]	[REDACTED]
2	[REDACTED]	[REDACTED]	[REDACTED]
3	[REDACTED]	[REDACTED]	[REDACTED]
4	[REDACTED]	[REDACTED]	[REDACTED]
5	[REDACTED]	[REDACTED]	[REDACTED]
6	[REDACTED]	[REDACTED]	[REDACTED]
7	[REDACTED]	[REDACTED]	[REDACTED]
8	[REDACTED]	[REDACTED]	[REDACTED]
9	[REDACTED]	[REDACTED]	[REDACTED]
10	[REDACTED]	[REDACTED]	[REDACTED]
11	[REDACTED]	[REDACTED]	[REDACTED]

1

Questions & Answers:

Q1:

What is the City's budget for this project?

A1:

\$330,000



City of Lauderdale Lakes
4300 NW 36th Street
Lauderdale Lakes, Fl., 33319

Department of Financial Services
Phone: [REDACTED]
Fax: [REDACTED]

Q2:

Is the existing fuel pump required to remain operational during all construction activities?

A2:

From 7 am to 9 am Monday to Friday.

Q3:

Confirm whether existing fuel dispensers, tanks, slab, and fuel piping are to remain fully operational during construction.

A3:

The response to Q2 should be considered so the City can have access to fuel.

Q4:

Provide demolition requirements for the existing canopy, including limits of removal and disposal.

A4:

Demolition scope is to remove 2 existing steel columns and existing overhead canopy. Dispose in accordance to building codes.

Q5:

Who is responsible for delegated design and engineering of the canopy system?

A5:

Design and specifications are provided on the bid package. City will provide Special inspector's and design support, if any revisions are required during construction.

Q6:

Confirm exact canopy dimensions and governing layout (since drawings are NTS).

A6:

The plans are not in scale, but the dimensions are provided on the plan.

Q7:

Confirm roof drainage strategy (gutters, slope, discharge).

A7:

The roof drainage discharge is toward the lower slope area. No gutters, or roof drains are proposed.

Q8:

Provide paint/coating specification for steel.

A8:

Sandblasting and apply a rust-inhibitive prime coat. Final color will be determined by the Project Manager.



City of Lauderdale Lakes
4300 NW 36th Street
Lauderdale Lakes, Fl., 33319

Department of Financial Services
Phone: [REDACTED]
Fax: [REDACTED]

ALL ELSE REMAINS THE SAME

ACKNOWLEDGED BY:

COMPANY NAME

SIGNATURE/DATE

PRINTED NAME

CITY OF LAUDERDALE LAKES

[REDACTED]

[REDACTED]
**Procurement Manager,
Financial Services**