



TEST REPORT IEC/EN 62109-1 Safety of Power Converter for use in Photovoltaic Power Systems Part 1: General requirements	
Report Number.:	GZES230100125901
Date of issue:	2023-02-01
Total number of pages:	72
Name of Testing Laboratory preparing the Report:	SGS-CSTC Standards Technical Services Co., Ltd. Guangzhou Branch
Applicant's name:	Zhejiang CHISAGE New Energy Technology Co., Ltd
Address:	No. 1828 Fuqing South RD. Panhuo ST. Yinzhou District Ningbo Zhejiang 315000 China
Test specification:	
Standard:	EN 62109-1:2010 IEC 62109-1:2010 (First Edition)
Test procedure:	SGS-CSTC
Non-standard test method:	N/A
Test Report Form No.:	IEC62109_1B
Test Report Form(s) Originator:	VDE Testing and Certification Institute
Master TRF:	Dated 2016-04
Copyright © 2016 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved. This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.	
This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.	
General disclaimer: The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.	

Test item description	Single phase inverter
Trade Mark	 CHISAGE
Manufacturer	Zhejiang CHISAGE New Energy Technology Co., Ltd
Address	No. 1828 Fuqing South RD. Panhuo ST. Yinzhou District Ningbo Zhejiang 315000 China
Model/Type reference	See model list in page 7
Ratings	See model list in Page 7 to 8. Hardware version: Ver2.3 DC Software version: Ver0107 AC Software version: Ver2.5

Responsible Testing Laboratory (as applicable), testing procedure and testing location(s):		
☒	Testing Laboratory:	SGS-CSTC Standards Technical Services Co., Ltd. Guangzhou Branch
	Location/ address	198 Kezhu Road, Science City, Economic & Technology Development Area, Guangzhou, Guangdong, China
	Tested by (name, function, signature)	Doris Tao (Project Engineer)  
	Approved by (name, function, signature	Roger Hu (Technical Reviewer)  

List of Attachments (including a total number of pages in each attachment): 63 Page ~72 Page

Summary of testing:

Tests performed (name of test and test clause):

The equipment has been tested according to the standard: EN 62109-1:2010 and IEC 62109-1:2010.

All test results are from the original report GZES210602035101, issued by SGS-CTS Standards Technical Services Co., Ltd Guangzhou Branch.

Testing location:

See page 2

Summary of compliance with National Differences (List of countries addressed):

No National Differences are addressed to this test report

Copy of marking plate(representative):

Utility-Interactive Inverter

Maximum input Voltage: 60Vdc
Range of input operating voltage: 25~55Vdc
Maximum input current: 13A x 4
Operating voltage range (AC): 230Vac
Rated output current(AC): 8.7A
Max output apparent power: 2000VA
Rated output power: 2000W
Rated AC Grid Frequency: 50/60Hz
Ambient Temperature: -40°C~+65°C
Peak efficiency: 96.5%
Protective class: Class I
Ingress protection: IP67
Max.Units per branch: 3

**Type: CE-1P20001G-230-EU**

Number Serial:



- Both AC and DC voltage sources are terminated inside this equipment
- Each circuit must be individually disconnected before servicing
- Photovoltaic array supplied a DC voltage to this equipment when exposed to light
- Hot surface: To reduce the risk of burn - Do not touch
- Raintight enclosure: IP67
- To be connected to a dedicated branch circuit
- Maximum Branch circuit overcurrent protection: 45A

www.chisagess.com**Note:**

1. The above markings are the minimum requirements required by the safety standard. For the final production samples, the additional markings which do not give rise to misunderstanding may be added.
2. Label is attached on the side surface of enclosure and visible after installation
3. Labels of other models are as the same with **CE-1P20001G-230-EU**'s except the parameters of rating.
4. As declared by the applicant, the importer (and manufacturer, if it is different)'s name, registered trade name or registered trademark and the postal address will be marked on the products before being place on the market. The contact details shall be in a language easily understood by end-users and market surveillance authorities.

Test item particulars	Single Phase Inverter		
Equipment mobility	☐ movable ☒ fixed	☐ hand-held ☐ transportable	☐ stationary ☐ for building-in
Connection to the mains	☐ pluggable equipment ☒ permanent connection		☐ direct plug-in ☐ for building-in
Environmental category	☒ outdoor	☐ indoor unconditional	☐ indoor conditional
Over voltage category Mains	☐ OVC I	☐ OVC II	☒ OVC III ☐ OVC IV
Over voltage category PV	☐ OVC I	☒ OVC II	☐ OVC III ☐ OVC IV
Mains supply tolerance (%)	-90 / +110 %		
Tested for power systems	TN systems		
IT testing, phase-phase voltage (V)	N/A		
Class of equipment	☒ Class I ☐ Class II ☐ Class III ☐ Not classified		
Mass of equipment (kg)	3,5 kg for all model		
Pollution degree	Outside PD3; Inside PD2		
IP protection class	IP 67		
Possible test case verdicts:			
- test case does not apply to the test object.....: N/A			
- test object does meet the requirement.....: P (Pass)			
- test object was not evaluated for the requirement.....: N/E			
- test object does not meet the requirement.....: F (Fail)			
Testing			
Date of receipt of test item			
Date (s) of performance of tests			
N/A			
2020-09-06 to 2020-09-28			

General remarks:

"(See Enclosure #)" refers to additional information appended to the report.

"(See appended table)" refers to a table appended to the report.

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at www.sgs.com/terms_and_conditions.htm and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

Throughout this report a ☒ comma / ☐ point is used as the decimal separator.

Manufacturer's Declaration per sub-clause 4.2.5 of IEC 60335-1:

The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided

☐ Yes

☒ Not applicable

When differences exist; they shall be identified in the General product information section.

Name and address of factory (ies).....: NingBo Deye Inverter Technology Co., Ltd.
No.26 South YongJiang Road, Daqi, Beilun, NingBo,
China.

General product information:

Product covered by this report is grid-connected PV inverter for indoor or outdoor installation. The connection to the DC input and AC output are through connectors.

The Solar inverter converts DC voltage into AC voltage.

The input and output are protected by varistors to Earth. The unit is providing EMC filtering at the output toward mains. The unit does not provide galvanic separation from input to output (transformerless). The output is switched off redundant by the high-power switching bridge and two relays. This assures that the opening of the output circuit can operate in case of single fault.

Equipment Under Testing:

**CE-1P3001G-230-EU, CE-1P5001G-230-EU, CE-1P6001G-230-EU,
CE-1P8001G-230-EU, CE-1P10001G-230-EU, CE-1P13001G-230-EU,
CE-1P16001G-230-EU, CE-1P18001G-230-EU, CE-1P20001G-230-EU⁽¹⁾**

⁽¹⁾ Except for 4.2.2.6 TABLE: mains supply electrical data in normal condition is All models test, the other test clause model is CE-1P20001G-230-EU.

Model Number	CE-1P3001G-230-EU	CE-1P5001G-230-EU	CE-1P6001G-230-EU	CE-1P8001G-230-EU	CE-1P10001G-230-EU
Input (DC)					
Max. input power	400W	600W	800W	1200W	1200W
Max. input voltage	60V				
MPPT voltage range	25~55V				
Max. input current	13A	13A	13A×2	13A×2	13A×2
Output (AC)					
Rated grid voltage	230V				
Rated grid frequency	50Hz				
Rated output power	300W	500W	600W	800W	1000W
Rated output current	1.3A	2.2A	2.6A	3.8A	4.8A
Power factor	>0.99				
Ambient temperature	-40 °C ~ 65 °C				
Ingress protection	IP67				
Protective class	Class I				

Model Number	CE-1P13001G -230-EU	CE-1P16001G -230-EU	CE-1P18001G -230-EU	CE-1P20001G -230-EU
Input (DC)				
Max. input power	1600W	2400W	2400W	2400W
Max. input voltage	60V			
MPPT voltage range	25~55V			
Max. input current	13A×4	13A×4	13A×4	13A×4
Output (AC)				
Rated grid voltage	230V			
Rated grid frequency	50Hz			
Rated output power	1300W	1600W	1800W	2000W
Rated output current	6.2A	7.7A	8.6A	9.6A
Power factor	>0.99			
Ambient temperature	-40 °C ~65 °C			
Ingress protection	IP67			
Protective class	Class I			