ILLUSTRATIVE DEMO DOCUMENT · not real customer data

Heating check report (installer visit)

Customer D-B03 · Hamburg area (21xxx)

Top floor added in the 1990s: 45 m², not heated and not lived in.

Radiators: 15 panel radiators, all type 22 (two panels), 600 × 1400 mm.

Heating system: two-pipe (Zweirohrsystem).

Hydraulic balancing done 03/2023: all 15 thermostatic valves replaced and preset.

Heating curve: 55 °C flow at -12 °C outside.