**ILLUSTRATIVE DEMO DOCUMENT · not real customer data**

# Hydraulic balancing protocol, 03/2023

Customer D-B03 · Hamburg area (21xxx)

Heating system: two-pipe (Zweirohrsystem).

All 15 thermostatic valves replaced and preset; hydraulic balancing done.

Heating curve: 55 °C flow at -12 °C outside.