

INORGANIC ANALYSIS REPORT



0013

Earth4Earth Technology Ltd
85 Great Portland Street
London
W1W 7LT

FAO: Ms. Anna Simmons

Report of Tests on: Cabon Capture Brick L10

Your Reference: 20250002

Lucideon Reference: N26730 - 2

Date Reported: 24-Mar-2026

Order Number:

Proforma Invoice PO-0004

Date Logged: 20-Feb-2026

Date(s) of Test(s):

18-Mar-2026 to 23-Mar-2026

Determination of Soluble Salts

C254 BSEN772-5: 2016 with ICP Finish

Result(s)		Units	
Active Magnesium	Mg ²⁺	%	<0.005
Active Sodium	Na ⁺	%	0.013
Active Potassium	K ⁺	%	0.017
Sodium + Potassium	Na ⁺ + K ⁺	%	0.03
Water Soluble Magnesium	Mg ²⁺	%	<0.01
Classification Category			S2
Sulphate, Water Soluble	SO ₄	%	0.01
Mean of Duplicate Determinations			No
Sample Basis			Dried 105 deg C
Sample Preparation Procedure:			C21
UKAS Accredited			Yes

Sulphate has been measured on the same BSEN772-5 prepared extract solution, but it is outside the scope of the standard.

Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.

End of Test Report

Mrs Julie Thornett
Manager

This report is issued in accordance with the Conditions of Business of Lucideon Limited and relates only to the sample(s) tested. No responsibility is taken for the accuracy of the sampling unless this is done under our own supervision. This report shall not be reproduced in part without the written approval of Lucideon Limited, nor used in any way as to lead to misrepresentation of the results or their implications.

Lucideon is the trading name of Lucideon Limited. Registered in England No. 1960455.