













Wuhan Photography Boards: requirement against final design

The proposal asks for nine panels, each 1.5 m × 1.5 m *or similar convenient size for brick layout*, all based on a 215 × 65 mm slip. Every board below is dimensioned to close on whole and half slips at its own joint width, so the sizes differ from 1.5 m and from each other. Joint widths are noted only where they changed.

#	PROPOSAL REQUIREMENT	PROPOSAL MOCK-UP	OUR FINAL DESIGN	ACTUAL SIZE AND CHANGES
01	Standard stretcher, one row of vertically stacked 215 x 65 slips Wall · Sleek finish 10 mm joint, warm white, approx RAL 1013			1565 × 1490 mm 148 slips, 2 brick types, none cut.
02	Standard stretcher Floor · Raw finish 10 mm joint, warm white, approx RAL 1013			1452.5 × 1490 mm 140 slips, 2 brick types, none cut.
03	Herringbone, one border of 102 x 65 slips Floor · Sleek finish 10 mm joint, warm white, approx RAL 1013			1500 × 1401.5 mm 166 slips, 5 brick types, 52 cut.

#	PROPOSAL REQUIREMENT	PROPOSAL MOCK-UP	OUR FINAL DESIGN	ACTUAL SIZE AND CHANGES
04	Standard stretcher, brick end border top and bottom, 65 x 102 slip size Wall · Sleek finish 7 mm joint, warm grey white, RAL 9001			1436 × 1517 mm 185 slips, 2 brick types, none cut.
05	Herringbone, straight edge Floor · Sleek finish 7 mm joint, warm grey white, RAL 9001			1565 × 1415 mm Joint width changed from 7 mm to 10 mm. A herringbone closes only when three courses of the module equal one slip and one joint, $3 \times (65 + J) = 215 + J$, so $J = 10$. Laid at 7 mm the field carried 126 joints off width. 145 slips, 3 brick types, 24 cut.
06	Basketweave Floor · Raw finish 7 mm joint, warm grey white, RAL 9001			1565 × 1565 mm Joint width changed from 7 mm to 10 mm. Basketweave blocks must stay square: three slips plus two joints has to equal one slip, $3 \times 65 + 2 \times 10 = 215$, which holds at 10 mm and not at 7 mm. 147 slips, 1 brick type, none cut.

#	PROPOSAL REQUIREMENT	PROPOSAL MOCK-UP	OUR FINAL DESIGN	ACTUAL SIZE AND CHANGES
07	Running bond Wall · Sleek finish 5 mm joint, natural mortar colour			1535 × 1465 mm 157 slips, 2 brick types, none cut.
08	Triple herringbone with two brick border Floor · Sleek finish 5 mm joint, neutral white mortar			1572.5 × 1572.5 mm Joint width changed from 5 mm to 10 mm. The 45 degree weave inside a two-slip border needs that same square block, 3 x 65 + 2J = 215. At 5 mm it is 10 mm out and 46 joints closed up, some to slips touching. 172 slips, 5 brick types, 52 cut.
09	Horizontal stack Floor · Raw finish 3 mm joint, neutral white mortar			1523 × 1493 mm 154 slips, 1 brick type, none cut.