WEEK 6 ASSIGNMENT

-BY PRATHYUSHA RAVICHANDRAN

QUESTION 1

Considering the same example you solved in the previous assignment (radiative heat transfer between two parallel plates), how many shields with epsilon = 0.1 should you add in order to have the new heat transfer rate to be 1% of the case without shields?

ANSWER:

From the previous assignment
Q_{12} = 1035.81 W/m^2
$Q_{12\ N\_shield}$ = 10.3581 W/m^2
We need to calculate N

$Q_{12\ N\_shield}$ = 1/ (N+1) Q_{12}
10.3581 = 1/ (N+1) 1035.81
10.3581/1035.81 = 1/ (N+1)
0.01 = 1/ (N+1)
100 = N+1
99 = N

Hence, we need **99 shields** in order to have the new heat transfer to be 1% of the case without shields

QUESTION 2

Create a pdf file with screenshots of all of the steps we went through and explain briefly the reason behind the use of each step.

ANSWER:

Creating an office plan of 30mx40m.

Using the 'create space from diagram' tool to give height for each floors and to specify the number of floors.

Using the 'info' tool to give us information about the sun, wind, boundary conditions etc. E.g., placing the cursor on the roof will tell us that wind and sun are exposed but if we place the cursor on the base of the building, it will tell us no sun and wind exposed.

For roof

For base

Using the 'surface matching' tool to match the surfaces so it is easier to create windows.

Creating windows using the 'set window to wall ratio' tool by giving the window height and sill height.

Using the 'search surfaces' tool to filter out the surface we need to provide shading (in this exercise). Assuming there is no harsh sun in the North façade, we exclude that by typing 90° to 360° in the dialog box


Using the 'add overhangs by projection factor' tool to provide sun shades for the windows by inputting the width of the projection.

Overhangs are not seen in the north facade.

Using the 'set attributes for the selected spaces' tool to provide thermal zones for each spaces. In this case open office for the rooms facing outside and break room for the rooms facing inside

After, we run the data, we arrive at the result of the energy consumption like annual overview of the consumption, monthly overview, monthly bills, lighting consumptions, plug point consumption, exterior lighting, equipment consumption(if we have loaded any), water consumption, air loops detail, cash flow etc.