

Project Memo



DLR Group inc.
an Arizona corporation
6225 North 24th Street, Suite 250
Phoenix, AZ 85016

Date September 20, 2024

To Ryan Companies

From Charlie Carroll

Project Project Yellow Jacket

Log No.

Subject Addendum 4

Message

REVISION ITEMS

ARCHITECTURAL

- A1.1
 - 1. Add chain link cages per Composite 1.0
 - 2. Relocated MDPs per coordination from Amazon
 - 3. Relocated stairs at the PID platform per Amazon direction
- A1.1A
 - 1. Add chain link cages per Composite 1.0
 - 2. Relocated an MDP per Amazon direction
 - 3. Relocated stairs at the PID platform per Amazon direction
- A1.1B
 - 1. Relocated an MDP per Amazon direction
- A1.1C
 - 1. Add chain link cages per Composite 1.0
- A1.1D
 - 1. Add chain link cages per Composite 1.0
 - 2. Relocated an MDP per Amazon direction
 - 3. Relocated stairs and the VRC at the PID platform per Amazon direction
- A1.1F
 - 1. Add chain link cages per Composite 1.0
- A2.09
 - 1. Revised PID Platform stairs and VRC per Amazon direction
- A7.3
 - 1. Revised stair plans and sections per Amazon direction
- A8.2B
 - 1. Added chain link gate information

- 10.1
 1. Updated PID Platform elevations per new stair and VRC configuration

FIRE PROTECTION

- FP401
 1. Reconfigured fire pump suction line and orientation of backflow preventer per coordination with sprinkler contractor
 2. Updated "Fire Pump Room Equipment List" to include missing information
 3. Added note for OS&Y in vertical alignment to coordinate with backflow preventer update

ELECTRICAL

- E1.10
 1. Updated and revised IDF cabinet locations
- E1.11 thru E1.16
 1. Updated power plan per Composite 1.0
- E3.00
 1. Coordinated power with Composite 1.0
 2. Moved panels to coordinate with modules
- E3.10P
 1. Updated power per Composite 1.0
- E3.11P
 1. Updated power per Composite 1.0
- E3.12P
 1. Updated power per Composite 1.0
- E4.01
 1. Deleted battery charger panel
 2. Revised DB-GEN per RFI
- E4.04
 1. Updated load calculations
- E5.01 thru E5.05
 1. Updated panels per Composite 1.0

SPECIFICATIONS

- The following sections were updated in addendum 2 but are being revised back to their original state as issued with the 100%/Permit Set. The addendum 2 revisions for these spec sections should be disregarded.
 1. 220000
 2. 230000
 3. 230548
 4. 238128
 5. 260000
 6. 260519
 7. 260520
 8. 260526
 9. 260534
 10. 260923
 11. 262200
 12. 262413
 13. 262726
 14. 262816
 15. 263213
 16. 264113
 17. 264313
 18. 265100

A
Name Charlie Carroll
cc