










Sheet: /
File: heating-controller.kicad_sch


Title:


Size: A4	Date:	**Rev:**
KiCad E.D.A. 10.0.7		Id: 1/4


POWER + MCU. USB-C is the only supply and programmer (native USB-Serial-JTAG on IO12/IO13). Relay drives on IO21/22/23/3 only. Strapping: IO8 high (LED pull-up), IO9 BOOT, IO15 LED pull-up.

































OLED header: JP1/JP2 select pin-1/2 order (GND,VCC default). JP3 selects OLED VCC 3V3 (default) or 5V. Qwiic = GND,3V3,SDA,SCL.


























Sheet: /Power + MCU/
File: power_mcu.kicad_sch

Title:

Size: A3 | Date: | **Rev:**
KiCad E.D.A. 10.0.7 | Id: 2/4

OPENTHERM MASTER ADAPTER (Ihor Melnyk topology). Bus is boiler-powered SELV, polarity independent. OT_OUT high -> U201 on -> extra bus current (TX). Boiler voltage high -> D206 conducts




Sheet: /OpenTherm/
File: opentherm.kicad_sch


Title:

Size: A4 | Date: | **Rev:**
KiCad E.D.A. 10.0.7 | Id: 3/4

MAINS IO. Relays K101–K104 switch MAINS_L to NO; link L–COM with a wire in the terminal for switched–live, or leave open for volt–free. K104 DNP. Gate pull–downs keep every relay OFF through reset/brownout.



230V SENSE INPUTS: 6 x 22k 1206 chain (~1.7mA, ~420V impulse per part) –> LTV–817S LED with antiparallel diode. Output is ACTIVE–LOW when live present (inverted: true in ESPHome). ES1–3 return via MAINS_N. DEMAND: use 230V or 24V input with its own RET. MAINS_OK senses board L.



Sheet: /Mains IO/		
File: mains_io.kicad_sch		
Title:		
Size: A3	Date:	**Rev:**
KiCad E.D.A. 10.0.7		Id: 4/4