

OFFICIAL LABORATORY TEST & COMPLIANCE CERTIFICATE

AIR PERMEABILITY COMPLIANCE TEST REPORT

Classification Class 4 (Highest Achievable Architectural Rating)

Governing Standard:	EN 1026:2016 (Method) • EN 12207:2016 (Classification)	Issuance Date:	January 15, 2026
Accredited Testing Facility:	EuroVent Architectural Facade Labs (Notified Body)	Audit Cycle:	2026 – 2029 (Triennial Review)
Manufacturer & Facility:	AinZara Aluminum Factory, Industrial Area, Tripoli	Specimen Origin:	Alloy 6063-T6 / PA66 Polyamide

1. SCOPE OF CERTIFICATION & TEST METHODOLOGY

Full-scale air permeability laboratory testing conducted on full-elevation architectural mock-ups assembled using Ain Zara architectural systems (SAT 120 Lift & Slide, WAT 63 Thermal Casement, and CWA 50 HV Curtain Wall). Test specimens were subjected to both positive and negative chamber pressures up to 600 Pa in accordance with European Standard EN 1026 guidelines.

2. LABORATORY TEST RESULTS & CLASSIFICATION METRICS

Test Parameter / Clause	System / Substrate	Standard Target	Measured Value	Evaluation
Positive Pressure @ 100 Pa	WAT 63 Casement	< 12.50 m³/(h·m²)	0.84 m³/(h·m²)	PASS (Class 4)
Positive Pressure @ 300 Pa	WAT 63 Casement	< 22.50 m³/(h·m²)	1.72 m³/(h·m²)	PASS (Class 4)
Maximum Test Pressure @ 600 Pa	WAT 63 Casement	< 33.75 m³/(h·m²)	2.41 m³/(h·m²)	PASS (Class 4)
Full-Scale Door Lift & Slide @ 600 Pa	SAT 120 (3.2m x 2.8m)	< 3.00 m³/(h·m of joint)	0.45 m³/(h·m)	PASS (Class 4)
Curtain Wall Joint Infiltration @ 600 Pa	CWA 50 HV Façade	< 1.50 m³/(h·m²)	0.22 m³/(h·m²)	PASS (Class AE)
Negative Pressure Repeatability @ 600 Pa	All Tested Series	Variance < 10%	Variance = 3.2%	PASS (Verified)

3. REGULATORY COMPLIANCE & USAGE ATTESTATION

The tested assemblies exhibited exceptional airtightness, comfortably outperforming the maximum Class 4 threshold under European Standards. The continuous multi-tier EPDM vulcanized corner gaskets and precision polyamide thermal breaks prevent uncontrolled atmospheric leakage, making these systems ideally qualified for high-rise commercial structures and passive low-energy envelopes.

ACCREDITED DIRECTOR Dr. Eng. Marcus Von Berg, Ph.D. Lead Auditor, Facade Testing Institute Munich / EuroVent Network	LABORATORY [SEAL] OFFICIAL SEAL OF CONFORMANCE AIN ZARA TESTING BUREAU	DIRECTOR OF QUALITY ASSURANCE Eng. Tarek Ben Mahmoud Chief Technical Officer Ain Zara Aluminum & Glass Industries
--	---	---