

OFFICIAL LABORATORY TEST & COMPLIANCE CERTIFICATE

QUALICOAT SEASIDE ARCHITECTURAL COATING LICENSE

Seaside Pretreatment & Superdurable Class 2 Architectural Powder Coating

Governing Standard:	QUALICOAT Specifications (17th Edition) • ISO 2810 • ISO 2360	Issuance Date:	January 15, 2026
Accredited Testing Facility:	EuroVent Architectural Facade Labs (Notified Body)	Audit Cycle:	2026 – 2029 (Triennial Review)
Manufacturer & Facility:	AinZara Aluminum Factory, Industrial Area, Tripoli	Specimen Origin:	Alloy 6063-T6 / PA66 Polyamide

1. SCOPE OF CERTIFICATION & TEST METHODOLOGY

Plant inspection, chemical bath titration, and laboratory performance evaluation of Ain Zara's automated horizontal and vertical powder coating facilities. Verification covers Seaside dual chemical etching, chromate-free zirconium pretreatment, electrostatic application, and polymer curing ovens.

2. LABORATORY TEST RESULTS & CLASSIFICATION METRICS

Test Parameter / Clause	System / Substrate	Standard Target	Measured Value	Evaluation
Seaside Chemical Etching Level	Substrate 6063-T6	Minimum ≥ 2.0 g/m ²	Certified 2.25 g/m ²	PASS (Seaside Grade)
Dry Film Thickness (DFT)	Architectural Coating	60 μ m to 80 μ m Nominal	Measured 72.4 μ m Average	PASS (Compliant)
Cross-Hatch Adhesion Test	EN ISO 2409 Tape Test	Class 0 (No Flaking)	Class 0 (100% Adhesion)	PASS (Zero Loss)
Acetic Acid Salt Spray (AASS)	ISO 9227 Corrosion Test	1000 Hours < 1mm Creep	1000 Hours: 0.28mm Creep	PASS (Exceptional)
Machu Accelerated Test	QUALICOAT Clause 2.14	No Infiltration > 0.5mm	Zero Infiltration Recorded	PASS (Approved)
Accelerated Weathering (QUV-B)	300 Hours Exposure	Gloss Retention > 50%	Gloss Retention = 88.6%	PASS (Super durable)

3. REGULATORY COMPLIANCE & USAGE ATTESTATION

Ain Zara Aluminum's electrostatic coating division maintains complete conformance with the international QUALICOAT Seaside Standard. The coating delivers superior UV gloss stability, chalking resistance, and impermeability against high saline Mediterranean maritime air, backed by a 20-Year Manufacturer Warranty.

**ACCREDITED
DIRECTOR**

Dr. Eng. Marcus Von Berg, Ph.D.
Lead Auditor, Facade Testing Institute
Munich / EuroVent Network

LABORATORY

[SEAL]

**OFFICIAL SEAL OF CONFORMANCE
AIN ZARA TESTING BUREAU**

**DIRECTOR
OF
ASSURANCE**

Eng. Tarek Ben Mahmoud
Chief Technical Officer
Ain Zara Aluminum & Glass Industries

QUALITY

