

OFFICIAL LABORATORY TEST & COMPLIANCE CERTIFICATE

STATIC WATER TIGHTNESS LABORATORY CERTIFICATE

Classification Class 9A / Class E1200 (600 Pa – 1200 Pa Uncontrolled Spray)

Governing Standard:	EN 1027:2016 (Method) • EN 12208:2016 (Classification)	Issuance Date:	January 15, 2026
Accredited Testing Facility:	EuroVent Architectural Facade Labs (Notified Body)	Audit Cycle:	2026 – 2029 (Triennial Review)
Manufacturer & Facility:	AinZara Aluminum Factory, Industrial Area, Tripoli	Specimen Origin:	Alloy 6063-T6 / PA66 Polyamide

1. SCOPE OF CERTIFICATION & TEST METHODOLOGY

Laboratory water tightness examination evaluating continuous resistance to driven rain and dynamic surface water runoff under severe static pressure differentials. Test assemblies were continuously sprayed with 2.0 L/(min·m²) of water at calibrated nozzle orientations across incremental 50 Pa to 1200 Pa steps.

2. LABORATORY TEST RESULTS & CLASSIFICATION METRICS

Test Parameter / Clause	System / Substrate	Standard Target	Measured Value	Evaluation
Spraying @ 0 Pa (15 minutes)	WAT 63 & SAT 120	No Water Penetration	Zero Moisture Ingress	PASS (1A)
Spraying @ 300 Pa (5 minutes)	WAT 63 Casement	No Water Penetration	Zero Ingress Recorded	PASS (7A)
Spraying @ 600 Pa (5 minutes)	WAT 63 & SAT 120	No Water Penetration	Zero Ingress Recorded	PASS (Class 9A)
Extended Pressure @ 900 Pa (5 minutes)	CWA 50 SG Façade	No Water Penetration	Complete Drainage Flow	PASS (Class E900)
Extreme Pressure @ 1200 Pa (5 minutes)	CWA 50 HV / SA 65	No Water Penetration	Internal Channels Dry	PASS (Class E1200)
Internal Condensation Drainage Check	All Extrusions	100% Gravity Evacuation	Instant Drainage Verified	PASS (Optimal)

3. REGULATORY COMPLIANCE & USAGE ATTESTATION

The patented internal multi-chamber stepped drainage channels and EPDM pressure equalization seals prevent water ingress up to 1200 Pa. Ain Zara systems meet the most stringent hurricane and maritime building codes, preventing moisture infiltration into conditioned interior structural envelopes.

ACCREDITED LABORATORY
DIRECTOR
Dr. Eng. Marcus Von Berg, Ph.D.
Lead Auditor, Facade Testing Institute
Munich / EuroVent Network

[SEAL]
OFFICIAL SEAL OF CONFORMANCE
AIN ZARA TESTING BUREAU

DIRECTOR OF QUALITY
ASSURANCE
Eng. Tarek Ben Mahmoud
Chief Technical Officer
Ain Zara Aluminum & Glass Industries