aquaCare
The Water Treatment Company

Aqua clean RO 64

Membrane Cleaning Compound

Product Benefits

- Suitable for use with polyamide thin film Composite and cellulose acetate membranes
- Effective removal of organic matter
- High level of active substance
- Powder product, cost effective and simple to apply

Principal Uses

- **Aqua Clean RO-64** has been developed for the cleaning of reverse osmosis (RO), nano-filtration (NF) and ultra-filtration membranes. Its formulation is based on an organic polymer and is most effective in removing colloidal and other organic matter.

- During normal operation,reverse osmosis and other membranes can become fouled, which greatly reduces the efficiency of the system. Deposists build up on the membrane until they cause a reduction in normalised permeate flow, increases in differential pressure and losses in salt rejection.

- The effects of fouling can lead to poor water quality, loss in production, unscheduled downtime and premature membrane replacement.A regular maintenance and cleaning programme can provide a significant return on investment by extending system run time, prevention membrane degradation, maintaining lower feed pressures and extending the membranes's life.

- **Aqua clean RO-64** shouid always be used as recom-mended by the membrane manufacturer with respect to pH, temperature ,flow rate and differential pressure.

Dosage

- **Aqua clean RO-64** cleaning solution are made up at 1.0-2.5% by volume with chlorine-free product water and sodium hydroxide addition to give a pH of 10.5-11.5. It is recommended that warm cleaning solutions be used within the limits imposed by the

membrane manufacturers.This temperature will determine the maximum cleaning pH.
The dura**tion** of the cleaning cycla depends on the quantity and nature of the fouling although a cleaning period of 2-4 hours may be typical an extended overnigst soaking prriod may be necessary in the case of heavy fouling short periods of recirculation and soaking (-15 minute change over) are considered good practice for heavily fouled membranes.

On completion of the cleaning process, it is recom-mended that the membranes be rinsed with good quality water to remove any residual **Aqua clean RO-64** .When returning the plant to service, the product water should be discarded for the first 15-20 minutes or as long as necessary to ensure it is free of the cleaning solution.

Handling

May cause irritation to skin and eyes. Avoid contact with eyes.

Avoid prolonged or repeated contact with skin. Avoid breathing

dust. Do not take internally

In case of contact :

Skin - wash with soap and water.

Eyes - immediately irrigate with copious amounts of water for at least 15 minutes and seek medical advice.

Clothing - remove and wash before reuse.

Storage

- Drums should be stored in a dry area. Replace lid after use.
- Suggested in-plant storage limit is Two (02) year.

Remarks

If you need assistance or information, please contact your nearest Aqua Care representative.
