Acorn Enhanced Expansion Card Specification

(formerly Acorn expansion card specification)

Acorn Enhanced Expansion Card Specification

Copyright © 1994 Acorn Computers Limited. All rights reserved.

Published by Acorn Computers Technical Publications Department.

No part of this publication may be reproduced or transmitted, in any form or by any means, electronic, mechanical, photocopying, recording orotherwise, or stored in any retrieval system of any nature, without the written permission of

the single Eurocard dimension only – double Eurocards will not fit. All expansion cards fitted to the Risc PC should include an EMC gasket where required, fitted inside the rear panel. The EMC gasket should be as detailed in the section entitled *EMC design*ing

and D. The slowest cycle type is A and the quickest is D – cycle types B and C fall in-between. Data can be

Acorn Ennanced Expansion Card					
drive the					

must be installed to improve the ventilation, if not already

byte of the ECId. In this way the operating system can quickly find which expansion card is generating the interrupt.

If the expansion card contains paged ROM, these status bits may be located elsewhere in the expansion card address space, in which case the two bits in the ECId low byte should be zeros. The location of these status bits must appear in the ROM space above the extended ECId

If an expansion card is not capable of generating either a $\overline{\text{PIRQ}}$

paged) ROM into main memory, and as such is capable of updating the page register as required. There may be

Figure 3: ExtenS86 MeCl

Figure 7: Stretched expansion card read cycle






Figure 10: Medium cycle read







REF8M


IORQ (A)

IOGT

PS

BD[0:15]

LA[2:15]



REF8M

IORQ (A)

A MEMC I/O cycle is shown in Figure 18 below. The cycle starts with

Safety

The current industry wide IT safety standard is IEC950 whose European 'harmonised' version is EN60950 / BS7002, but your particular application may also be within the scope of other additional standards.

The main requirements are that the equipment provide protection against:

- · the spread of fire
- hazardous voltages or energy.

The spread of fire

The Underwriters Laboratory (UL) of the USA have



DMA Extended Bus Interface

Description of signals

The following table shows the complete pin-out of the Acorn enhanced expansion bus. The DEBI specific



DMA Extended Bus Interface

DMA access timings

The DMA access timings for Cycle types A, B, C, and D are as follows:

Table 4: DMA access timings

Sym.	Description	Cycles	Min	Тур	Max	Units
tO	CLK16 clock cycle	all		62.5		ns
t1	Clock low to DACK low	all	0		20	ns
t2	Clock low to TC high	all	0		20	ns
t3	DACK strobe width	Α	427			ns
		В	302			ns
		С	175			ns
		D	115			ns

Reader's Comment Form

Acorn Enhanced Expansion Card Specification (Issue 5)