

Minipillar Code	OR65
Manuf Serial Number	y5h8
Minipillar Type	None
Subtype CD	gssa
Substation Number	25
Feeder Number	251
Circuits Number	25
Used Circuits Number	25
Sub Minipillar	None
Manufacturer Code	fcc5
Manufacturer Year	gf5h
Entrance is free of obstacles	no
Ensure the Equipment Grounding	no
Rusted Earthing Connection	yes
Availability of No/Dang. Signs/Mono	no
Substation Cleanless	yes
Equipment Level	yes
Check for burnt marks & Sparks	no
Check for oxidation & corrosions	yes
Check dust or foreign debris	no
Connectors & lugs	yes
Burnt or heating marks on cable	no
Urgent Issue	yes
Issue Description	Null
Serious Issue	no
Issue Description	Null
Physical condition, dent, damages	> 40

Check rust, corrosion & deterioration	10 - 20
Check paint condition	> 40
Check gaps and slots	> 40
Check locks and hinges	10 - 20
Check latching mechanism	20 - 40
Check leveling cracks or damages	10 - 20
Gaps or unblock cable entry	> 40
Galvanization on blots, nuts & screw	20 - 40
Grounding & Bounding	None
Access obstructions on Mini pillar	20 - 40
Numbering, danger signs, monogram	> 40
Maintenance Completed	10 - 20
Minor Repairs Made	None
Latitude	24.15861513597105
Longitude	47.33694847551266
Last Check	2022-02-11 19:05:18.809245
Checked By	string

*Signature*