

Ann Arbor Service Request Notification

Request Number:	271034
Complaint Code:	HYDRANT ISSUE
Description:	Hydrant issue
Problem Address:	208 West Liberty Street,
Date / Time Reported:	8/6/2014 5:20:17 PM
Service Priority:	Medium
Submitted To:	CITYWORKS_WATER, A
Prj Complete Date:	8/8/2014 5:20:00 PM
Request Number:	271034
Complaint Code:	HYDRANT ISSUE

Problem Details

Hydrant issue
THIS HYDRANT IS OUT OF SERVICE AND WILL BE DUG UP AND REPAIRED IN THE SPRING. A WORK ORDER HAS BEEN CREATED.

Caller Information

First Name	Last Name	Address	Phone	Customer Email
SEECCLICKFIX	CHRISTOPHER TAYLOR			

Questions and Answers

Call	Questions	Answers
[SRQuestionIncidentNum]	What is the hydrant issue?	Needs maintenance

Comments: By ARCGISWEBSERVICES, JOE: 8/6/2014 5:20:17 PM

Reported from SeeClickFix at the following URL <http://seeclickfix.com/issues/1226478>

Leaking

Caller: CHRISTOPHER TAYLOR, SEECCLICKFIX:

Q: What is the hydrant issue?

A: Needs maintenance

Ann Arbor Service Request Notification

Request Number:	271865
Complaint Code:	HYDRANT ISSUE
Description:	Hydrant issue
Problem Address:	100-198 East Ann Street,
Date / Time Reported:	8/29/2014 1:20:17 PM
Service Priority:	Medium
Submitted To:	CITYWORKS_WATER, A
Prj Complete Date:	8/31/2014 1:20:00 PM
Request Number:	271865
Complaint Code:	HYDRANT ISSUE

Problem Details

Hydrant issue
 PSI 80 9/12/14
 DM, MA, KM
 2288,3813 NOTHING WAS WRONG.

Caller Information

First Name	Last Name	Address	Phone	Customer Email
SEECCLICKFIX	RYAN STANTON			

Questions and Answers

Call	Questions	Answers
[SRQuestionIncidentNum]	What is the hydrant issue?	Needs maintenance

Comments: By ARCGISWEBSERVICES, JOE: 8/29/2014 1:20:17 PM
 Reported from SeeClickFix at the following URL <http://seeclickfix.com/issues/1262174>
 Media URL: http://seeclickfix.com/files/issue_images/0023/5350/1409332305283.jpg
 Leaking fire hydrant at Main and Ann
 Caller: RYAN STANTON, SEECCLICKFIX:
 Q: What is the hydrant issue?
 A: Needs maintenance

Ann Arbor Service Request Notification

Request Number:	275565
Complaint Code:	HYDRANT ISSUE
Description:	Hydrant issue
Problem Address:	3248-3332 Birch Hollow Drive,
Date / Time Reported:	11/24/2014 8:41:20 AM
Service Priority:	Medium
Submitted To:	CITYWORKS_WATER, A
Prj Complete Date:	11/26/2014 8:41:00 AM
Request Number:	275565
Complaint Code:	HYDRANT ISSUE

Problem Details

Hydrant issue
Hydrant has been repaired.

Caller Information

First Name	Last Name	Address	Phone	Customer Email
SEECCLICKFIX	MILL CREEK TOWNHOMES			MC1PROPMGR@VILLAGEGREEN.COM

Questions and Answers

Call	Questions	Answers
[SRQuestionIncidentNum]	What is the hydrant issue?	Other (Use comments section)

Comments: By ARCGISWEBSERVICES, JOE: 11/24/2014 8:41:41 AM
 Reported from SeeClickFix at the following URL <http://seeclickfix.com/issues/1374042>
 Media URL: http://seeclickfix.com/files/issue_images/0026/1747/1416836199417.jpg
 Was knocked off base
 Caller: MILL CREEK TOWNHOMES, SEECCLICKFIX:
 Q: What is the hydrant issue?
 A: Other (Use comments section)

Ann Arbor Service Request Notification

Request Number:	273233
Complaint Code:	HYDRANT ISSUE
Description:	Hydrant issue
Problem Address:	258-272 Eighth St.
Date / Time Reported:	9/27/2014 1:50:24 PM
Service Priority:	Medium
Submitted To:	CITYWORKS WATER, A
Prj Complete Date:	9/29/2014 1:50:00 PM
Request Number:	273233
Complaint Code:	HYDRANT ISSUE

Problem Details

Hydrant meter no-no

Caller Information

First Name	Last Name	Address	Phone	Customer Email
SECLICKFIX	DT			

Questions and Answers

Call	Questions	Answers
[SRQuestionIncidentNum]	What is the hydrant issue?	Other (Use comments section)

Comments: By ARCGISWEBSERVICES, JOE: 9/27/2014 1:50:24 PM
 Reported from SeeClickFix at the following URL <http://seeclickfix.com/issues/1300358>
 Media URL:
http://seeclickfix.com/files/issue_images/0024/4785/20140927_134500-1.jpg
 Unprotected hydrant meter on 8th Street at waterworks park from construction operation
 Caller: DT, SECLICKFIX:
 Q: What is the hydrant issue?
 A: Other (Use comments section)
 By Fuller, LaTwana: 9/30/2014 2:55:14 PM
 HYDRANT METER REMOVED 9/29/14.

Ann Arbor Service Request Notification

Request Number:	280020
Complaint Code:	HYDRANT ISSUE
Description:	Hydrant issue
Problem Address:	2018 Chaucer Drive,
Date / Time Reported:	3/10/2015 6:20:43 PM
Service Priority:	Medium
Submitted To:	CITYWORKS_WATER, A
Prj Complete Date:	3/12/2015 6:20:43 PM
Request Number:	280020
Complaint Code:	HYDRANT ISSUE

Problem Details

Hydrant issue

Caller Information

First Name	Last Name	Address	Phone	Customer Email
SEECCLICKFIX	ANN			

Questions and Answers

Call	Questions	Answers
[SRQuestionIncidentNum]	What is the hydrant issue?	Needs maintenance

Comments: By ARCGISWEBSERVICES, JOE: 3/10/2015 6:20:43 PM
 Reported from SeeClickFix at the following URL <http://seeclickfix.com/issues/1522293>
 Leaking a steady stream of water coming from hose connection.
 Caller: ANN, SEECCLICKFIX:
 Q: What is the hydrant issue?
 A: Needs maintenance
 By Wooden, Daniel: 3/17/2015 1:29:48 PM
 duplicate request

Ann Arbor Service Request Notification

Request Number:	280099
Complaint Code:	HYDRANT ISSUE
Description:	Hydrant issue
Problem Address:	Chaucer Dr & Scio Church Rd,
Date / Time Reported:	3/12/2015 9:38:10 AM
Service Priority:	Medium
Submitted To:	CITYWORKS WATER, A
Prj Complete Date:	3/14/2015 9:38:10 AM
Request Number:	280099
Complaint Code:	HYDRANT ISSUE

Problem Details

Caller Information

First Name	Last Name	Address	Phone	Customer Email
	UNKNOWN			

Questions and Answers

Call	Questions	Answers
[SRQuestionIncidentNum]	What is the hydrant issue?	Other (Use comments section)

Comments: By SCHLAK, RENEE: 3/12/2015 9:38:10 AM
per resident there is a hyndrant on the corner at this location that is spouting water. he stated they tried to tighten it as best they could with their hands but still leaking.

called Dan---he will head over there to see waht is going on

Caller: UNKNOWN, :

Q: What is the hydrant issue?

A: Other (Use comments section)

By Wooden, Daniel: 3/17/2015 1:28:11 PM

closed hyd valve leak stopped

Ann Arbor Service Request Notification

Request Number:	281053
Complaint Code:	HYDRANT ISSUE
Description:	Hydrant issue
Problem Address:	101-199 North 4th Avenue,
Date / Time Reported:	4/2/2015 1:10:21 PM
Service Priority:	Medium
Submitted To:	CITYWORKS_WATER, A
Prj Complete Date:	4/4/2015 1:10:21 PM
Request Number:	281053
Complaint Code:	HYDRANT ISSUE

Problem Details

Hydrant issue

Caller Information

First Name	Last Name	Address	Phone	Customer Email
SEECCLICKFIX	KEVIN			HOWARDK@EWASHTENAW.ORG

Questions and Answers

Call	Questions	Answers
[SRQuestionIncidentNum]	What is the hydrant issue?	Needs maintenance

Comments: By ARCGISWEBSERVICES, JOE: 4/2/2015 1:10:21 PM
 Reported from SeeClickFix at the following URL <http://seeclickfix.com/issues/1569099>
 Media URL:
http://seeclickfix.com/files/issue_images/0030/6950/20150402_120029_1_.jpg Outlet fitting broken off. Needs painting, too.
 Caller: KEVIN, SEECCLICKFIX:
 Q: What is the hydrant issue?
 A: Needs maintenance
 By Wooden, Daniel: 4/17/2015 9:34:09 AM
 to scf: a work order for repair has been created

Ann Arbor Service Request Notification

Request Number:	281166
Complaint Code:	HYDRANT ISSUE
Description:	Hydrant issue
Problem Address:	Stadium and Baldwin nw corner,
Date / Time Reported:	4/6/2015 9:20:51 AM
Service Priority:	Medium
Submitted To:	CITYWORKS_WATER, A
Prj Complete Date:	4/8/2015 9:20:51 AM
Request Number:	281166
Complaint Code:	HYDRANT ISSUE

Problem Details

Hydrant issue

Caller Information

First Name	Last Name	Address	Phone	Customer Email
SEECCLICKFIX	SDPOWERSUP			

Questions and Answers

Call	Questions	Answers
[SRQuestionIncidentNum]	What is the hydrant issue?	Needs maintenance

Comments: By ARCGISWEBSERVICES, JOE: 4/6/2015 9:20:51 AM
 Reported from SeeClickFix at the following URL <http://seeclickfix.com/issues/1573016>
 Leaking
 Caller: SDPOWERSUP, SEECCLICKFIX:
 Q: What is the hydrant issue?
 A: Needs maintenance
 By Cozart, Mark: 4/6/2015 12:59:13 PM
 Leak stopped