PUMP P-204 INSPECTION REPORT (SYNTHETIC DEMO)

Equipment: Centrifugal Pump P-204

Inspection Date: 2026-01-15 (Demo Date)

Observed Vibration: 4.8 mm/s RMS (synthetic value)

Temperature: 62 C (synthetic value)

Inspection finding: elevated vibration detected.

Recommended action: monitor trend and schedule seal inspection.

This document is synthetic demonstration content for SIH26117.

NOT real MRPL operational data.