ETP and STP Observership Report

Kanidi Biotech LLP, Greater Noida

Prepared by AADVWAYA PASSI

Table of Contents

Introduction ***2***

ETP and STP ***2***

Plant Capacity ***2***

What I Observed ***2***

Reuse of Water ***2***

What I Learned ***2***

Conclusion ***2***

Introduction

During my visit to Kanidi Biotech LLP, I learned how wastewater is treated before it is used again. The plant has two systems: an Effluent Treatment Plant, called ETP, and a Sewage Treatment Plant, called STP.

ETP and STP

The ETP treats wastewater coming from the manufacturing and production process. It has a capacity of 15 KLD. The treated water from the ETP is used for flushing in the washrooms.

The STP treats domestic sewage from the premises. It has a capacity of 10 KLD. The water treated in the STP is used for horticulture and gardening in the plant's green areas.

Plant Capacity

The monthly use of both treatment plants is given below.

Parameter	ETP	STP
Designed capacity	15 KLD	10 KLD
Monthly volume treated	63 KL	180 KL
Average daily load (over 30 days)	~2.1 KLD	~6.0 KLD
Capacity utilisation	~14%	~60%

What I Observed

Both plants together treat around 243 KL of wastewater every month. The ETP treats around 63 KL in a month, so it uses around 14% of its total capacity. The STP treats around 180 KL in a month and works at around 60% of its capacity.

Reuse of Water

The treated water is not wasted. ETP water is used for flushing, and STP water is used for gardening. This reduces the use of fresh water at the plant and helps keep the surroundings green.

What I Learned

I learned that factory wastewater and domestic sewage are treated separately because they are different. I also learned that treated water can be used again for work like flushing and gardening instead of using fresh water every time.

Conclusion

The ETP and STP at Kanidi Biotech LLP help the plant save water and manage wastewater properly. This is a simple but important step towards keeping the plant clean and environment-friendly.