

**BHUSAWAL DIVISION-S AND T/CENTRAL RLY
TENDER DOCUMENT**

Tender No: BSL-N-SNT-04-2026-27

Closing Date/Time: 19/06/2026 15:00

Sr DSTE acting for and on behalf of The President of India invites E-Tenders against Tender No **BSL-N-SNT-04-2026-27** Closing Date/Time 19/06/2026 15:00 Hrs. Bidders will be able to submit their original/revised bids upto closing date and time only. Manual offers are not allowed against this tender, and any such manual offer received shall be ignored.

1. NIT HEADER

Name of Work	Improving Reliability of Power supply by augmenting existing Power Supply with additional IPS along with Automatic changeovers in BSL-BD section) on BSL division		
Bidding type	Normal Tender		
Tender Type	Open	Bidding System	Single Packet System
Tender Closing Date Time	19/06/2026 15:00	Date Time Of Uploading Tender	27/05/2026 17:44
Pre-Bid Conference Required	No	Pre-Bid Conference Date Time	Not Applicable
Advertised Value	80628631.50	Tendering Section	S AND T
Bidding Style	[Decision at Schedule level]	Bidding Unit	
Earnest Money (Rs.)	1612600.00	Validity of Offer (Days)	60
Tender Doc. Cost (Rs.)	0.00	Period of Completion	6 Months
Contract Type	Works - General	Contract Category	Expenditure
Bidding Start Date	05/06/2026		
Are JV allowed to bid	No	Number of JV Member Allowed	0
Are Consortium allowed to bid	No	Number of Consortium Member Allowed	0
Ranking Order For Bids	Lowest to Highest	Expenditure Type	Combined (Revenue + Capital Works)

2. SCHEDULE

S.No.	Item Code	Item Qty	Qty Unit	Unit Rate	Basic Value	Escl.(%)	Amount	Bidding Unit
Schedule () A-Improving Reliability of Power supply by augmenting existing Power Supply with additional IPS along with Automatic changeovers in BSL-BD section) on BSL division							38710646.94	Above/ Below/Par
1	A011	10.00	Set	30325.00	303250.00	18.00	357835.00	
	Description:- Supply of Relay rack assembly complete with scaffolding, fixtures and accessories including MS Bars for fixing of relay plug board, string rods, fuse strips with bracket, 11 way Bus bars with cover and mounting brackets, runway for cable/wires, frame, base assembly etc. Siemens type & as per extant practice on C.Rly. Typical part list as per Annexure-II and Rack arrangement as per sketch no SK-727 and Rack plan as approved by Engineer in charge. (Inspection by Consignee)							
2	A012	30.00	Numbers	1217.00	36510.00	18.00	43081.80	
	Description:- Supply of Tag blocks 200/160/120 way with polycarbonate cover as per IRS S 77-2006.(Rev.1) RDSO DRG. No.SA 24751, SA 24752 & SA 24753. Requirement of each type shall be specified by Engineer-in-charge. (Inspection by Consignee)							
3	A046	50.00	Kilometre	39345.00	1967250.00	18.00	2321355.00	
	Description:- Supply of PVC flexible copper cable single core, multistrand 1x2.5 Sq.mm (50 conductor each diameter 0.25 +/- 0.01) as per IS 694/2010. with latest amendment if any with insulation thickness of 0.70 mm nominal conductor resistance 7.98 ohms/km and test parameters are as per IRS (S) 76/89 (Amd.3)or latest. (Inspection by RDSO)							
4	A047	15.00	Kilometre	76141.00	1142115.00	18.00	1347695.70	
	Description:- Supply of PVC flexible copper cable single core, multistrand 1x6 Sq.mm (84 conductor each diameter 0.30 +/- 0.01) as per IS 694/2010. with latest amendment if any with insulation thickness of 0.80 mm nominal conductor resistance 3.30 ohms/km and test parameters are as per IRS (S) 76/89 (Amd.3)or latest. (Inspection by RDSO)							
5	A048	40.00	Kilometre	119222.00	4768880.00	18.00	5627278.40	
	Description:- Supply of PVC flexible copper cable single core, multistrand 1x10 Sq.mm (80 conductor each diameter 0.40 +/- 0.01) as per IS 694/2010. with latest amendment if any with insulation thickness of 1.0 mm nominal conductor resistance 1.91 ohms/km and test parameters are as per IRS (S) 76/89 (Amd.3)or latest. (Inspection by RDSO)							

**BHUSAWAL DIVISION-S AND T/CENTRAL RLY
TENDER DOCUMENT**

Tender No: BSL-N-SNT-04-2026-27

Closing Date/Time: 19/06/2026 15:00

6	A049	20.00	Kilometre	177112.00	3542240.00	18.00	4179843.20	
	Description:- Supply of PVC flexible copper cable single core, multistrand 1x16 Sq.mm (126 conductor each diameter 0.40 +/- 0.01) as per IS 2465/1984 & IS: 694/2010. with latest amendment if any with insulation thickness of 1.0mm nominal conductor resistance 1.121 ohms/km and test parameters are as per IRS (S) 76/89 (Amd.3) or latest. (Inspection by RDSO)							
7	A050	20.00	Kilometre	279653.00	5593060.00	18.00	6599810.80	
	Description:- Supply of PVC flexible copper cable single core, multistrand 1x25 Sq.mm (196 conductor each diameter 0.40 +/- 0.01) as per IS 2465/1984 & IS: 694/2010. with latest amendment if any with insulation thickness of 1.2mm nominal conductor resistance 0.780 ohms/km and test parameters are as per IRS (S) 76/89 (Amd.3) or latest. (Inspection by RDSO)							
8	A051	30.00	Kilometre	5605.00	168150.00	18.00	198417.00	
	Description:- Supply of wire 16/0.2 (Blue, Red, Grey, yellow, Brown, Black, White as per site engineer instruction) finolex/polycab/delton make. IRS:S-76/89 (Amd.3), BS: 4808 Part-2. Wire to be procured from RDSO approved vender. (Inspection by RDSO)							
9	A062	2178.00	Numbers	3755.00	8178390.00	18.00	9650500.20	
	Description:- Sealed maintenance free VRLA Battery/Cell 2 volt, 300AH IRS: S-93/96 (A) (Amd.1) or latest. (Inspection by RDSO)							
10	A067	5.00	Numbers	6571.00	32855.00	18.00	38768.90	
	Description:- Supply of Transformer 230V/110V-130V Single phase 1 KVA as per spec. IRS S-72/88 (Amd.2) with latest amendments. (Inspection by RDSO)							
11	A083	2000.00	Kg	112.00	224000.00	18.00	264320.00	
	Description:- Supply of Rubber Mat 5mm thick for use in signaling installation. (Inspection by Consignee)							
12	A085	23.00	Numbers	69806.00	1605538.00	18.00	1894534.84	
	Description:- Supply of Auto Changeover panel for 3 incoming supply single phase with manual bypass arrangement along with MCBs, switches, voltage sensing relays, fuses etc. of repute & approved make of suitable rating. The panel should be made up of 16 SWG powder coated MS sheet. General arrangement & scheme to be in line with RDSO spec. and approved by Engineer in charge and as per RDSO spec. No.TI/SPC/CLS/0023 with A & C Slip no. EN-13600 with the plated surface, or latest amendments. CAPACITY 63 Amps. (Inspection by RDSO)							
13	A200	92.00	Each Module	23147.00	2129524.00	18.00	2512838.32	
	Description:- Design, fabrication and supply of fuse Auto changeover system for 32 Nos external non detorating type fuses or 'G' type fuses from 0.6A Amp to 4A Amp capacities used in signaling circuits. System shall have 8 cards with monitoring arrangement of 4 fuses in one card. As per RDSO spec. RDSO/SPN/209/2012 Ver.2.0 or latest amendment if any. (Inspection by RDSO)							
14	A201	23.00	Each Module	33712.00	775376.00	18.00	914943.68	
	Description:- Design, fabrication and supply of fuse Auto changeover system for 24 Nos external non detorating type fuses or 'G' type fuses from 4 A to 10 Amp capacities generally used for point operation circuits. System shall have 6 cards with monitoring arrangement of 4 fuses in one card. As per RDSO spec. RDSO/SPN/209/2012 Ver.2.0 or latest amendment if any. (Inspection by RDSO)							
15	A243	2000.00	Numbers	65.00	130000.00	18.00	153400.00	
	Description:- Supply of ARA Terminal blocks with links made of PBT Specn No.IRS/75/2006 (Rev - 2) with latest amendments and RDSO Drg.No.SA-23741A Alt.4., SA-23745 Alt.5, SA-23746, SA-23748 Alt.4, & SA-23756 Alt.3. (Inspection by RDSO)							
16	A244	250.00	Numbers	144.00	36000.00	18.00	42480.00	
	Description:- Supply of cartridge fuse block made of PBT as per RDSO Drg No SA-23748 Alt 4, SA-23749 & Spec No.IRS S 75/2006 Rev.02 with latest amendment. Fuse block shall be suitable for round head type voltage fuses. (Inspection by RDSO)							
17	A245	250.00	Numbers	62.00	15500.00	18.00	18290.00	
	Description:- Supply of round head type non detorating type low voltage cartridge fuse as per specn No. IRS/S/78/92 with latest amendments - 2A/4A/6A capacity (Inspection by RDSO)							
18	A246	50.00	Numbers	30.00	1500.00	18.00	1770.00	
	Description:- Supply of Tik-tak, piano type switches, 5 A (as per IS Specification). (Inspection by Consignee)							
19	A248	50.00	Numbers	20.00	1000.00	18.00	1180.00	
	Description:- Supply of Lamp 110V / 24W, 2 pin for Location boxes .(Inspection by Consignee)							
20	A270	25.00	Set	15671.00	391775.00	18.00	462294.50	

**BHUSAWAL DIVISION-S AND T/CENTRAL RLY
TENDER DOCUMENT**

Tender No: BSL-N-SNT-04-2026-27

Closing Date/Time: 19/06/2026 15:00

	Description:- Maintenance Free Earth as per RDSO/SPN/197/2008 or latest consisting of : 1) Copper bond steel electrode 3 Mtr long 17mm dia with copper bonding thickness of min. 250micron & UL listed & marked-01 No. (2) Earth enhancement compound RDSO Approved in sealed bag of 10 kgs - 03 No. (3) Copper strip 150 x 25 x 6mm - 02 No (4) Copper Strip 300 x 25 x 6mm- 01 No (5) 35 Sqmm Copper Cable to connect earth electrode to MEEB - 15Mtr Approx. (Inspection by RDSO)							
21	A271	2000.00	Metre	365.00	730000.00	18.00	861400.00	
	Description:- Supply of 35 Sq. mm. multistrand single core PVC insulated copper for connecting earth bus bar to earth electrode. (Inspection by RDSO)							
22	A359	10000.00	Numbers	100.00	1000000.00	18.00	1180000.00	
	Description:- Supply of modular terminal block of 2.5 sq. mm 2 IN 2 OUT type disconnect type terminal along with as per RDSO SPN/189/2004 Rev 3.0. The current capacity of 16 Amps and more. The terminal should have marking at centre to view description from front. Material to be procured from RDSO approved firms only. (Inspection by RDSO)							
23	A360	60.00	Numbers	187.00	11220.00	18.00	13239.60	
	Description:- Supply of DIN Channel for the terminals 1 Mtrs each. (Inspection by Consignee)							
24	A361	200.00	Numbers	20.00	4000.00	18.00	4720.00	
	Description:- Supply of End plates for modular terminal block. (Inspection by Consignee)							
25	A362	200.00	Numbers	15.00	3000.00	18.00	3540.00	
	Description:- Supply of End Clamp for modular terminal block. (Inspection by Consignee)							
26	A363	100.00	Numbers	71.00	7100.00	18.00	8378.00	
	Description:- Supply of Marker Card as per customer spec (10x10). (Inspection by Consignee)							
27	A366	200.00	Numbers	37.00	7400.00	18.00	8732.00	
	Description:- Fuse links of (400 mA, 630mA, 1 A, 1.6 A, 2 A, 4A, 6.3 A & 10A) (Inspection by Consignee)							
S.No.	Item Code	Item Qty	Qty Unit	Unit Rate	Basic Value	Escl.(%)	Amount	Bidding Unit
Schedule () B-Improving Reliability of Power supply by augmenting existing Power Supply with additional IPS along with Automatic changeovers in BSL-BD section) on BSL division							1565216.90	Above/ Below/P ar
1	011040	10.00	Numbers	1258.00	12580.00	18.00	14844.40	
	Description:- Installation of Relay Rack Assembly including IDF pillars if any complete with wall supports, scaffolding, ladders, runway for cables, Relay/Relay group base plates, fixing of Tag blocks etc. The work shall be done as per approved plan, extant practice on C.Railways & the instructions of Rly engineer at site.							
2	011120	23.00	Lot	20768.00	477664.00	18.00	563643.52	
	Description:- Installation of LT Power panel/power distribution panel/Auto Changeover Panel, power supply equipments such as Rectifiers Transformers, Battery chargers etc., mounting of program switches on bakelite sheet of size 300 mm x 300 mm x 8 mm fitted to MS angle (size 25mm x 25mm x 5mm) brackets, wiring as per requirements. Necessary wires to be supplied by Rlys, lugs & glands to be supplied by contractor.							
3	011260	23.00	Lot	24836.00	571228.00	18.00	674049.04	
	Description:- Wiring and Charging of Integrated power supply to signalling installation. This includes connection of MF Earth of 1 ohm earth resistance for IPS and power distribution connection to bus bars and relay racks in the room with contractor's own wiring materials and fabrication and fixing of AC/DC power distribution board made on 10mm thick phenolic hylam sheets or any standard make with connections suitable for 63 A. Wiring to be done considering site requirement, depending upon the load with suitable wires, lugs & glands as per insructions of Engineer-in-charge. This item also includes supply & fixing of ladder along the wall for carrying power supply wires/cables from IPS room to Relay room/power room and potential free contact wiring at Datalogger IDF etc.							
4	011270	92.00	Each Module	537.00	49404.00	18.00	58296.72	
	Description:- Wiring, fixing & commissioning of modules of fuse 0.6 to 4 Amp rating alarm system having change over arrangement and potential free contact wiring at Datalogger IDF. Etc as per instructions of Railway Engineer. (Module of 32 nos fuses)							
5	011280	23.00	Each Module	523.00	12029.00	18.00	14194.22	
	Description:- Wiring, fixing & commissioning of modules of fuse 4 to 10 Amp rating alarm system having change over arrangement and potential free contact wiring at Datalogger IDF. Etc as per instructions of Railway Engineer. (Module of 24 nos fuses)							
6	011520	2000.00	Per Conductor	12.00	24000.00	18.00	28320.00	

**BHUSAWAL DIVISION-S AND T/CENTRAL RLY
TENDER DOCUMENT**

Tender No: BSL-N-SNT-04-2026-27

Closing Date/Time: 19/06/2026 15:00

7	Description:- Fixing of ARA Terminals and fuse blocks on phenolic laminated sheets and fixing by stainless steel/brass nuts & bolts. This includes provision of two additional holes on the board on either side for cable conductor entry.							
	011640	25.00	Set	4382.00	109550.00	18.00	129269.00	
8	Description:- Installation of unit earth as per RDSO/SPN/197/ver I or latest, to construct earthing of $\leq 1\text{ Ohm}$ consisting of a digging the earth to required depth, insertion of electrode, filling of earth enhancing compound & construction of chamber, measurement of earth value and all other work of earthing as per code of practice. All the consumables for mounting the copper tape inside the relay room, Exothermic weld materials and tools & fixtures for the welding copper tapes and Electrodes etc shall be arranged by the contractor.							
	012060	4000.00	Numbers	16.00	64000.00	18.00	75520.00	
9	Description:- Fixing of modular terminal/fuse blocks alongwith all accessories with provision of fixing holes on hylam sheets/side angles of Loc Box and fixing by galvanised nuts & bolts. This includes fixing on DIN channel alongwith PVC Comb type 'C' channel (size 2 inch x 2 inch) for cable termination of modular terminal. The PVC channel with cover to be supplied by firm as required. The work shall be done as per the instruction of Rly engineer at site.							
	012070	1000.00	Numbers	6.00	6000.00	18.00	7080.00	
9	Description:- Termination of cable cores on ARA terminal/Disconnecting link/fuse blocks, in the apparatus Cases/ cable termination rack. This includes all associated works of pulling out the cable from underground. The work shall be done as per location plans and instructions of Rly engineer at site.							
S.No.	Item Code	Item Qty	Qty Unit	Unit Rate	Basic Value	Escl.(%)	Amount	Bidding Unit
Schedule () C-Improving Reliability of Power supply by augmenting existing Power Supply with additional IPS along with Automatic changeovers in BSL-BD section) on BSL division							40352767.66	
1	1	23.00	Numbers	894612.87	20576096.01	AT Par	20576096.01	Rs.
	Description:- Supply, installation commissioning and testing of SMPS based integrated power supply with Battery set conforming to RDSO specification no.RDSO/SPN/165/2023 version 4.0withlatest amendment for Panel interlocking as per Central RailwayDrq No. SK-790/1/A with latest correction if any. scope of supply installation and commissioning of IPS shall be as per RDSO guidelines and Letter No. STS/E/IPS/Genldt:03.04.2008 or latest if any.(Inspection by RDSO)							
2	2	138.00	Numbers	45000.00	6210000.00	AT Par	6210000.00	Rs.
	Description:- Bumpless Automatic power source changeover device DC-20-150V, 45A(2 input sources) Model no. PT-RSAHL-DC-03. (Inspection by RDSO)							
3	3	138.00	Numbers	3500.00	483000.00	AT Par	483000.00	Rs.
	Description:- Installation of item Automatic changeover unit of signal/ Track /Point supply of 32A, DC consisting of 3TC44 contactors or similar , LED Lamp, Push button terminals, VSR, polarity switches.							
4	4	93.00	Numbers	45000.00	4185000.00	AT Par	4185000.00	Rs.
	Description:- Supply, installation, wiring, testing, and commissioning of Bumpless Power Supply Autochangeover device complete along with accessories using Contractor's own wiring & fixing material as per the following configuration - (i) Power Supply - AC/DC. (ii) Voltage 24V to 150V. (iii) Current Up to - 45Amp. Note: The work shall be done as per the instructions of the Railway's Engineer in-charge. (Inspection by RITES)							
5	5	6.00	Numbers	175186.73	1051120.38	AT Par	1051120.38	Rs.
	Description:- Supply of IOT device for sensing 110V DC Battery bank parameters including current and voltage transducers as per RDSO/RDPM/FRS/2021 dated 06.05.2021 or latest. (Inspection by RDSO)							
6	6	6.00	Numbers	27372.84	164237.04	AT Par	164237.04	Rs.
	Description:- Installation, Testing and Commissioning of IOT device for sensing 110V DC Battery bank parameters including current and voltage transducers as per RDSO/RDPM/FRS/2021 dated 06.05.2021 or latest							
7	7	30.00	Set	629.65	18889.44	AT Par	18889.44	Rs.
	Description:- Set of Insulated copper lugs. Set consisting of 3 items. 1)1.5 sq mm X 8 mm Lugs = 120 Nos. 2) 2.5 sq mm X 8 mm Lugs =50 Nos. 3) 6 sq mm X 8 mm Lugs = 20 Nos Accepted make/brand: CHETNA. (Inspection by Consignee)							
8	8	390.00	Numbers	2.48	966.42	AT Par	966.42	Rs.
	Description:- "Supply of Glass Fuse (5X20) mm 630 mA compatible for Electronic interlocking. Make:Unique or equivalent. (Inspection by Consignee) "							
	9	380.00	Numbers	13.74	5221.20	AT Par	5221.20	Rs.

**BHUSAWAL DIVISION-S AND T/CENTRAL RLY
TENDER DOCUMENT**

Tender No: BSL-N-SNT-04-2026-27

Closing Date/Time: 19/06/2026 15:00

9	Description:- "Supply of FAST-ACTING GLASS FUSE, RATING- 2AMP, SIZE 5 X 20 MM CONFORMING TO IEC: 60127-2. AS PER ICF SPECIFICATION NO. ICF/EDML 007, REV-B SUITABLE FOR SWITCH PLATE ASSEMBLY OF LHB EOG AC COACHES. MAKE-FERRAZ SHAWMUT, COOPER BUSSMANN, OR EQUIVALENT MAKE SHALL BE ICF/RCF/MCF APPROVED ONLY ACCEPTABLE (MATERIAL SHOULD BE PROCURED FROM OEMS OR THEIR AUTHORISED DEALERS HAVING TENDER SPECIFIC AUTHORISATION ONLY). Accepted make/brand:- Eaton Bussmann make" (Inspection by Consignee)							
10	10	11.00	Numbers	61886.19	680748.09	AT Par	680748.09	Rs.
	Description:- Supply of True RMS Industrial Logging Multimeter with trend capture Make:Fluke 289/ stanley SMM 180 orsimilar as per annexure attached inTender document (Inspection byConsignee)							
11	11	30.00	Numbers	4000.00	120000.00	AT Par	120000.00	Rs.
	Description:- "UNI-T 3.5 digit Backlit LCD Hand Held True Rms Clamp Meter Brand: UNI-T (Detailed Description/Specification as per Product # 1 of GeM Contract No. GEMC-511687785288162 dt.10/10/2024)" (Inspection by Consignee)							
12	12	8.00	Numbers	178029.41	1424235.28	AT Par	1424235.28	Rs.
	Description:- "Arrangement of battery operated rail core drill along with additional 18 mm TCT rail core drill.Maximum core cutting capacity 36mm, rated speed 250/450Z RPM, Battery type Lion, Battery voltage 50V, Battery pack capacity 4AH, Number of battery supplied- 2No. Charger-1No. Special design pressurised internal spindle cooling to give maximum life of core cutter by avoiding heating.3 sets of 22,13,16,7.1 gauge drills adapters to be provided along with the machine.weight of machine with battery-18.5 Kg Make Eibenstok, Bosch, KPTL. " (Inspection by Consignee)							
13	13	175.00	Numbers	12265.98	2146546.50	AT Par	2146546.50	Rs.
	Description:- DC-DC converter modules of IPS of various supplies/make.(As per siterequirement.) (Inspection by RDSO)							
14	14	15.00	Numbers	53152.58	797288.70	AT Par	797288.70	Rs.
	Description:- Supply of Cabinet with wiring arrangement for DC-DC converter 08 Nos. suitable for Station. (Inspection by RDSO)							
15	15	600.00	Metre	300.00	180000.00	AT Par	180000.00	Rs.
	Description:- "Supply of 110 mm Diameter PE 100 HDPE Pipe (Detailed Description/Specification as per Product # 1 of GeM Contract No. GEMC- 511687786912153 dt.08/12/2023) make GANGA KAVERI or equivalent (Inspection by Consignee)"							
16	16	3.00	Numbers	153400.00	460200.00	AT Par	460200.00	Rs.
	Description:- "Infra Red Thermal Imaging System (Thermo Vision Camera) as per RDSO speci no. TI/SPC/OHE/TIPS/1031(12/2013) rev.1 or latest with all accessories .make fluke/ CEM or similar Make/Brand: METRAVI MAKE, MODEL : Pro TI-40" (Inspection by Consignee)							
17	17	6900.00	Numbers	109.93	758544.60	AT Par	758544.60	Rs.
	Description:- Supply of drill bit 7.2 mm (Inspection by Consignee)							
18	18	6.00	Set	163135.00	978810.00	AT Par	978810.00	Rs.
	Description:- "Supply of modular power supply arrangement for VDU (42"" to 85"") and embedded PC (As specified in NWR HQ Policy letter No. SG/184/1-Vol.VII dtd 01.03.24) with input and output redundancy arrangement and hot plugable modules having voltage & load current digital display on each module. Each set consisting of: - 1.Isolated inverters (master/slave with auto changeover) -2 Nos. input: 110VDC, output: 110 VAC, 500VA (as per RDSO TAN No. STS/E/TAN/3012 Version 3.0 Dated.03.11.22) 2.Isolated DC-DC converters - 02 Nos. connected in parallel with built in O-ring diode, active current sharing as per RDSO/SPN/165/2023 version 4.0 or latest (input: 110VDC, output:24 VDC/10A) 3.Input (redundancy) O-ring diode module with two input sources and one output supply along with potential free contacts, alarm and acknowledgment switch. 4. 3U stainless steel rack with back panel mother board and front panel power connectors, power cord for VDU panel. Technical detail is mentioned in Annexure-TS-1(B). MakeGallant/Phoenix/APC or better. Inspection: RITES, Inspection charges:Borne by Railways, Paymentterms:100% after supply(Item is also planned to be use at midsection LC gates (where IPS is not provided) to produce the 110V AC for road user signal and 24 V for gate circuits from common 110 V DC input extended from nearest IPS.)" (Inspection by RDSO)							
19	19	6.00	Set	18644.00	111864.00	AT Par	111864.00	Rs.
	Description:- Installation, Wiring,Testing and Commissioning of modular power supply arrangement for VDU (42" to 85") as per RDSO TAN No.STS/E/TAN/3012 Version 3.0 Dated. 03.11.22 item includes supply and fixing of suitable mounting arrangement.Inspection: Consignee,Inspection charges: None ,Payment terms:100% after commissioning.							

3. ITEM BREAKUP

No item break up added

4. ELIGIBILITY CONDITIONS

Standard Financial Criteria

**BHUSAWAL DIVISION-S AND T/CENTRAL RLY
TENDER DOCUMENT**

Tender No: BSL-N-SNT-04-2026-27

Closing Date/Time: 19/06/2026 15:00

S.No.	Description	Confirmation Required	Remarks Allowed	Documents Uploading
1	The tenderer must have minimum average annual contractual turnover of V/N or 'V' whichever is less; where V= Advertised value of the tender in crores of Rupees N= Number of years prescribed for completion of work for which bids have been invited. The average annual contractual turnover shall be calculated as an average of "total contractual payments" in the previous three financial years, as per the audited balance sheet. However, in case balance sheet of the previous year is yet to be prepared/ audited, the audited balance sheet of the fourth previous year shall be considered for calculating average annual contractual turnover. The tenderers shall submit requisite information as per Annexure-VIB of SGCC, along with copies of Audited Balance Sheets duly certified by the Chartered Accountant/ Certificate from Chartered Accountant duly supported by Audited Balance Sheet.	No	No	Allowed (Mandatory)

Standard Technical Criteria

S.No.	Description	Confirmation Required	Remarks Allowed	Documents Uploading
1	(a)The tenderer must have successfully completed or substantially completed any one of the following categories of work(s) during last 07 (seven) years, ending last day of month previous to the one in which tender is invited: Three similar works each costing not less than the amount equal to 30% of advertised value of the tender, or Two similar works each costing not less than the amount equal to 40% of advertised value of the tender, or One similar work costing not less than the amount equal to 60% of advertised value of the tender. (b) (1)In case of tenders for composite works (e.g. works involving more than one distinct component, such as Civil Engineering works, S&T works, Electrical works, OHE works etc. and in the case of major bridges - substructure, superstructure etc.), tenderer must have successfully completed or substantially completed any one of the following categories of work(s) during last 07 (seven) years, ending last day of month previous to the one in which tender is invited: Three similar works each costing not less than the amount equal to 30% of advertised value of each component of tender, or Two similar works each costing not less than the amount equal to 40% of advertised value of each component of tender, or One similar work each costing not less than the amount equal to 60% of advertised value of each component of tender. Note for b(1): Separate completed works of minimum required values shall also be considered for fulfillment of technical eligibility criteria for different components. (b)(2)In such cases, what constitutes a component in a composite work shall be clearly pre-defined with estimated tender cost of it, as part of the tender documents without any ambiguity. (b) (3) To evaluate the technical eligibility of tenderer, only components of work as stipulated in tender documents for evaluation of technical eligibility, shall be considered. The scope of work covered in other remaining components shall be either executed by tenderer himself if he has work experience as mentioned in clause 7 of the Standard General Conditions of Contractor through subcontractor fulfilling the requirements as per clause 7 of the Standard General Conditions of Contract or jointly i.e., partly himself and remaining through subcontractor, with prior approval of Chief Engineer in writing.	No	No	Allowed (Mandatory)
1.1	Defination of Similar Work :- Any Signalling/Telecom work, which includes supply, installation, testing and commissioning of power Supply system.	No	No	Not Allowed

Bidders shall confirm and certify on the behalf of the tenderer including its constituents as under:

S.No.	Description
1	I/we the tenderer (s) am/are signing this document after carefully reading the contents.
2	I/We the tenderer(s) also accept all the conditions of the tender and have signed all the pages in confirmation thereof.
3	I/we hereby declare that I/we have downloaded the tender documents from Indian Railway website www.ireps.gov.in . I/we have verified the content of the document from the website and there is no addition, no deletion or no alteration to the content of the tender document. In case of any discrepancy noticed at any stage i.e. evaluation of tenders, execution of work or final payment of the contract, the master copy available with the railway Administration shall be final and binding upon me/us.
4	I/we declare and certify that I/we have not made any misleading or false representation in the forms, statements and attachments in proof of the qualification requirements.

**BHUSAWAL DIVISION-S AND T/CENTRAL RLY
TENDER DOCUMENT**

Tender No: BSL-N-SNT-04-2026-27

Closing Date/Time: 19/06/2026 15:00

5	I/We also understand that my/our offer will be evaluated based on the documents/credentials submitted along with the offer and same shall be binding upon me/us.
6	I/We declare that the information and documents submitted along with the tender by me/us are correct and I/we are fully responsible for the correctness of the information and documents, submitted by us.
7	I/we certify that I/we the tenderer(s) is/are not blacklisted or debarred by Railways or any other Ministry / Department of Govt. of India from participation in tender on the date of submission of bids, either in individual capacity or as a HUF/ member of the partnership firm/LLP/JV/Society/Trust.
8	I/we understand that if the contents of the certificate submitted by us are found to be forged/false at any time during process for evaluation of tenders, it shall lead to forfeiture of the Bid Security and may also lead to any other action provided in the contract including banning of business for a period of upto two year. Further, I/we and all my/our constituents understand that my/our offer shall be summarily rejected.
9	I/we also understand that if the contents of the certificate submitted by us are found to be false/forged at any time after the award of the contract, it will lead to termination of the contract, along with forfeiture of Bid Security/Security Deposit and Performance guarantee and may also lead to any other action provided in the contract including banning of business for a period of upto two year.
10	I/We have read the clause regarding restriction on procurement from a bidder of a country which shares a land border with India and certify that I am/We are not from such a country or, if from such a country, have been registered with the competent Authority. I/We hereby certify that I/we fulfil all the requirements in this regard and am/are eligible to be considered (evidence of valid registration by the competent authority is enclosed)

Partnership firm/Joint Venture (JV) / Hindu Undivided Family (HUF) / Limited Liability Partnership (LLP) etc.

S.No.	Description
1	Partnership firm/Joint Venture (JV) / Hindu Undivided Family (HUF) / Limited Liability Partnership (LLP) etc. Please submit a certificate in the prescribed format (please download the format from the link given below). Non submission of the certificate, or submission of certificate either not properly filled in, or in a format other than the prescribed format shall lead to summary rejection of your offer. (Click here to download the Format of Self Certification)

5. COMPLIANCE

Commercial-Compliance

S.No.	Description	Confirmation Required	Remarks Allowed	Documents Uploading
1	Please enter the percentage of local content in the material being offered. Please enter 0 for fully imported items, and 100 for fully indigenous items. The definition and calculation of local content shall be in accordance with the Make in India policy as incorporated in the tender conditions.	No	Yes	Allowed (Optional)

Technical-Compliances

S.No.	Description	Confirmation Required	Remarks Allowed	Documents Uploading
1	The bid must comply technical conditions of tender.	Yes	Yes	Allowed (Optional)

Custom

S.No.	Description	Confirmation Required	Remarks Allowed	Documents Uploading
1	The tenderer shall clearly specify whether the tender is submitted on his own (Proprietary Firm) or on behalf of a Partnership Firm / Company / Joint Venture (JV) / Registered Society / Registered Trust / Hindu Undivided Family (HUF) / Limited Liability Partnership (LLP) etc. The tenderer(s) shall enclose the attested copies of the constitution of their concern, and copy of PAN Card along with their tender. Tender Documents in such cases are to be signed by such persons as may be legally competent to sign them on behalf of the firm, company, association, trust or society, as the case may be. Tenderer should upload all necessary documents as specified in Clause no 14 of GCC-April, 2022 of Indian Railway.	Yes	Yes	Allowed (Mandatory)

**BHUSAWAL DIVISION-S AND T/CENTRAL RLY
TENDER DOCUMENT**

Tender No: BSL-N-SNT-04-2026-27

Closing Date/Time: 19/06/2026 15:00

2	Contractor shall employ following Qualified Engineers during execution of the allotted work- a] One Qualified Graduate Engineer when cost of work to be executed is Rs. 200 Lakh and above, b] One Qualified Diploma Holder Engineer when cost of work to be executed is more than Rs. 25 Lakh, but less than Rs. 200 Lakh. C] If the total cost of the tenderer's offer is Rs.25 Lakh or more, the tenderer(s) shall also give a declaration along with his/their tender to the effect that he/they shall engage and continue in service for the period of the contract, one Engineering Degree holder/one Engineering Diploma holder in line with above sub clause (a) and (b).	No	No	Allowed (Mandatory)
3	Mandate form dully signed by Bank Authority with seal to be attached.	No	No	Allowed (Mandatory)
4	GST Registration certificate of the tenderer to be uploaded alongwith tender document.	No	No	Allowed (Mandatory)

6. Documents attached with tender

S.No.	Document Name	Document Description
1	GCC-April2022_merged20.05.2024.pdf	GCC Apr 22
2	GCC_April-2022_2022_POLICY_27_04_22.pdf	GCC policy
3	C.RLYDRAWINGANNEXURES-SORST-20211_compressed.pdf	DRAWING
4	Annexure-ASafety-CriticalSignalingItemsbyRDSORSDe26.09.2025.1.pdf	Annexure A
5	CorrectionslipGCC13032026.pdf	GCC corr slip
6	Tenderdocument04-26-27.pdf	Tender document

This tender complies with Public Procurement Policy (Make in India) Order 2017, dated 15/06/2017, issued by Department of Industrial Promotion and Policy, Ministry of Commerce, circulated vide Railway Board letter no. 2015/RS(G)/779/5 dated 03/08/2017 and 27/12/2017 and amendments/ revisions thereof.

As a Tender Inviting Authority, the undersigned has ensured that the issue of this tender does not violate provisions of GFR regarding procurement through GeM.

Signed By: ANKIT KUMAR MISHRA

Designation : DSTE HQ BSL