



## MAINTENANCE SCHEDULE -DAILY

### Approved by ED CNS

Station Name:

Region:

Duration:

Equipment Name: DME (Thales)

Make:

Model No: 435(HP) / 415(LP)

S. No.	Parameters to be checked	Normal Status	Observed status						
1. GENERAL									
1.1	Equipment shelter cleanliness	Dust free							
1.2	Battery room cleanliness	Dust free							
1.3	Status of the air conditioners	Serviceable							
1.4	Equipment shelter temperature	22° ±2° C							
1.5	Mains Power supply	220 V±10%							
1.6	Stabilizer output	220 ±5V							
1.7	Voltage of Battery bank	24 V							
1.8	Status of Monitor	OK							
1.9	Status of remote indications at: a) Equipment room b) A.T.C	OK OK							
1.10	Change of Channels	Tx I to II and Vice-Versa							
1.11	Alarms. If any	Nil							
1.12	Any Unusual noise	No							
1.13	Battery operation	Normal							
1.14	Humidity in shelter								
1.15	Status of Electrical Fittings/works	No. of lights No. of fans							
1.16	Status of mast light	OK							
1.17	Signature of Officer								

Signature

(Manager)

(Sr. Manager)