

# Design and Development of a Device to Harvest AC Compressor Exhaust Heat for Sustainable Electrical Energy Production

Dr. Om Prakash Sahu  
Associate Professor, School of  
Computer Science  
University of Petroleum and Energy  
Studies  
Dehradun, India  
om.sahu@upes.ac.in

Aarush Badruka  
Student  
Independent Research  
Hyderabad, Telangana, India  
aarushbadruka@gmail.com

Khyati Verma  
Department of Computer Science and  
Engineering  
SSIPMT  
Raipur, Chhattisgarh, India  
khyati.verma24@ssipmt.com

Lekha Sahu  
Department of Computer Science and  
Engineering  
SSIPMT  
Raipur, Chhattisgarh, India  
lekha.sahu2023@ssipmt.com

**Abstract**—The increasing demand for air conditioners raises the problem of thermal energy wastage. Domestic air conditioners waste low-grade heat of 30–70 °C, which cannot be used efficiently by classical heat-to-power methods. This paper presents an approach to the sustainable conversion of this heat energy into usable electrons, stored in an electric cell. Experimental research has been performed on two different materials, stainless-steel and copper plates, with thermal adhesive to optimize physical conduction into a Peltier module. The temperature difference between the two sides of the module creates the need for an optimal cold-side heat sink to maximize domestic on-site power generation. The developed algorithms are applied to real-time data, and the outcomes are compared to identify the better efficiency, as proved through data visualization and graphical representation.

**Index Terms**—Sustainable-energy; Heat-harvesting; Charged-Electrons.

## I. INTRODUCTION

AC (air-conditioning) systems are increasingly used in residential and commercial buildings, and a large amount of the electricity they use is ultimately rejected as waste heat through the condenser unit. Typically, several hundred watts of thermal energy are persistently transferred to the ambient environment during normal operation, even in small domestic air conditioners. This waste heat falls within the low-temperature range (approximately 30–70 °C) and therefore remains largely unutilized due to its limited potential for traditional energy conversion methods. Recovering energy from this low-grade thermal source without disturbing the primary cooling performance of the air-conditioning system poses a challenge [1]. Peltier modules operating in power generation mode offer a

potential pathway to address this issue, as they can directly convert potential/temperature differences into electrical energy.

The main conversion stage makes use of the Peltier module, functioning as a thermoelectric generator (TEG), producing a direct-current (DC) voltage. The energy output of a Peltier module is mainly dependent on the temperature difference ( $\Delta T$ ) maintained across its two ceramic sides. As the hot side absorbs waste heat, the system needs to dissipate heat from the other side using a heat sink to prevent thermal equilibrium, which would stop energy generation, as the TEG relies on the thermal potential difference.

However, the direct use of a Peltier module in this application presents electrical challenges due to the low output current and voltage fluctuations of the Peltier module. To address this, the paper suggests using the harvested energy to charge a solid-state battery (SSB). SSBs are well-suited for this application due to their high safety profile and energy density, making them an ideal candidate for domestic energy storage systems, although any electric cell can be used to store the generated electrons [2].

Domestic refrigerators and air conditioners are the most widely used household appliances worldwide; however, they are infrequently acknowledged as potential sources of usable thermal energy. When operated, these appliances continuously emit heat through compressor shells and condenser coils to the surrounding environment. The rejected thermal exhaust usually comes out as a steady flow of low-temperature hot air, representing an underutilized energy resource. Considering the massive global deployment of such appliances, even small amounts of recovered waste heat can add up to significant energy savings. Practical implementation poses difficulties

owing to variations in compressor size, geometry, and installation constraints, motivating the exploration of adaptable and retrofittable heat-capture mechanisms.

This paper presents an effective way to use the waste thermal energy rejected by domestic air-conditioner exhaust systems to produce electricity, providing the combined advantages of cost-free electricity production and mitigation of thermal pollution. By converting low-grade heat that would otherwise be dissipated into the ambient environment, the proposed system contributes toward minimizing unnecessary thermal emissions, which indirectly intensify the accumulation of urban heat and contribute to global warming. It presents a practical implementation of low-temperature thermal energy harvesting using thermoelectric conversion, validated through an assessment of thermal pathways and system components. The work highlights the potential for integrating waste heat recovery mechanisms into everyday household appliances, thereby offering a platform for subsequent innovations in residential-scale sustainable energy recovery technologies.

### A. Background

1) *Thermodynamic constraints in low-grade heat recovery:* The primary challenge in recovering energy from domestic air-conditioning systems lies in the limited temperature difference ( $\Delta T$ ) between the heat source and the ambient environment. According to Carnot's theorem, the maximum theoretical efficiency of any heat-to-power conversion system is directly proportional to  $\Delta T$ . In domestic settings, the hot-side temperature typically ranges between 30 °C and 70 °C, while the ambient air temperature remains around 25–35 °C, resulting in inherently low conversion efficiency. Consequently, prior research emphasizes that system optimization under such constraints must focus on minimizing heat losses rather than increasing the source temperature [3], [4].

2) *Thermal interface resistance and material considerations:* Several studies have reported that thermal interface resistance significantly affects the performance of thermoelectric energy harvesting systems operating at low temperature gradients. Microscopic air gaps between the heat source and harvesting surfaces act as thermal insulators, severely degrading heat transfer efficiency. To mitigate this issue, the use of thermal interface materials (TIMs) has been widely explored to improve surface contact and reduce interfacial thermal resistance [5], [6].

### B. Existing research

Thermoelectric devices have attracted considerable attention because of their versatility in cooling, dehumidification, heat transfer, and energy conversion applications. Recent studies have integrated Peltier modules with air-conditioning systems for cooling enhancement and water recovery, demonstrating their suitability for sustainable energy-related applications [7].

Nohra et al. constructed a thermal model and examined the geometric parameters of TEG plates and duct dimensions to maximize output. However, the integration complexity and the

dependence on matching HVAC and engine conditions can restrict real-world adoption for small appliances [8].

Roungbungrud et al. demonstrated a prototype in which condenser heat is utilized more effectively for electricity generation. It captures waste heat from a split AC condenser and cools the module using the condensate water that drips off. The prototype yielded very low power due to the small  $\Delta T$  and limited heat transfer area [9].

Hasalli Ibrahim et al. analyzed and built a TEG model specifically for AC waste heat, comparing air-cooled and water-cooled configurations to determine which produced more electricity when tested at simulated hot-side temperatures. Even with optimized cooling, the real power remained low due to the very small temperature gradients in domestic systems [10].

## II. METHODOLOGY

### A. Working principle of thermoelectric power generation

Thermoelectric conversion is a technique for turning a temperature difference directly into electricity without having solid materials, with no moving parts or working fluids. This is mainly based on a phenomenon called the Seebeck effect. When a temperature difference is established across a TEG module, charge carriers migrate from the hot side to the cold side within the semiconductor material, creating an electrical potential difference. The voltage is proportional to the temperature difference ( $\Delta T$ ) and to the Seebeck coefficient of the materials. When an electrical load is connected, a current flows, and heat is converted into electrical power [11], [12].

The Seebeck voltage generated by the thermoelectric module is expressed as:

$$V = S\Delta T$$

where  $V$  is the generated voltage,  $S$  is the Seebeck coefficient, and  $\Delta T$  is the temperature difference between the hot and cold sides of the module.

Electrical power generated by the thermoelectric module can be calculated using:

$$P = VI$$

where  $P$  is the output power,  $V$  is the output voltage, and  $I$  is the output current. Maximizing power generation requires efficient heat transfer from the waste heat source, as a larger temperature difference across the module leads to improved electrical output.

### B. Experimental setup

Six Peltier modules were used in this experimental setup to convert waste heat from an air-conditioning system into electrical energy. The heat rejected by the air conditioner served as the hot-side thermal source for the thermoelectric modules. Two different heat transfer materials, copper and stainless steel, were investigated to evaluate their influence on thermoelectric performance. These materials were placed between the waste heat source and the thermoelectric modules to facilitate heat transfer.

Figure 1 shows the setup, in which the hot side of the thermoelectric modules was attached to the heat transfer plate, while the cold side was connected to a heat sink exposed to ambient air. The setup preserved a temperature gradient across the modules, thereby supporting the generation of thermoelectric power. Electrical measurements, including voltage and current, were recorded at regular time intervals. The generated power was subsequently calculated using the measured voltage and current values.





Fig. 1. AC compressor as thermoelectric heat generator

### 1) Parallel configuration



### 2) Series configuration




Fig. 2. Circuit diagrams of the parallel and series configurations using six Peltier modules

### C. Experimental Procedure

The experiment was conducted under uniform conditions for all configurations. Initially, six Peltier modules were mounted between the heat transfer plate and the heat sink. Waste heat was allowed to flow from the air-conditioning system

through the selected plate material to the hot side of the Peltier modules.

The air-conditioning system was operated continuously for each test configuration while voltage and current readings were recorded at predefined time intervals. Data were measured for two configurations, series and parallel, using the copper and stainless-steel plates. The data comprise voltage-versus-time, current-versus-time, and power-versus-time readings, which are plotted as graphs in the following section.

## III. RESULTS

The experimental results for the two plates, copper and stainless steel, are presented below in graphical form in Figures 3 to 17. The plates were tested in two configurations, series and parallel, and the graphical outputs are presented in three forms: voltage, current, and power.

### A. Effect of stainless-steel plates

**1) Series configuration:** Figure 3 demonstrates a gradual increase in voltage with time, reaching a stable region and indicating effective thermoelectric generation under continuous heating. A steady rise in current was observed in Figure 4, signifying improved transport of charge carriers with the development of the temperature gradient. Confirming successful thermal-to-electrical energy conversion, the power output shown in Figure 5 increased with heating duration and reached its maximum value at higher operating temperatures.

Stainless Steel (Series) Voltage v/s Time




Fig. 3. Voltage vs. Time: stainless-steel plates connected in series




Fig. 4. Current vs. Time: stainless-steel plates connected in series




Fig. 7. Current vs. Time: stainless-steel plates connected in parallel




Fig. 5. Power vs. Time: stainless-steel plates connected in series




Fig. 8. Power vs. Time: stainless-steel plates connected in parallel

**2) Parallel configuration:** The voltage shown in Figure 6 remained relatively low and stable throughout the experiment due to the characteristics of a parallel connection. The current (Figure 7) initially increased and later stabilized, indicating moderate thermoelectric performance. Power generation, shown in Figure 8, was inferior to that of the series setup, reflecting decreased effectiveness in harvesting energy.

### B. Effect of copper plates

**1) Series configuration:** Copper plates produced a stable voltage output due to efficient heat transfer through the material (shown in Figure 9). Figure 10 presents the current, which increased gradually over time and then stabilized, signifying efficient thermoelectric conversion. The power output, shown in Figure 11, reached higher peak values, demonstrating improved energy harvesting capability.




Fig. 6. Voltage vs. Time: stainless-steel plates connected in parallel




Fig. 9. Voltage vs. Time: copper plates connected in series




Fig. 10. Current vs. Time: copper plates connected in series




Fig. 12. Voltage vs. Time: comparison between stainless-steel and copper plates in series




Fig. 11. Power vs. Time: copper plates connected in series




Fig. 13. Current vs. Time: comparison between stainless-steel and copper plates in series




Fig. 14. Power vs. Time: comparison between stainless-steel and copper plates in series

### C. Copper and stainless steel in series

Figures 12, 13, and 14 present the graphical analysis of both materials, which exhibited similar voltage trends; however, due to the superior thermal conductivity of copper, it showed slightly more stable voltage generation. In the current measurements, copper generated a marginally higher current output than stainless steel over most of the operating period. Copper also produced marginally higher output power, reflecting superior efficiency in thermoelectric conversion.

### D. Series vs parallel configuration

Figures 15, 16, and 17 show that the series configuration generated a significantly higher voltage than the parallel configuration. A comparatively greater and steadier current was recorded in the series arrangement. In power generation, the

series configuration also produced substantially greater power output, demonstrating superior energy harvesting performance.

Series and Parallel (Stainless Steel) Voltage v/s Time




Fig. 15. Voltage vs. Time: stainless-steel plates, comparison between series and parallel

Series and Parallel (Stainless Steel) Current v/s Time




Fig. 16. Current vs. Time: stainless-steel plates, comparison between series and parallel

Series and Parallel (Stainless Steel) Power v/s Time




Fig. 17. Power vs. Time: stainless-steel plates, comparison between series and parallel

Based on the experimental results obtained from the voltage, current, and power measurements, the stainless-steel plates in

the series configuration demonstrated the best overall performance among all tested arrangements, as analyzed in Table I. Stainless steel consistently produced slightly higher and more stable voltage and current outputs, resulting in improved power generation.

TABLE I  
COMPARATIVE ANALYSIS

| Parameter                    | Stainless steel | Copper   | Better material |
|------------------------------|-----------------|----------|-----------------|
| Thermal conductivity         | higher          | lower    | stainless steel |
| Voltage output               | higher          | lower    | stainless steel |
| Current output               | higher          | lower    | stainless steel |
| Power output                 | higher          | lower    | stainless steel |
| Energy harvesting efficiency | better          | moderate | stainless steel |

The improvement is attributed to stainless steel's effective thermal properties in this setup, allowing for more efficient heat transfer from the air-conditioner compressor to the Peltier modules, which in turn yields a greater temperature difference across the thermoelectric devices. Copper also successfully generated energy but exhibited comparatively lower overall performance in these trials. Furthermore, series-connected modules produced markedly greater electrical performance than parallel arrangements, making series the optimal configuration for thermoelectric energy harvesting applications.

#### IV. CONCLUSION

This paper demonstrated the feasibility of converting waste heat from an air-conditioning system into electrical energy using thermoelectric modules. The results of the experiments conducted using six Peltier modules showed that performance metrics such as voltage, current, and power were considerably influenced by the thermal interface material and the operational arrangement. Of the two investigated materials, stainless steel exhibited superior performance compared to copper, resulting in improved heat transfer and greater electrical output. The findings verify that thermoelectric energy harvesting can convert waste heat into useful power, offering a practical, green, and sustainable method for low-power generation. Future work may focus on improving conversion efficiency through optimized module arrangements and advanced heat transfer techniques.

#### V. FUTURE SCOPE

The performance of the proposed thermoelectric energy harvesting system can be further improved by employing advanced thermoelectric materials with higher conversion efficiency and optimizing the hot-side and cold-side thermal management. The ultimate goal of this experiment is to build a small, easy-to-install module compatible with existing systems, enabling large-scale deployment. With further optimization, such systems could aid in mitigating thermal pollution while enhancing energy utilization within residential environments.

- 1) B. Lamrani, S. El Marbet, T. ur Rehman, and T. Kouksou, “Comprehensive analysis of waste heat recovery and thermal energy storage integration in air conditioning systems,” *Energy Conversion and Management*: X, vol. 24, p. 100708, Oct. 2024.
- 2) J. Janek and W. G. Zeier, “Challenges in speeding up solid-state battery development,” *Nature Energy* 2023 8:3, vol. 8, no. 3, pp. 230-240, Feb. 2023.
- 3) T. Hussain, A. Hafiz, and Akramuddin, “Exergy Analysis of an Air Conditioning System Using Air-Cooled Condenser at Different Ambient Conditions with Different Volume Flow Rates of Air,” *Smart Innovation, Systems and Technologies*, vol. 174, pp. 597-605, 2020.
- 4) M. I. Zdobnov, N. A. Lavrov, and V. V. Shishov, “Entropy Analysis of Energy Losses in Heat-Exchanger and Mixing Sections of a Central Air Conditioner,” *Chemical and Petroleum Engineering*, vol. 58, no. 11-12, pp. 943-952, Mar. 2023.
- 5) W. Dai et al., “Ultralow Interfacial Thermal Resistance of Graphene Thermal Interface Materials with Surface Metal Liquefaction,” *Nano-Micro Letters* 2022 15:1, vol. 15, no. 1, pp. 9-, Dec. 2022.
- 6) Y. Tu et al., “A Review of Advanced Thermal Interface Materials with Oriented Structures for Electronic Devices,” *Electronics* 2024, Vol. 13, Page 4287, vol. 13, no. 21, p. 4287, Oct. 2024.
- 7) C. Baglivo, A. Buscemi, M. Spagnolo, M. Bonomolo, V. Lo Brano, and P. M. Congedo, “Toward a Sustainable Indoor Environment: Coupling Geothermal Cooling with Water Recovery Through EAHX Systems,” *Energies* 2025, Vol. 18, Page 2297, vol. 18, no. 9, p. 2297, Apr. 2025.
- 8) C. Nohra et al., “Hybrid thermoelectric generator system for enhanced waste heat recovery from diesel generators using HVAC condenser airflow,” *Mater. Sci. Energy Technol.*, vol. 8, pp. 178-187, Jan. 2025.
- 9) K. Roungrungrud, P. Chantawong, and J. Khedari, “Development of a Stand-Alone Thermoelectric Power Generator Using Heat of Refrigerant Leaving the Condenser and Self-Cooled by Condensate of a Split-Type Air Conditioning,” *International Journal of Heat & Technology*, vol. 40, no. 3, p. 737, Jun. 2022.
- 10) N. Hasalli Ibrahim, S. Najir Ahmed Cheplin, Z. Sharmila Shamsuddin, and A. Rahman Abd Aziz, “Investigation of Power Generation from Air Conditioning Waste Heat Towards Sustainable Cooling Solution,” *Jurnal Kejuruteraan*, vol. 37, no. 6, pp. 3055-3062.
- 11) M. Ridwan, M. Gasulla, and F. Reverter, “Principle and Applications of Thermoelectric Generators: A Review,” *Sensors* 2025, Vol. 25, Page 2484, vol. 25, no. 8, p. 2484, Apr. 2025.
- 12) D. Yuan, W. Jiang, A. Sha, J. Xiao, W. Wu, and T. Wang, “Technology method and functional characteristics of road thermoelectric generator system based on Seebeck