

225121/CGB CNY FAB

18 April 2014

	System	Peak Supply Air	Design Outside Air	OA Fraction		
		cfm	cfm	%	DCV	Comments
	AHU-1 Workspaces N	24200	16900	70%	2900	
CD (Ez = 0.8 &	AHU-2 Workspaces S	11900	7000	59%	1500	
Storage Ra = 0.12)	AHU-3 Cafe	11600	5100	44%	1200	need to adjust DCV to 2900 cfm, OA increased to 5200 cfm on 04/10/14
Storage Ra = 0.12)	AHU-4 Seminar	14600	10300	71%	800	need to adjust DCV to 1900 cfm
	AHU-5 Conference	18600	6300	34%	1600	need to adjust DCV to 6000 cfm, SA increased to 18400 cfm, OA increased to 7900 cfm on 04/10/14
	AHU-1 Workspaces N	22500	17000	76%	4000	
	AHU-2 Workspaces S	15000	8000	53%	2300	
DD	AHU-3 Cafe	13000	5500	42%	2300	
	AHU-4 Seminar	13000	8500	65%	1100	
	AHU-5 Conference	20000	7500	38%	3700	
						_
	AHU-1 Workspaces N	-8%	1%		28%	
Difference	AHU-2 Workspaces S	21%	13%		35%	
between CD &	AHU-3 Cafe	11%	7%		48%	
DD	AHU-4 Seminar	-12%	-21%		27%	
	AHU-5 Conference	7%	16%		57%	
	System	Peak Supply Air	Design Outside Air	OA Fraction		
		cfm	cfm	%	DCV	Comments
	AHU-1 Workspaces N	24200	17700	73%	2900	
	AHU-2 Workspaces S	11900	7900	66%	1500	
CD (Ez = 1.0)	AHU-3 Cafe	11500	5200	45%	1200	need to adjust DCV to 2900 cfm, OA increased to 5200 cfm on 04/10/14
	AHU-4 Seminar	14600	11600	79%	800	need to adjust DCV to 1900 cfm
	AHU-5 Conference	18400	7900	43%	1500	need to adjust DCV to 6000 cfm, SA increased to 18400 cfm, OA increased to 7900 cfm on 04/10/14

J:\N-Y\220000\225121-00\4 Internal Project Data\4-04 Calculations\4-04-06 Mech\Ventilation\ CD ventilation calculations.xlsm : Summary © Arup | F0.13 | 14 February 2011

225121/CGB CNY FAB

18 April 2014

								Step #:	1	2	3	1			Γ	4	9	Ī				
Zone	Occupancy	Rp	Pz-des	Ra	Az	Density	CO2	DCV	Vbz	Ez	Voz	Vdz-unco	· Vdz-des	Vdz-min-uncor	Vdz-min	Zdz	Evz	Ds	Vdz-min > Vdz- min-uncorr	Vdz-des > Vdz min	VAV	
	Category	cfm/p	person	cfm/sf	sf	pp/1000SF	for LEED?	for 90.1?	cfm		cfm	cfm	cfm	cfm	cfm				mm-uncorr	111111		
118 L1 HuddleRm_170	Huddle	5	5	0.06	93	54	Y	-	31	0.8	38	100	100	30	45.0	0.85	0.50	0.45		Υ	VAV 1.31	
119 L1 HuddleRm_172	Huddle	5	5	0.06	93	54	Y	-	31	0.8	38	100	100	30	45.0	0.85	0.50	0.45		Y	VAV 1.31	
120 L1 HuddleRm_173	Huddle	5	5	0.06	89	56	Y	-	30	0.8	38	100	100	30	45.0	0.84	0.50	0.45		Y	VAV 1.28	
121 L1 HuddleRm_174 122 L1 HuddleRm 175	Huddle Huddle	5	5	0.06	89 89	56 56	Y	-	30 30	0.8	38 38	100	100	30	45.0 45.0	0.84	0.50	0.45 0.45		Y	VAV 1.34	
123 L1 HuddleRm 176	Huddle	5	5	0.06	89	56	Y	-	30	0.8	38	100	100	30	45.0	0.84	0.50	0.45		T V	VAV 1.28 VAV 1.34	
124 L1 HuddleRm 177	Huddle	5	5	0.06	89	56	Y	-	30	0.8	38	100	100	30	45.0	0.84	0.50	0.45		Y	VAV 1.34 VAV 1.27	
125 L1 HuddleRm 178	Huddle	5	5	0.06	89	56	Y		30	0.8	38	100	100	30	45.0	0.84	0.50	0.45		Y	VAV 1.27	
126 L1 HuddleRm_179	Huddle	5	5	0.06	103	48	Y	-	31	0.8	39	122	122	37	50.0	0.78	0.57	0.41		Ϋ́	VAV 1.27	
127 L1 HuddleRm_192	Huddle	5	5	0.06	88	57	Y	-	30	0.8	38	100	100	30	45.0	0.84	0.50	0.45	Υ	Υ	VAV 1.35	
128 L1 HuddleRm_195	Huddle	5	5	0.06	89	56	Y	-	30	0.8	38	100	100	30	45.0	0.84	0.50	0.45	Υ	Υ	VAV 1.35	
129 L1 HuddleRm_194	Huddle	5	5	0.06	88	57	Y	-	30	0.8	38	100	100	30	45.0	0.84	0.50	0.45	Υ	Υ	VAV 1.35	
134 L1 LockerRm_168_Ext	Corridor	0	2	0.06	211	9	-	-	13	0.8	16	100	100	30	30.0	0.53	0.82	0.30		Υ	VAV 1.33	
135 L1 LockerRm_168_Int	Corridor	0	1	0.06	104	10	-	-	6	0.8	8	25	25	8	10.0	0.78	0.57	0.40		Y	VAV 1.33	
145 L1 MastersStudio_191_Ext1	Masters	10	22	0.12	798	28	Y	-	316	0.8	395	750	750	225	470.0	0.84	0.51	0.63		Y	VAV 1.29	1 7
146 L1 MastersStudio_191_Ext2	Masters	10	20	0.12	416	48	Y	-	250	0.8	312	750	750	225	370.0	0.84	0.50	0.49		Y	VAV 1.37	. ,
147 L1 MastersStudio_191_Ext3	Masters	10	12	0.12	780	15	- 7/	-	214	0.8	267	500	500	150	320.0	0.83	0.51	0.64		Y	VAV 1.36	
148 L1 MastersStudio_191_Ext4	Masters	10	15	0.12	530	28	Y	- V	214	0.8	267	450	450	135	320.0	0.83	0.51	0.71		Y	VAV 1.33	
149 L1 MastersStudio_191_Int1 150 L1 MastersStudio 191 Int2	Masters Masters	10	20	0.12	1048 425	42	Y	- Y	566 251	0.8	707 314	900 450	900 450	270 135	840.0 375.0	0.84	0.50	0.93 0.83		T V	VAV 1.30 VAV 1.39	
150 L1 MastersStudio_191_int2	Masters	10	20	0.12	353	57	Y	-	242	0.8	303	450	450	135	360.0	0.84	0.51	0.83		' Y	VAV 1.39 VAV 1.39	
151 L1 MastersStudio_191_Int3 152 L1 MastersStudio 191 Int4	Masters	10	17	0.12	701	24	-		254	0.8	318	488	488	146	380.0	0.84	0.51	0.80		Y	VAV 1.39 VAV 1.32	
154 L1 QuietRm 197	Masters	10	20	0.12	732	27	Y	-	288	0.8	360	732	732	220	430.0	0.84	0.51	0.78		Ϋ́	VAV 1.32 VAV 1.38	
205 L2 CollabArea 274	Workspace	5	7	0.12	279	25	Y		52	0.8	65	150	150	45	80.0	0.81	0.54	0.53		Y	VAV 1.36 VAV 2.31	
206 L2 CollabArea 295	Swing	5	12	0.06	679	18	-		101	0.8	126	400	400	120	150.0	0.84	0.54	0.38		Y Y	VAV 2.31	
214 L2 HuddleCorridor	Corridor	0	0	0.06	608	0	-	-	36	0.8	46	50	55	17	55.0	0.83	0.52	1.00		Y	VAV 2.31	
221 L2 HuddleRm 252	Huddle	5	5	0.06	103	48	Y	-	31	0.8	39	100	100	30	50.0	0.78	0.57	0.50		Ϋ́	VAV 2.23	
222 L2 HuddleRm_254	Huddle	5	5	0.06	99	50	Y	-	31	0.8	39	100	100	30	50.0	0.77	0.57	0.50		Υ	VAV 2.23	
223 L2 HuddleRm_255	Huddle	5	5	0.06	107	47	Y	-	31	0.8	39	122	122	37	50.0	0.79	0.56	0.41	Υ	Υ	VAV 2.24	
224 L2 HuddleRm_256	Huddle	5	5	0.06	124	40	Y	-	32	0.8	41	100	100	30	50.0	0.81	0.54	0.50	Υ	Υ	VAV 2.23	
225 L2 HuddleRm_257	Huddle	5	5	0.06	101	49	Y	-	31	0.8	39	122	122	37	50.0	0.78	0.57	0.41	Υ	Υ	VAV 2.24	
226 L2 HuddleRm_259	Huddle	5	5	0.06	101	49	Y	-	31	0.8	39	122	122	37	50.0	0.78	0.57	0.41	Υ	Υ	VAV 2.24	
227 L2 HuddleRm_260	Huddle	5	5	0.06	146	34	Y	-	34	0.8	42	100	100	30	50.0	0.84	0.50	0.50	Υ	Υ	VAV 2.25	
228 L2 HuddleRm_261	Huddle	5	5	0.06	101	49	Y	-	31	0.8	39	122	122	37	50.0	0.78	0.57	0.41		Y	VAV 2.26	
229 L2 HuddleRm_262	Huddle	5	5	0.06	100	50	Y	-	31	0.8	39	100	100	30	50.0	0.77	0.57	0.50		Y	VAV 2.25	
230 L2 HuddleRm_263	Huddle	5	5	0.06	101	49	Y	-	31	0.8	39	122	122	37	50.0	0.78	0.57	0.41		Y	VAV 2.26	
231 L2 HuddleRm_264	Huddle	5	5	0.06	100	50	Y	-	31	0.8	39	100	100	30	50.0	0.77	0.57	0.50		Y	VAV 2.27	
232 L2 HuddleRm_265	Huddle	5	5	0.06	101	49	Y	-	31	0.8	39	122	122	37	50.0	0.78	0.57	0.41		Y	VAV 2.28	
233 L2 HuddleRm_266 234 L2 HuddleRm_267	Huddle Huddle	5	5	0.06	100 152	50 33	Y	-	31	0.8	39	100 122	100 122	30	50.0 55.0	0.77	0.57	0.50 0.45		Y V	VAV 2.27 VAV 2.28	
235 L2 HuddleRm_268	Huddle	5	5	0.06	100	50	Y	-	34 31	0.8	43 39	100	100	30	50.0	0.78	0.57	0.43		T V	VAV 2.26 VAV 2.29	
236 L2 HuddleRm_270	Huddle	5	5	0.06	97	51	Y		31	0.8	39	100	100	30	50.0	0.77	0.57	0.50		V	VAV 2.29 VAV 2.29	
237 L2 HuddleRm 271	Huddle	5	5	0.06	101	49	Y	-	31	0.8	39	122	122	37	50.0	0.78	0.57	0.41		Y	VAV 2.20	
238 L2 HuddleRm 273	Huddle	5	5	0.06	101	50	Y	-	31	0.8	39	122	122	37	50.0	0.78	0.57	0.41		Y	VAV 2.30	
239 L2 ConferenceRm 275	Conference	5	10	0.06	261	38	Y	-	66	0.8	82	300	300	90	100.0	0.82	0.53	0.33		Y	VAV 2.32	
240 L2 HuddleRm_287	Huddle	5	5	0.06	139	36	Y	-	33	0.8	42	100	100	30	50.0	0.83	0.51	0.50		Ϋ́	VAV 2.33	
241 L2 HuddleRm_289	Huddle	5	5	0.06	132	38	Y	-	33	0.8	41	100	100	30	50.0	0.82	0.52	0.50		Υ	VAV 2.33	
242 L2 HuddleRm_291	Huddle	5	5	0.06	131	38	Y	-	33	0.8	41	100	100	30	50.0	0.82	0.52	0.50	Υ	Υ	VAV 2.34	
243 L2 HuddleRm_293	Huddle	5	5	0.06	130	39	Y	-	33	0.8	41	100	100	30	50.0	0.82	0.53	0.50	Υ	Υ	VAV 2.34	
246 L2 Library_281	Workspace	5	17	0.06	690	25	-	-	126	0.8	158	375	375	113	190.0	0.83	0.51	0.51		Υ	VAV 2.42	
250 L2 OfficeZoneB_283_Ext1	Workspace	5	17	0.06	1022	17	-	-	146	0.8	183	450	450	135	220.0	0.83	0.51	0.49		Υ	VAV 2.19	
251 L2 OfficeZoneB_283_Ext2	Workspace	5	17	0.06	1067	16	-	-	149	0.8	186	450	450	135	225.0	0.83	0.52	0.50		Y	VAV 2.20	
252 L2 OfficeZoneB_283_Ext3	Workspace	5	17	0.06	1093	_	-		151	0.8	188	450	450	135	225.0	0.84	0.51	0.50		Y	VAV 2.36	
253 L2 OfficeZoneB_283_Ext4	Workspace	5	17	0.06	842		-	-	136	0.8	169	450	450	135	205.0	0.83	0.52	0.46		Y	VAV 2.37	
254 L2 OfficeZoneB_283_Ext5	Workspace	5	25	0.06	1075		-	-	190	0.8	237	650	650	195	280.0	0.85	0.50	0.43		ĭ V	VAV 2.40	
255 L2 OfficeZoneB_283_Int1 256 L2 OfficeZoneB_283_Int2	Workspace	5	8	0.06	435 454	18 18	-	-	66 67	0.8	83 84	150 150	150 150	45 45	100.0	0.83	0.52	0.67 0.67		т У	VAV 2.21	
256 L2 OfficeZoneB_283_Int2 257 L2 OfficeZoneB 283 Int3	Workspace Workspace	5	8	0.06	454	18	-	-	68	0.8	84	150	150	45	100.0	0.84	0.51	0.67		' V	VAV 2.22 VAV 2.38	
258 L2 OfficeZoneB_283_Int4	Workspace	5	8	0.06	358	22			62	0.8	77	150	150	45	95.0	0.81	0.54	0.70		Y	VAV 2.36 VAV 2.39	
263 L2 QuietRm_277	Workspace	5	6	0.06	251	24	-		45	0.8	56	200	200	60	70.0	0.80	0.54	0.35		Y Y	VAV 2.35	
270 L2 Storage_276	Storage	5	0	0.12	54	0	-	-	6	0.8	8	25	25	8	10.0	0.81	0.54	0.40		Υ	VAV 2.31	
306 L3 CollabArea_374	Workspace	5	7	0.06	279	25	Y	-	52	0.8	65	150	150	45	80.0	0.81	0.54	0.53		Υ	VAV 3.31	
307 L3 CollabArea_381	Huddle	5	5	0.06	101	49	Y	-	31	0.8	39	100	100	30	50.0	0.78	0.57	0.50		Υ	VAV 3.33	
308 L3 CollabArea_395	Workspace	5	12	0.06	505	24	-	-	90	0.8	113	300	300	90	135.0	0.84	0.51	0.45		Υ	VAV 3.39	
311 L3 ConferenceRm_375	Conference	5	10	0.06	261	38	Y	-	66	0.8	82	300	300	90	100.0	0.82	0.53	0.33	Υ	Υ	VAV 3.32	
312 L3 ConferenceRm_397	Conference	5	9	0.06	302	30	Y	-	63	0.8	79	325	325	98	100.0	0.79	0.56	0.31	Υ	Υ	VAV 3.41	
313 L3 ConferenceRm_398	Conference	5	9	0.06	418	22	-	-	70	0.8	88	325	325	98	105.0	0.83	0.51	0.32	Υ	Υ	VAV 3.40	
319 L3 HuddleCorridor	Corridor	0	0	0.06	608	0	-	-	36	0.8	46	50	55	17	55.0	0.83	0.52	1.00		Υ		flow rounded up to allow for Evz ~ 0.5
326 L3 HuddleRm_352 327 L3 HuddleRm_354	Huddle Huddle	5	5	0.06	103 99	48 50	Y	-	31 31	0.8	39 39	100	100	30	50.0 50.0	0.78 0.77	0.57	0.50 0.50		Υ	VAV 3.23 VAV 3.23	

328 L3 HuddleRm_355	Huddle	5	5	0.06	104	48	Y	-	31	0.8	39	122	122	37	50.0	0.78	0.56	0.41 Y	Υ	VAV 3.2	
329 L3 HuddleRm_356	Huddle	5	5	0.06	124	40	Y	-	32	0.8	41	100	100	30	50.0	0.81	0.54	0.50 Y	Υ	VAV 3.23	}
330 L3 HuddleRm_357	Huddle	5	5	0.06	101	49	Y	-	31	0.8	39	122	122	37	50.0	0.78	0.57	0.41 Y	Υ	VAV 3.24	
331 L3 HuddleRm_359	Huddle	5	5	0.06	101	49	Y	-	31	0.8	39	122	122	37	50.0	0.78	0.57	0.41 Y	Υ	VAV 3.24	
332 L3 HuddleRm_360	Huddle	5	5	0.06	146	34	Y	-	34	0.8	42	100	100	30	50.0	0.84	0.50	0.50 Y	Υ	VAV 3.2	
333 L3 HuddleRm_361	Huddle	5	5	0.06	101	49	Y	-	31	0.8	39	122	122	37	50.0	0.78	0.57	0.41 Y	Υ	VAV 3.20	
334 L3 HuddleRm_362	Huddle	5	5	0.06	100	50	Y	-	31	0.8	39	100	100	30	50.0	0.77	0.57	0.50 Y	Υ	VAV 3.2	
335 L3 HuddleRm_363	Huddle	5	5	0.06	101	49	Y	-	31	0.8	39	122	122	37	50.0	0.78	0.57	0.41 Y	Υ	VAV 3.20	
336 L3 HuddleRm_364	Huddle	5	5	0.06	100	50	Y	-	31	0.8	39	100	100	30	50.0	0.77	0.57	0.50 Y	Y	VAV 3.2	
337 L3 HuddleRm_365	Huddle	5	5	0.06	101	49	Y	-	31	0.8	39	122	122	37	50.0	0.78	0.57	0.41 Y	Y	VAV 3.2	
338 L3 HuddleRm_366	Huddle	5	5	0.06	100	50	Y	-	31	0.8	39	100	100	30	50.0	0.77	0.57	0.50 Y	Y	VAV 3.2	
339 L3 HuddleRm_367	Huddle	5	5	0.06	152	33	Y	-	34	0.8	43	122	122	37	55.0	0.78	0.57	0.45 Y	Y	VAV 3.2	
340 L3 HuddleRm_368	Huddle	5	5	0.06	100	50	Y	-	31	0.8	39	100	100	30	50.0	0.77	0.57	0.50 Y	Y	VAV 3.29	
341 L3 HuddleRm_370	Huddle	5	5	0.06	97	51	Y	-	31	0.8	39	100	100	30	50.0	0.77	0.57	0.50 Y	Y	VAV 3.29	
342 L3 HuddleRm_371 343 L3 HuddleRm 373	Huddle Huddle	5	5	0.06	101	49 50	Y Y	-	31	0.8	39 39	122 122	122	37 37	50.0	0.78	0.57	0.41 Y 0.41 Y	Y	VAV 3.30 VAV 3.30	
348 L3 OfficeZoneB 383 Ext1	Workspace	5	17	0.06	1022	17	-	-	146	0.8	183	450	122 450	135	220.0	0.78	0.57	0.41 T 0.49 Y	T V	VAV 3.3	
349 L3 OfficeZoneB 383 Ext2	Workspace	5	17	0.06	1022	16	-	-	149	0.8	186	450	450	135	225.0	0.83	0.51		V		
350 L3 OfficeZoneB_383_Ext3	Workspace	5	17	0.06	1007	16	-	-	151	0.8	188	450	450	135	225.0	0.83	0.52	0.50 Y 0.50 Y	' V	VAV 3.20 VAV 3.3	
351 L3 OfficeZoneB 383 Ext4	Workspace	5	17	0.06	1162	15	-	-	155	0.8	193	450	450	135	230.0	0.84	0.51	0.50 Y 0.51 Y	Y	VAV 3.3	
352 L3 OfficeZoneB 383 Int1	Workspace	5	8	0.06	435	18	-	-	66	0.8	83	150	150	45	100.0	0.83	0.52	0.67 Y	Y	VAV 3.3	
353 L3 OfficeZoneB 383 Int2	Workspace	5	8	0.06	454	18	-	-	67	0.8	84	150	150	45	100.0	0.83	0.52	0.67 Y	Ϋ́	VAV 3.2	
354 L3 OfficeZoneB 383 Int3	Workspace	5	8	0.06	467	17	-	-	68	0.8	85	150	150	45	105.0	0.81	0.54	0.70 Y	Ϋ́	VAV 3.3	
355 L3 OfficeZoneB 383 Int4	Workspace	5	8	0.06	515	16	-	-	71	0.8	89	150	150	45	105.0	0.84	0.50	0.70 Y	Ϋ́	VAV 3.3	
361 L3 QuietRm_377	Huddle	5	6	0.06	251	24	-	-	45	0.8	56	200	200	60	70.0	0.80	0.54	0.35 Y	Y	VAV 3.3	
367 L3 Storage_376	Storage	5	0	0.12	54	0	-	-	6	0.8	8	25	25	8	10.0	0.81	0.54	0.40 Y	Y	VAV 3.3	
406 L4 CollabArea 474	Workspace	5	7	0.06	279	25	Y	-	52	0.8	65	175	175	53	80.0	0.81	0.54	0.46 Y	Υ	VAV 4.3	
407 L4 CollabArea_481	Huddle	5	5	0.06	101	49	Y	-	31	0.8	39	150	150	45	50.0	0.78	0.57	0.33 Y	Υ	VAV 4.3	
408 L4 CollabArea_487	Huddle	5	5	0.06	93	54	Y	-	31	0.8	38	150	150	45	50.0	0.76	0.58	0.33 Y	Υ	VAV 4.3	
409 L4 CollabArea_495	Workspace	5	12	0.06	436	28	Y	-	86	0.8	108	300	300	90	130.0	0.83	0.52	0.43 Y	Υ	VAV 4.4	
412 L4 ConferenceRm_475	Conference	5	10	0.06	261	38	Y	-	66	0.8	82	244	244	73	100.0	0.82	0.53	0.41 Y	Υ	VAV 4.3	}
413 L4 ConferenceRm_497	Conference	5	18	0.06	778	23	-	-	137	0.8	171	600	600	180	205.0	0.83	0.51	0.34 Y	Υ	VAV 4.4	
419 L4 HuddleCorridor	Corridor	0	0	0.06	608	0	-	-	36	0.8	46	50	55	17	55.0	0.83	0.52	1.00 Y	Υ	VAV 4.3	flow rounded up to allow for Evz ~ 0.5
426 L4 HuddleRm_452	Huddle	5	5	0.06	103	48	Y	-	31	0.8	39	100	100	30	50.0	0.78	0.57	0.50 Y	Υ	VAV 4.2	
427 L4 HuddleRm_454	Huddle	5	5	0.06	99	50	Y	-	31	0.8	39	100	100	30	50.0	0.77	0.57	0.50 Y	Υ	VAV 4.2	
428 L4 HuddleRm_455	Huddle	5	5	0.06	107	47	Y	-	31	0.8	39	122	122	37	50.0	0.79	0.56	0.41 Y	Υ	VAV 4.2	
429 L4 HuddleRm_456	Huddle	5	5	0.06	124	40	Y	-	32	0.8	41	100	100	30	50.0	0.81	0.54	0.50 Y	Y	VAV 4.2	
430 L4 HuddleRm_457	Huddle	5	5	0.06	101	49	Y	-	31	0.8	39	122	122	37	50.0	0.78	0.57	0.41 Y	Y	VAV 4.2	
431 L4 HuddleRm_459	Huddle	5	5	0.06	101	49	Y	-	31	0.8	39	122	122	37	50.0	0.78	0.57	0.41 Y	Y	VAV 4.2	
432 L4 HuddleRm_460	Huddle	5	5	0.06	146	34	Y	-	34	0.8	42	100	100	30	50.0	0.84	0.50	0.50 Y	Y	VAV 4.20	
433 L4 HuddleRm_461	Huddle	5	5	0.06	101	49	Y	-	31	0.8	39	122	122	37	50.0	0.78	0.57	0.41 Y	Y	VAV 4.2	
434 L4 HuddleRm_462 435 L4 HuddleRm 463	Huddle Huddle	5	5	0.06	100	50 49	Y Y	-	31	0.8	39 39	100 122	100 122	30 37	50.0	0.77	0.57	0.50 Y	Y V	VAV 4.20 VAV 4.2	
436 L4 HuddleRm 464	Huddle	5	5	0.06	100	50	Y	-	31	0.8	39	100	100	30	50.0	0.78	0.57	0.41 Y 0.50 Y	T V	VAV 4.2 VAV 4.2	
437 L4 HuddleRm 465	Huddle	5	5	0.06	100	49	Y	-	31	0.8	39	122	122	37	50.0	0.77	0.57	0.50 Y 0.41 Y	' V	VAV 4.20 VAV 4.20	
438 L4 HuddleRm 466	Huddle	5	5	0.06	100	50	Y	-	31	0.8	39	100	100	30	50.0	0.78	0.57	0.41 T 0.50 Y	Y	VAV 4.2	
439 L4 HuddleRm 467	Huddle	5	5	0.06	152	33	Y	-	34	0.8	43	122	122	37	55.0	0.78	0.57	0.45 Y	Ϋ́	VAV 4.20	
440 L4 HuddleRm 468	Huddle	5	5	0.06	100	50	Y	-	31	0.8	39	100	100	30	50.0	0.77	0.57	0.50 Y	Ϋ́	VAV 4.2	
441 L4 HuddleRm 470	Huddle	5	5	0.06	97	51	Y	-	31	0.8	39	100	100	30	50.0	0.77	0.57	0.50 Y	Ϋ́	VAV 4.30	
442 L4 HuddleRm_471	Huddle	5	5	0.06	101	49	Y	-	31	0.8	39	122	122	37	50.0	0.78	0.57	0.41 Y	Y	VAV 4.3	
443 L4 HuddleRm_473	Huddle	5	5	0.06	101	50	Y	-	31	0.8	39	122	122	37	50.0	0.78	0.57	0.41 Y	Υ	VAV 4.3	
447 L4 OfficeZoneB_483_Ext1	Workspace	5	17	0.06	1022	17	-	-	146	0.8	183	600	600	180	220.0	0.83	0.51	0.37 Y	Υ	VAV 4.20	
448 L4 OfficeZoneB_483_Ext2	Workspace	5	17	0.06	1067	16	-	-	149	0.8	186	600	600	180	225.0	0.83	0.52	0.38 Y	Υ	VAV 4.2	
449 L4 OfficeZoneB_483_Ext3	Workspace	5	17	0.06	1093	16	-	-	151	0.8	188	600	600	180	225.0	0.84	0.51	0.38 Y	Υ	VAV 4.3	
450 L4 OfficeZoneB_483_Ext4	Workspace	5	17	0.06	1166	15	-		155	0.8	194	600	600	180	230.0	0.84	0.50	0.38 Y	Υ	VAV 4.3	
451 L4 OfficeZoneB_483_Int1	Workspace	5	8	0.06	435	18	-		66	0.8	83	150	150	45	100.0	0.83	0.52	0.67 Y	Υ	VAV 4.2	
452 L4 OfficeZoneB_483_Int2	Workspace	5	8	0.06	454	18	-		67	0.8	84	150	150	45	100.0	0.84	0.51	0.67 Y	Υ	VAV 4.2	
453 L4 OfficeZoneB_483_Int3	Workspace	5	8	0.06	465	17	-	-	68	0.8	85	150	150	45	105.0	0.81	0.54	0.70 Y	Υ	VAV 4.39	
454 L4 OfficeZoneB_483_Int4	Workspace	5	8	0.06	496	16	-	-	70	0.8	87	150	150	45	105.0	0.83	0.52	0.70 Y	Υ	VAV 4.4	
460 L4 QuietRm_477	Huddle	5	6	0.06	251	24	-	-	45	0.8	56	200	200	60	70.0	0.80	0.54	0.35 Y	Υ	VAV 4.3	
466 L4 Storage_476	Storage	5	0	0.12	54	0	-	-	6	0.8	8	25	25	8	10.0	0.81	0.54	0.40 Y	Υ	VAV 4.3	
				DCV Total	2829								26845		13650						
															Stan #	min % peak	30%				

225121/CGB CNY FAB

18 April 2014

one	Occupancy	D-	Da dos	D _a	A ~~	Donoite	CO2	DCV	Vbz	Ez	Voz	Vdz-uncor	Vdz-des	Vdz-min-uncor	Vdz-min	Zdz	Evz	Ds V	/dz-min-	Vdz-des >	VAV	
one	Occupancy Category	Rp	Pz-des	Ra cfm/sf	Az sf	Density pp/1000SF	CO2 for LEED?		v dz cfm	EZ	cfm	vaz-uncor cfm				Zaz	Evz			Vdz-min	VAV	
3 L2 CollabArea 208	Workspace	cfm/p	person 10	0.06	367	27	Y	101 90.17	72	0.8	90	225	225	cfm 68	cfm 115.0	0.78	0.51	I 0.51 Y	uncorr	V	VAV 2.4	
L2 CollabArea 240	Workspace	5	20	0.06	939	21	-	-	156	0.8	156	475	475	143	200.0	0.78	0.51	0.31 T		Y	VAV 2.4 VAV 2.9	
L2 HubLounge_251	Lobby	5	16	0.06	939	17	-		136	0.8	170	488	488	146	215.0	0.78	0.51	0.42 T		Y	VAV 2.3 VAV 2.16	
5 L2 HuddleRm 210	Huddle	5	5	0.06	126	40	Y	-	33	0.8	41	100	100	30	55.0	0.79	0.56	0.44 T 0.55 Y		Y	VAV 2.10 VAV 2.10	
5 L2 HuddleRm 212	Huddle	5	5	0.06	100	50	Y	-	31	0.8	39	100	100	30	50.0	0.74	0.50	0.55 Y		Y	VAV 2.10 VAV 2.10	
		5	5		100	50	Y	-	31	0.8	39	100	100	30	50.0					Y		
7 L2 HuddleRm_214	Huddle Huddle	5	5	0.06	97		Y	-	31	0.8		100	100	30	50.0	0.78	0.52	0.50 Y		Y	VAV 2.11	
8 L2 HuddleRm_216			3	0.06		51		-			39						0.52	0.50 Y		Y	VAV 2.11	
9 L2 HuddleRm_218	Huddle	5	5	0.06	135	37	Y	-	33	0.8	41	100	100	30	55.0	0.75	0.54	0.55 Y		•	VAV 2.14	
0 L2 HuddleRm_220	Huddle	5	3	0.06	108	46	Y	-	31	0.8	39	100	100	30	50.0	0.79	0.51	0.50 Y		Y Y	VAV 2.14	
5 L2 Library_235	Workspace	5	23	0.06	983	23	-	-	174	0.8	218	525	525	158	275.0	0.79	0.50	0.52 Y		•	VAV 2.7	
8 L2 OfficeZoneA_231_Ext1	Workspace	5	14	0.06	931	15	-	-	126	0.8	157	450	450	135	200.0	0.79	0.51	0.44 Y		Y	VAV 2.5	
L2 OfficeZoneA_231_Ext2	Workspace	5	14	0.06	1042	13	-	-	132	0.8	166	450	450	135	210.0	0.79	0.51	0.47 Y		Y	VAV 2.6	
L2 OfficeZoneC_215_Ext1	Workspace	5	6	0.06	505	12	-	-	60	0.8	75	200	200	60	95.0	0.79	0.50	0.48 Y		Y	VAV 2.3	
L2 OfficeZoneC_215_Ext2	Workspace	5	12	0.06	822	15		-	109	0.8	137	450	450	135	175.0	0.78	0.51	0.39 Y		Y	VAV 2.12	
L2 OfficeZoneC_215_Ext3	Workspace	5	10	0.06	746	13	-	-	95	0.8	118	450	450	135	150.0	0.79	0.50	0.33 Y		Υ	VAV 2.13	
L2 Pantry_240A	Storage	5	3	0.12	136	22	-	-	31	0.8	39	50	75	23	75.0	0.52	0.77	1.00 Y		Υ	VAV 2.9	100% of exhaust supplied
L2 SwingSpace_209	Swing	5	12	0.06	561	21	-	-	94	0.8	117	400	400	120	150.0	0.78	0.51	0.38 Y		Υ	VAV 2.3	
L3 CollabArea_308	Workspace	5	10	0.06	367	27	Y	-	72	0.8	90	225	225	68	115.0	0.78	0.51	0.51 Y		Υ	VAV 3.4	
L3 CollabArea_335	Huddle	5	5	0.06	101	50	Y	-	31	0.8	39	100	100	30	50.0	0.78	0.52	0.50 Y		Υ	VAV 3.7	
L3 CollabArea_340	Workspace	5	20	0.06	989	20	-	-	159	0.8	159	475	475	143	205.0	0.78	0.52	0.43 Y		Υ	VAV 3.9	
L3 HubLounge_351	Lobby	5	16	0.06	746	21	-	-	125	0.8	156	488	488	146	200.0	0.78	0.51	0.41 Y		Υ	VAV 3.16	
L3 HuddleRm_310	Huddle	5	5	0.06	126	40	Y	-	33	0.8	41	100	100	30	55.0	0.74	0.56	0.55 Y		Υ	VAV 3.10	
L3 HuddleRm_312	Huddle	5	5	0.06	100	50	Y	-	31	0.8	39	100	100	30	50.0	0.78	0.52	0.50 Y		Υ	VAV 3.10	
L3 HuddleRm_314	Huddle	5	5	0.06	100	50	Y	-	31	0.8	39	100	100	30	50.0	0.78	0.52	0.50 Y		Υ	VAV 3.11	
L3 HuddleRm_316	Huddle	5	5	0.06	97	51	Y	-	31	0.8	39	100	100	30	50.0	0.77	0.52	0.50 Y		Υ	VAV 3.11	
L3 HuddleRm 318	Huddle	5	5	0.06	135	37	Y	-	33	0.8	41	100	100	30	55.0	0.75	0.54	0.55 Y		Υ	VAV 3.14	
L3 HuddleRm 320	Huddle	5	5	0.06	108	46	Y	-	31	0.8	39	100	100	30	50.0	0.79	0.51	0.50 Y		Υ	VAV 3.14	
L3 OfficeZoneA 331 Ext2	Workspace	5	14	0.06	1039	13	-	_	132	0.8	165	450	450	135	210.0	0.79	0.51	0.47 Y		Υ	VAV 3.6	
L3 OfficeZoneA 331 Ext1	Workspace	5	14	0.06	931	15	-	_	126	0.8	157	450	450	135	200.0	0.79	0.51	0.44 Y		Ϋ́	VAV 3.5	
L3 OfficeZoneC 315 Ext3	Workspace	5	12	0.06	822	15	-	_	109	0.8	137	450	450	135	175.0	0.78	0.51	0.39 Y		Ϋ́	VAV 3.12	
L3 OfficeZoneC_315_Ext4	Workspace	5	10	0.06	940	11	-	_	106	0.8	133	450	450	135	170.0	0.78	0.51	0.38 Y		Y	VAV 3.13	
L3 OfficeZoneC 315 Ext2	Workspace	5	6	0.06	468	13	-	_	58	0.8	73	200	200	60	95.0	0.76	0.53	0.48 Y		Y	VAV 3.3	
L3 OfficeZoneC_315_Ext1	Workspace	5	0	0.06	36	0	-	_	2	0.8	3	50	50	15	15.0	0.18	1.12	0.30 Y		Y	VAV 3.3	
L3 Pantry_340A	Storage	5	3	0.12	136	22	_	_	31	0.8	39	50	75	23	75.0	0.52	0.77	1.00 Y		Y	VAV 3.9	100% of exhaust supplied
L3 SwingSpace_309	Swing	5	12	0.06	561	21	-	_	94	0.8	117	400	400	120	150.0	0.78	0.51	0.38 Y		Ÿ	VAV 3.3	100% of exhaust supplies
3 L4 CollabArea 408	Workspace	5	10	0.06	367	27	Y	_	72	0.8	90	225	225	68	115.0	0.78	0.51	0.51 Y		Ϋ́	VAV 4.4	
L4 CollabArea 439	Huddle	5	5	0.06	101	49	<u>Y</u>	_	31	0.8	39	150	150	45	50.0	0.78	0.51	0.33 Y		Ϋ́	VAV 4.7	
5 L4 CollabArea 440	Workspace	5	20	0.06	935	21	-	-	156	0.8	195	475	475	143	250.0	0.78	0.52	0.53 Y		Y	VAV 4.7 VAV 4.9	
L4 HubLounge_451	Lobby	5	16	0.06	747	21	-	-	125	0.8	156	488	488	146	200.0	0.78	0.51	0.33 T		Y	VAV 4.3 VAV 4.17	
L4 HuddleRm 410		5	5		1	40				1						0.78				Y		
	Huddle	5	5	0.06	126		Y Y	-	33	0.8	41	100	100	30	55.0		0.56	0.55 Y		Y	VAV 4.10	
L4 HuddleRm_412	Huddle		Ü	0.06	100	50		-	31	0.8	39	100	100		50.0	0.78	0.52	0.50 Y		Y	VAV 4.10	
2 L4 HuddleRm_414	Huddle	5	5	0.06	100	50	Y	-	31	0.8	39	100	100	30	50.0	0.78	0.52	0.50 Y		Y V	VAV 4.11	
L4 HuddleRm_416	Huddle	5	5	0.06	97	51	Y	-	31	0.8	39	100	100	30	50.0	0.77	0.52	0.50 Y			VAV 4.11	
L4 HuddleRm_418	Huddle	5	5	0.06	135	37	Y	-	33	0.8	41	100	100	30	55.0	0.75	0.54	0.55 Y		Y	VAV 4.14	
L4 HuddleRm_420	Huddle	5	5	0.06	108	46	Y	-	31	0.8	39	100	100	30	50.0	0.79	0.51	0.50 Y		I	VAV 4.14	
L4 OfficeZoneA_431_Ext2	Workspace	5	14	0.06	999	14	-	-	130	0.8	162	600	600	180	205.0	0.79	0.50	0.34 Y		Y	VAV 4.6	
L4 OfficeZoneA_431_Ext1	Workspace	5	14	0.06	894	16	-	-	124	0.8	155	600	600	180	195.0	0.79	0.50	0.33 Y		Υ	VAV 4.5	
L4 OfficeZoneC_415_Ext2	Workspace	5	12	0.06	822	15	-	-	109	0.8	137	450	450	135	175.0	0.78	0.51	0.39 Y		Y	VAV 4.12	
L4 OfficeZoneC_415_Ext3	Workspace	5	10	0.06	940	11	-	-	106	0.8	133	450	450	135	170.0	0.78	0.51	0.38 Y		Υ	VAV 4.13	
L4 OfficeZoneC_415_Ext1	Workspace	5	6	0.06	472	13	-	-	58	0.8	73	200	200	60	95.0	0.77	0.53	0.48 Y		Υ	VAV 4.3	
L4 Pantry_440A	Storage	5	3	0.12	136	22	-	-	31	0.8	39	50	75	23	75.0	0.52	0.77	1.00 Y		Υ	VAV 4.9	100% of exhaust supplie
L4 SwingSpace_409	Swing	5	12	0.06	549	22	-	-	93	0.8	116	400	400	120	150.0	0.77	0.52	0.38 Y		Υ	VAV 4.3	
				DCV Total	1468	1							13914	l L [6130 Step #:	min % peak	30% 0.85					
														-	6 7	Vou (cfm)	3483					
														-	8	Xs						
														}		Ev						
														-	10							
															11	Vot	6948					

225121/CGB CNY FAB

18 April 2014

Zone	Occupancy	Rp	Pz-des	Ra	Az	Density	CO2	Step #: DCV	Vbz	Ez	Voz	Vdz-uncor	Vdz-des	Vdz-min-uncor	Vdz-min	Zdz	9 Evz
Zone	Category	cfm/p	person	cfm/sf	sf		for LEED?		cfm	EZ	cfm	cfm	cfm	cfm	cfm	Zuz	EVZ
3 L0 Corridor B0041	Corridor	0	0	0.06	424	0	-	-	25	0.8	32	50	50	15	45.0	0.71	0.51
4 L0 Corridor B0043	Corridor	0	0	0.06	401	0	-	_	24	0.8	30	25	50	15	45.0	0.67	0.55
7 L0 CustodialRecycling B0061	Corridor	0	0	0.06	580	0	-	-	35	0.8	44	50	65	20	65.0	0.67	0.55
8 L0 EFRm B11	MEP	5	0	0.06	37	0	-	-	2	0.8	3	25	25	8	10.0	0.28	0.94
11 L0 EventStorage_B16	Storage	5	0	0.12	410	0	-	-	49	0.8	62	25	90	27	90.0	0.68	0.54
13 L0 FoodPrep_B04	Food	8	2	0.18	641	3	-	-	130	0.8	163	700	930	279	930.0	0.18	1.05
15 L0 FoodServOff_B04C	Workspace	5	1	0.06	84	12	-	-	10	0.8	13	50	50	15	20.0	0.63	0.59
16 L0 FoodStorage_B04A	Storage	0	0	0.00	0	#DIV/0!	#DIV/0!	-	0	0.8	0	25	75	23	75.0	0.00	1.22
17 L0 FoodWaste_B04D	MEP	0	0	0.00	0	#DIV/0!	#DIV/0!	-	0	0.8	0	925	925	278	925.0	0.00	1.22
34 L0 WalkInRefrig_B04B	Storage	5	0	0.12	122	0	-	-	15	0.8	18	50	50	15	30.0	0.61	0.61
103 L1 BathroomMen_10020	Corridor	0	0	0	0	#DIV/0!	#DIV/0!	-	0	0.8	0	25	180	54	180.0	0.00	1.22
104 L1 BathroomWomen_10021	Corridor	0	0	0	0	#DIV/0!	#DIV/0!	-	0	0.8	0	25	180	54	180.0	0.00	1.22
105 L1 Cafe_101_SE1	Cafe	8	20	0.18	482	41	Y	-	237	0.8	296	675	675	203	415.0	0.71	0.51
106 L1 Cafe_101_SE2	Cafe	8	20	0.18	569	35	Y	-	252	0.8	316	700	700	210	440.0	0.72	0.50
107 L1 Cafe_101_SW1	Cafe	8	44	0.18	703	63	Y	Y	457	0.8	571	1800	1800	540	795.0	0.72	0.50
108 L1 Cafe_101_SW2	Cafe	8	28	0.18	433	65	Y	-	288	0.8	360	950	950	285	505.0	0.71	0.51
109 L1 Cafe_101_W	Cafe	8	5	0.18	250	20	-	-	82	0.8	103	750	750	225	225.0	0.46	0.76
138 L1 MainLounge_115_Ext1	Lobby	5	16	0.06	319	50	Y	-	99	0.8	124	625	625	188	190.0	0.65	0.57
139 L1 MainLounge_115_Ext2	Lobby	5	4	0.06	249	16	-	-	35	0.8	44	325	325	98	100.0	0.44	0.78
140 L1 MainLounge_115_Ext3	Lobby	5	10	0.06	234	43	Y	-	64	0.8	80	350	350	105	115.0	0.70	0.52
141 L1 MainLounge_115_Ext4	Lobby	5	40	0.06	573	70	Y	Y	234	0.8	293	1050	1050	315	410.0	0.71	0.51
142 L1 MainLounge_115_Int	Lobby	5	31	0.06	561	55	Y	Y	189	0.8	236	750	750	225	330.0	0.71	0.51
159 L1 Servery_108_E	Food	8	9	0.18	423	21	-	-	144	0.8	179	1100	1100	330	330.0	0.54	0.68
160 L1 Servery_108_SE	Food	8	15	0.18	732	21	-	-	244	0.8	305	925	925	278	425.0	0.72	0.50
161 L1 Servery_108_SW	Food	8	8	0.18	364	22	-	-	126	0.8	157	575	575	173	220.0	0.71	0.51
162 L1 ServiceCorridor_10040	Corridor	0	0	0.06	152	0	-	-	9	0.8	11	25	25	8	20.0	0.57	0.65
163 L1 Storage_104	Food	8	1	0.18	167	6	-	-	38	0.8	47	100	200	60	100.0	0.47	0.75
169 L1 VestMen_10054	Corridor	0	0	0	0	#DIV/0!	#DIV/0!	-	0	0.8	0	25	45	14	45.0	0.00	1.22
172 L1 VestWomen_10053	Corridor	0	0	0	0	#DIV/0!	#DIV/0!	-	0	0.8	0	25	45	14	45.0	0.00	1.22
				DCV Total	1138								13560		7305		
						_									Stan #-	min % neak	20%

	Ds	Vdz-min > Vdz-min- uncorr	Vdz-des > Vdz-min	VAV	
	0.90	Υ	Υ	VAV 0.2	
1	0.90	Υ	Υ	VAV 0.4	flow rounded up to allow for Evz ~ 0.5
1	1.00	Υ	Υ	VAV 0.3	490 cfm exhaust, pressurization handled by SF
1	0.40	Υ	Υ	VAV 0.4	
1	1.00	Υ	Υ	VAV 0.4	flow rounded up to allow for Evz ~ 0.5
1	1.00	Υ	Υ	VAV 0.1	230 cfm exhaust
1	0.40	Υ	Υ	VAV 0.1	
1	1.00	Υ	Υ	VAV 0.1	100% of exhaust supplied
1	1.00	Υ	Υ	VAV 0.2	100% of exhaust supplied
1	0.60	Υ	Υ	VAV 0.1	
1	1.00	Υ	Υ	VAV 1.12	80% of supply to 103 L1 BathroomMen_10020
1	1.00	Υ	Υ	VAV 1.12	80% of supply to 104 L1 BathroomWomen_10021
1	0.61	Υ	Υ	VAV 1.7	
1	0.63	Υ	Υ	VAV 1.6	
1	0.44	Υ	Υ	VAV 1.2 & VAV 1.40	
1	0.53	Υ	Υ	VAV 1.5	
1	0.30	Υ	Υ	VAV 1.1	
1	0.30	Υ	Υ	VAV 1.10 (650/190)	
1	0.31	Υ	Υ	VAV 1.9 (250/100)	
1	0.33	Υ	Υ	VAV 1.9 (200/60) & 1.13 (200/55)	
1	0.39	Υ	Υ	VAV 1.13 (210/85) & 1.14 (840/325)	
1	0.44	Υ	Υ	VAV 1.11	
1	0.30	Υ	Υ	VAV 1.11 (820/330)	300 cfm exhaust
1	0.46	Υ	Υ	VAV 1.8 (1205/425)	200 cfm exhaust
1	0.38	Υ	Υ	VAV 1.4	200 cfm exhaust
1	0.80	Υ	Υ	VAV 1.3	
1	0.50	Υ	Υ	VAV 1.3	100 cfm exhaust
1	1.00	Υ	Υ	VAV 1.12	20% of supply to 103 L1 BathroomMen_10020
1	1.00	Υ	Υ	VAV 1.12	20% of supply to 104 L1 BathroomWomen_10021
_					29
1					

7305		
Step #:	min % peak	30%
5	D	0.85
6	Vou (cfm)	2541
7	Vps	11526
8	Xs	0.220
10	Ev	0.50
11	Vot	5058
•	Zmax	0.72

225121/CGB CNY FAB

18 April 2014

								Step #:	1	2	3	1				4	9	Vdz	-min > ,			
Zone	Occupancy	Rp	Pz-des	Ra	Az	Density	CO2	DCV	Vbz	Ez	Voz	Vdz-uncor	Vdz-des	Vdz-min-uncor	Vdz-min	Zdz	Evz		7-min- \	/dz-des		
	Category	cfm/p	person	cfm/sf	sf	pp/1000SF	for LEED?	for 90.1?	cfm		cfm	cfm	cfm	cfm	cfm			u	ıcorr	Vdz-mii	1	
1 L0 Bathroom_B00A	Corridor	0	0	0.00	0	#DIV/0!	#DIV/0!	-	0	0.8	0	75	585	176	585.0	0.00	1.35	1.00 Y	Υ		VAV 0.9	100% of supply to 1 L0 Bathroom_B00A corridor
2 L0 Bathroom_B00B	Corridor	0	0	0.00	0	#DIV/0!	#DIV/0!	-	0	0.8	0	50	840	252	840.0	0.00	1.35	1.00 Y	Υ		VAV 0.12	100% of supply to 1 L0 Bathroom_B00A corridor
5 L0 Corridor_B0050	Corridor	0	0	0.06	882	0	-	-	53	0.8	66	75	80	24	80.0	0.83	0.52	1.00 Y	Υ		8.0 VAV	flow rounded up to allow for Evz ~ 0.5
6 L0 Corridor_Int	Corridor	0	0	0.06	238	0	-	-	14	0.8	18	50	50	15	25.0	0.71	0.64	0.50 Y	Υ		VAV 0.7	
12 L0 SecEquipRm_B0070	MEP	5	3	0.06	241	12	-	-	29	0.8	37	50	50	15	45.0	0.82	0.53	0.90 Y	Υ		8.0 VAV	
19 L0 ITDepot_B72	IT	5	0	0.06	147	0	-	-	9	0.8	11	575	575	173	175.0	0.06	1.29	0.30 Y	Υ		8.0 VAV	
20 L0 Janitor_B0079	Corridor	0	0	0.00	0	#DIV/0!	#DIV/0!	-	0	0.8	0	25	75	23	75.0	0.00	1.35	1.00 Y	Υ		VAV 0.9	janitor supply to adjacent corridor
21 L0-1 Lecture Hall_131_Ext	Lecture	8	68	0.06	862	79	Y	Y	562	0.8	702	1625	1625	488	825.0	0.85	0.50	0.51 Y	Υ		VAV 1.15	
22 L0 LockerRm_B80	Corridor	0	5	0.06	423	12	-	-	25	0.8	32	75	75	23	40.0	0.79	0.56	0.53 Y	Υ		VAV 0.14	
24 L0 MainElecRm_B0068	MEP	5	0	0.06	78	0	-	-	5	0.8	6	25	25	8	10.0	0.59	0.76	0.40 Y	Υ		8.0 VAV	
25 L0 FirePumpRm_B0069	MEP	5	0	0.06	276	0	-	-	17	0.8	21	25	25	8	25.0	0.83	0.52	1.00 Y	Υ		VAV 0.14	
26 L0 Seminar_B61	Seminar	8	72	0.06	1147	63	Y	Y	609	0.8	761	1450	1450	435	895.0	0.85	0.50	0.62 Y	Υ		VAV 0.10	
27 L0 Seminar_B73	Seminar	8	74	0.06	1175	63	Y	Y	626	0.8	782	1475	1475	443	920.0	0.85	0.50	0.62 Y	Υ		VAV 0.11	
28 L0 Seminar_B81	Seminar	8	55	0.06	1175	47	Y	Y	483	0.8	604	1250	1250	375	710.0	0.85	0.50	0.57 Y	Υ		VAV 0.13	
29 L0 Seminar_B91	Seminar	8	55	0.06	1183	46	Y	Y	483	0.8	604	1275	1275	383	710.0	0.85	0.50	0.56 Y	Υ		VAV 0.15	
31 L0 Storage_B82	Storage	5	2	0.12	87	23	-	-	20	0.8	26	25	30	9	30.0	0.85	0.50	1.00 Y	Υ		VAV 0.14	flow rounded up to allow for Evz ~ 0.5
33 L0 Vestibule_B0048	Corridor	0	0	0.06	98	0	-	-	6	0.8	7	25	25	8	10.0	0.73	0.62	0.40 Y	Υ		8.0 VAV	
38 L0-1 Lecture Hall_131_Int	Lecture	8	68	0.06	886	77	Y	Y	563	0.8	704	1275	1275	383	830.0	0.85	0.50	0.65 Y	Υ		VAV 1.16	
133 L1 LectureHall_131	Lecture	8	68	0.06	916	74	Y	Y	565	0.8	706	1275	1275	383	830.0	0.85	0.50	0.65 Y	Υ		VAV 1.17	
157 L1 SeminarRm_161	Seminar	8	94	0.06	1108	85	Y	Y	771	0.8	964	2050	2050	615	1135.0	0.85	0.50	0.55 Y	Υ		VAV 1.23	
158 L1 SeminarRm_165	Seminar	8	94	0.06	1134	83	Y	Y	773	0.8	966	2075	2075	623	1135.0	0.85	0.50	0.55 Y	Υ		VAV 1.24	
				DCV Total	729								16185]	9930							
															Step #:	min % peak	30%					
															5	D	0.9					
															6	Vou (cfm)	5125					

Vps 14567 Xs 0.352 Ev 0.50 Vot 10278 Zmax 0.85

10 11

J:N-Yi220000'225121-00'4 Internal Project Data\4-04 Calculations\4-04-06 Mech\Ventilation\
CD ventilation calculations.xism: AHU-4 Seminar

Arup | F0.13 | 14 February 2011

225121/CGB CNY FAB

18 April 2014

								Step #:	1	2	3	1				4	9	Vdz-min >			
Zone	Occupancy	Rp	Pz-des	Ra	Az	Density	CO2	DCV	Vbz	Ez	Voz	Vdz-uncor	Vdz-des	Vdz-min-uncor	Vdz-min	Zdz	Evz	Ds Vdz-min-	Vdz-des > Vdz-min	VAV	
9 L0 ElevCntrRm B0066	Category MEP	cfm/p	person 2	cfm/sf 0.06	sf 161	pp/1000SF	for LEED?	for 90.1?	20	0.8	cfm 25	cfm 25	cfm 40	cfm 12	cfm 40.0	0.61	0.55	1.00 Y		VAV 0.6	flow rounded up to allow for Evz ~ 0.5
14 L0 Storage B15	Storage	5	2	0.12	306	7	-	-	47	0.8	58	50	90	27	90.0	0.65	0.52	1.00 Y		VAV 0.5	flow rounded up to allow for Evz ~ 0.5
18 L0 FuelOilRm_B0065	MEP	5	0	0.06	132	0	-	-	8	0.8	10	25	25	8	15.0	0.66	0.51	0.60 Y		VAV 0.7	
23 L0 LowerFoyer_B0046	Swing	5	57	0.06	1893	30	Y	-	399	0.8	498	1375	1375	413	745.0	0.67	0.50	0.54 Y	′ \	VAV 0.6	
30 L0 Storage_B32	Storage	5	2	0.12	148	14	-	-	28	0.8	35	50	55	17	55.0	0.63	0.54	1.00 Y		VAV 0.7	flow rounded up to allow for Evz ~ 0.5
35 L0 WaterServ_B0067	MEP	5	0	0.06	392	0	-	-	24	0.8	29	25	45	14	45.0	0.65	0.52	1.00 Y 0.30 Y		VAV 0.6	flow rounded up to allow for Evz ~ 0.5
101 L1-4 Atrium 102 L1 Bathroom	Lobby Corridor	5	6	0.06	355	17 #DIV/0!	#DIV/0!	-	51 0	0.8	64	2750 50	2750 960	825 288	825.0 960.0	0.08	1.09	0.30 Y 1.00 Y		VAV 4.18 (1375/410) & 4.43 (1375/415) VAV 1.25	80% of supply to 102 L1 Bathroom
111 L1 Corridor 10045	Corridor	0	0	0.06	120	#DIV/0:	#DIV/0:	-	7	0.8	9	25	25	8	15.0	0.60	0.57	0.60 Y		VAV 1.25	30 % of supply to 102 L1 Baunoom
112 L1 Corridor 10049	Corridor	0	0	0.06	341	0	-	-	20	0.8	26	25	50	15	40.0	0.64	0.53	0.80 Y		VAV 1.26	flow rounded up to allow for Evz ~ 0.5
113 L1 Corridor_10050	Corridor	0	0	0.06	643	0	-	-	39	0.8	48	50	75	23	75.0	0.64	0.53	1.00 Y		VAV 1.26	flow rounded up to allow for Evz ~ 0.5
114 L1 ElecRm_10068	MEP	5	0	0.06	102	0	-	-	6	0.8	8	25	25	8	15.0	0.51	0.66	0.60 Y		VAV 1.26	'
115 L1 ElevLobby_10046_Int1	Lobby	5	12	0.06	1411	9	-	-	145	0.8	181	400	400	120	270.0	0.67	0.50	0.68 Y		VAV 1.18 (225/135) & 1.19 (225/135)	
116 L1 ElevLobby_Int2	Lobby	5	10	0.06	1232	8	- "	-	124	0.8	155	350	350 75	105	235.0	0.66	0.51	0.67 Y 1.00 Y		VAV 1.19 (300/235)	
130 L1 Janitor_10065 136 L1 MailRm 154	Corridor Huddle	5	2	0.06	297	#DIV/0!	#DIV/0!	-	28	0.8	35	25 125	125	23 38	75.0 55.0	0.00	1.17 0.54	1.00 Y 0.44 Y		VAV 1.25 VAV 1.41	janitor supply to adjacent corridor
137 L1 MainDisconnect 10070	MEP	5	0	0.06	120	0	-	-	7	0.8	9	25	25	8	15.0	0.60	0.57	0.60 Y		VAV 1.41 VAV 1.26	
143 L1 MainLobby 10047 Ext1	Lobby	5	8	0.06	765	10	_	_	86	0.8	107	600	600	180	180.0	0.60	0.57	0.30 Y		VAV 1.14 (300/90) & 1.22 (300/90)	
144 L1 MainLobby_10047_Ext2	Lobby	5	4	0.06	383	10	-	-	43	0.8	54	325	325	98	100.0	0.54	0.63	0.31 Y		VAV 1.21	
155 L1 Reception_152	Lobby	5	2	0.06	302	7	-	-	28	0.8	35	75	75	23	55.0	0.64	0.53	0.73 Y		VAV 1.20	
156 L1 RPZ_10063	MEP	5	0	0.06	32	0	-	-	2	0.8	2	25	25	8	10.0	0.24	0.93	0.40 Y		VAV 1.26	
164 L1 Storage_163	Storage	5	1	0.12	46	22	-	-	10	0.8	13	25	25	8	20.0	0.66	0.51	0.80 Y		VAV 1.26	
165 L1 Storage_167	Storage	5	0	0.12	78	0	-	-	9	0.8	12	25	25	8	20.0	0.59	0.58	0.80 Y		VAV 1.26	2000 6 1 1 1027 1 2
168 L1 VestMen_10028	Corridor	0	0	0	0	#DIV/0!	#DIV/0!	-	0	0.8	0	25	120	36	120.0	0.00	1.17	1.00 Y		VAV 1.25	20% of supply to 102 L1 Bathroom
171 L1 VestWomen_10026 202 L2 Bathroom	Corridor Corridor	0	0	0.00	0	#DIV/0! #DIV/0!	#DIV/0! #DIV/0!	-	0	0.8	0	25 50	120 1080	36 324	120.0 1080.0	0.00	1.17	1.00 Y 1.00 Y		VAV 1.25 VAV 2.18	20% of supply to 102 L1 Bathroom 80% of supply to 202 L2 Bathroom
207 L2 ConferenceRm_201	Conference	5	40	0.06	968	#DIV/0:	#DIV/0:	- Y	258	0.8	323	1000	1000	300	485.0	0.67	0.50	0.49 Y		VAV 2.16 VAV 2.1	80% of supply to 202 L2 Bathroom
208 L2 ConferenceRm 238	Conference	5	10	0.06	259	39	Y	-	66	0.8	82	200	200	60	125.0	0.66	0.51	0.43 Y		VAV 2.1	
209 L2 Corridor_20041	Corridor	0	0	0.06	1310	0	-	-	79	0.8	98	100	150	45	150.0	0.66	0.51	1.00 Y		VAV 2.15	flow rounded up to allow for Evz ~ 0.5
210 L2 Corridor_20050	Corridor	0	0	0.06	1602	0	-	-	96	0.8	120	125	180	54	180.0	0.67	0.50	1.00 Y		VAV 2.17	flow rounded up to allow for Evz ~ 0.5
211 L2 ElecRm_20065	MEP	5	0	0.06	124	0	-	-	7	0.8	9	25	25	8	15.0	0.62	0.55	0.60 Y		VAV 2.15	
212 L2 ElecRm_20068	MEP	5	0	0.06	103	0	-	-	6	0.8	8	25	25	8	15.0	0.52	0.65	0.60 Y		VAV 2.17	
244 L2 Janitor_20069	Corridor	0	0	0.00	0	#DIV/0!	#DIV/0!	-	0	0.8	0	25	75	23	75.0	0.00	1.17	1.00 Y		VAV 2.18	janitor supply to adjacent corridor
247 L2 MultipurposeRm_205	Conference	5	46	0.06	566	81 #DR//01	#DIV/0!	Y	264	0.8	330	850	850	255	495.0	0.67	0.50	0.58 Y 1.00 Y		VAV 2.2	2007 5 1 202 1 2 D 4
268 L2 VestMen_20028 269 L2 VestWomen 20026	Corridor Corridor	0	0	0.00	0	#DIV/0! #DIV/0!	#DIV/0!	-	0	0.8	0	25 25	135 135	41	135.0 135.0	0.00	1.17 1.17	1.00 Y 1.00 Y		VAV 2.18 VAV 2.18	20% of supply to 202 L2 Bathroom 20% of supply to 202 L2 Bathroom
272 L2-4 OpenSpace East	Corridor	0	0	0.06	381	πD1V/0:	πD1V/0:	-	23	0.8	29	950	950	285	285.0	0.00	1.07	0.30 Y		VAV 4.16	20 % of supply to 202 L2 Baunoom
273 L2-3 Multipurpose_S	Conference	5	0	0.06	202	0	-	-	12	0.8	15	200	200	60	60.0	0.25	0.92	0.30 Y		VAV 3.2	
302 L3 Bathroom	Corridor	0	0	0	0	#DIV/0!	#DIV/0!	-	0	0.8	0	50	1080	324	1080.0	0.00	1.17	1.00 Y		VAV 3.18	80% of supply to 302 L3 Bathroom
309 L3 ConferenceRm_301_W	Conference	5	25	0.06	598	42	Y	Y	161	0.8	201	675	675	203	305.0	0.66	0.51	0.45 Y	′ '	VAV 3.1	***
310 L3 ConferenceRm_338	Conference	5	10	0.06	259	39	Y	-	66	0.8	82	200	200	60	125.0	0.66	0.51	0.63 Y		VAV 3.8	
314 L3 Corridor_30041	Corridor	0	0	0.06	1396	0	-	-	84	0.8	105	100	160	48	160.0	0.65	0.52	1.00 Y		VAV 3.15	flow rounded up to allow for Evz ~ 0.5
315 L3 Corridor_30050	Corridor MEP	0	0	0.06	1753	0	-	-	105	0.8	132	125	200	60	200.0	0.66	0.51	1.00 Y 0.60 Y		VAV 3.17	flow rounded up to allow for Evz ~ 0.5
316 L3 ElecRm_30065 317 L3 ElecRm 30068	MEP	5	0	0.06	124 103	0	-	-	6	0.8	9	25 25	25 25	8	15.0 15.0	0.62	0.55	0.60 Y 0.60 Y		VAV 3.15 VAV 3.17	
344 L3 Janitor 30069	Corridor	0	0	0.00	0	#DIV/0!	#DIV/0!	-	0	0.8	0	25	75	23	75.0	0.00	1.17	1.00 Y		VAV 3.17	janitor supply to adjacent corridor
345 L3 MultipurposeRm 305	Conference	5	46	0.06	566	81	#D1770:	Y	264	0.8	330	850	850	255	495.0	0.67	0.50	0.58 Y		VAV 3.2	games supply to deflective contract
365 L3 VestMen_30028	Corridor	0	0	0	0	#DIV/0!	#DIV/0!	-	0	0.8	0	25	135	41	135.0	0.00	1.17	1.00 Y		VAV 3.18	20% of supply to 302 L3 Bathroom
366 L3 VestWomen_30026	Corridor	0	0	0	0	#DIV/0!	#DIV/0!	-	0	0.8	0	25	135	41	135.0	0.00	1.17	1.00 Y	′ '	VAV 3.18	20% of supply to 302 L3 Bathroom
368 L3 ConferenceRm_301_SW	Conference	5	15	0.06	370	41	Y	-	97	0.8	121	400	400	120	185.0	0.66	0.51	0.46 Y		VAV 3.1	
401 L4 ConferenceRm_401_1	Conference	5	26	0.06	572	45	Y	Y	164	0.8	205	1175	1175	353	355.0	0.58	0.59	0.30 Y		VAV 4.2	
402 L4 Bathroom	Corridor	0	0	0	570	#DIV/0!	#DIV/0!	- V	0	0.8	0	50	1080	324	1080.0	0.00	1.17	1.00 Y 0.50 Y		VAV 4.19	80% of supply to 402 L4 Bathroom
410 L4 ConferenceRm_401_2 411 L4 ConferenceRm 438	Conference Conference	5	26 10	0.06	570 259	46 39	Y	Y -	164 66	0.8	205 82	625 200	625 200	188	310.0 125.0	0.66	0.51	0.50 Y 0.63 Y		VAV 4.1 VAV 4.8	
411 L4 ConferenceRm_438 414 L4 Corridor 40041	Corridor	0	0	0.06	1404	0	- Y	-	84	0.8	105	100	160	48	160.0	0.66	0.51	0.00 .		VAV 4.8 VAV 4.15	flow rounded up to allow for Evz ~ 0.5
415 L4 Corridor 40050	Corridor	0	0	0.06	1599	0	-	-	96	0.8	120	175	180	54	180.0	0.67	0.50	1.00 Y		VAV 4.13 VAV 4.18A	flow rounded up to allow for Evz ~ 0.5
416 L4 ElecRm_40065	MEP	5	0	0.06	124	0	-	-	7	0.8	9	25	25	8	15.0	0.62	0.55	0.60 Y		VAV 4.15	and the second s
417 L4 ElecRm_40068	MEP	5	0	0.06	103	0	-	-	6	0.8	8	25	25	8	15.0	0.52	0.65	0.60 Y		VAV 4.18A	
444 L4 Janitor_40069	Corridor	0	0	0	0	#DIV/0!	#DIV/0!	-	0	0.8	0	25	75	23	75.0	0.00	1.17	1.00 Y		VAV 4.19	janitor supply to adjacent corridor
464 L4 VestMen_40028	Corridor	0	0	0	0	#DIV/0!	#DIV/0!	-	0	0.8	0	25	135	41	135.0	0.00	1.17	1.00 Y		VAV 4.19	20% of supply to 402 L4 Bathroom
465 L4 VestWomen_40026	Corridor	0	0	0	0	#DIV/0!	#DIV/0!	-	0	0.8	0	25	135	41	135.0	0.00	1.17	1.00 Y	′ '	VAV 4.19	20% of supply to 402 L4 Bathroom
				DCV Total	1509								20585	_	12940		20~	1			
															Step #:	min % peak		-			
															5	Vou (cfm)	0.7	1			
															7	Vou (CIII)		1			

12940		
Step #:	min % peak	30%
5	D	0.9
6	Vou (cfm)	3138
7	Vps	18527
8	Xs	0.169
10	Ev	0.50
11	Vot	6281
	Zmax	0.67

J:\N-Y220000|225121-00|4 Internal Project Data\4-04 Calculations\4-04-06 MechiVentilation\
CD ventilation calculations.xism : AHU-5 Conference
@ Arup | F0.13 | 14 February 2011