

04-POST FRAMING QC

General:

- ✓ All walls framed
- ✓ Fire blocking if needed any
- ✓ All bulkheads framed properly
- ✓ All Recessed ceilings framed properly, if any
- ✓ Windows replaced if needed
 - ☐ — **ADD PHOTO(S)** —
- ✓ Egress windows and walk-outs if any
 - ☐ — **ADD PHOTO(S)** —
- ✓ **Add floor sq.ft. to 03-FLOORING DETAILS**

Doors (order/lay-out/specs)

- ✓ All doors framed
 - doors framing - height - $h+2.5=82.5''$ /width - $w+2''$
 - always where possible - space for trim! - sides and top
 - If door opening shorter than 82" - make a note and discuss.
- ✓ **Add door locks types and quantities to 02-HARDWARE**
- ✓ **Add doors and trims specs to 01-DOORS AND TRIMS**
- ✓ If exterior door replaced include specs:
 - ☐ Rough opening height -
 - ☐ Rough opening width -
 - ☐ Actual door panel height -
 - ☐ Actual door panel width -
- ✓ Double check DOOR style / core / etc
- ✓ MARK DOOR SIZED AND SWINGS ON THE DOOR FRAME and on the floor
+ Email/text draft of doors to electrician and finish carpenter
- ✓ **Please note. IF ANY DOORS ARE UNDER 78" - Confirm door styles. Paneled doors do not look good when cut and we usually convince client to switch to flat doors.**
- ✓ If any doors under 80" high - send quantity to billing@achgroupllc.com -
INCLUDE PROJECT NAME

Bathroom framing:

- ✓ Blocking for shower doors if needed

☐ — ADD PHOTO(S) —



- ✓ Blocking around the tiled shower pan

☐ — ADD PHOTO(S) —

- ✓ CRITICAL FRAMING - Inside corner - vanity
- ✓ CRITICAL FRAMING - inside corners and blocks for tub or shower

✓ Add tile specs to 07-BATHROOM TILE WORK SPECS

Stairs framing:

- ✓ Half walls on the stairs are cut, if needed
☐ — **ADD PHOTO(S)** —
- ✓ or Stair walls cut for spindles railing, if needed
☐ — **ADD PHOTO(S)** —
- ✓ Half walls in the basement are framed, if any
☐ — **ADD PHOTO(S)** —
- ✓ Step sides are installed if DISCUSSED
- ✓ Under stairs blocking for drywall for fire protection
☐ — **ADD PHOTO(S)** —



- ✓ Add railing specs to 05-Stairs and railing

Wet-bar framing:

- ✓ CRITICAL FRAMING - Cabinets in the recessed space 26" minimum for base and 13" for wall cabinets (16" if crown molding)
- ✓ CRITICAL FRAMING - Bulkhead above cabinets to fit crown molding - 16" minimum

- ✓ CRITICAL FRAMING - kitchenette, wet-bar cabinets inside corner
- ✓ Blocking for wall cabinets if needed
- — **ADD PHOTO(S)** —
- ✓ Make a video(s) of site conditions and post pre-con basement and add to MEDIA note in 03-SELECTIONS AND MEDIA FOLDER